


SZS CONSULTING GROUP

DRAFT ADA TRANSITION PLAN UPDATE
NEIGHBORHOOD AREA 9 SONA
SEPTEMBER 20, 2011



CITY OF CITRUS HEIGHTS

The Sunrise Oaks Neighborhood Association (SONA)


The Sunrise Oaks Neighborhood Association (SONA) is a residential area made up of single-family homes and apartment complexes, three recreational parks, one elementary school, and multiple commercial/retail centers. The area borders are Oak Avenue, Kenneth Avenue, Elm Avenue, Fair Oaks Boulevard, Greenback Lane, and Sunrise Boulevard.

Conditions

Most of the sidewalks in the SONA Area are of pre-1992 construction, which were identified with common issues such as non-compliant cross slopes, clear width issues, abrupt changes of level, and poor surface conditions. Many pre-1992 curb ramps were identified with multiple barriers to access.

Built elements found within the public rights-of-way in the SONA Neighborhood Area were “depressed curbs” which are not actual curb cuts but depressed areas in the concrete at intersection corners that it is assumed were intended to assist with travel over the existing vertical or rolled curb.

There are also some areas on Oak Avenue where no improved sidewalk is provided within a pedestrian route that leads to a school. Bus stops along primary arterial roadways were also identified as non-compliant.



Statistics

An intersection inventory was compiled as part of the field assessment process. In the SONA Neighborhood Area, 22 intersections were found to have no barriers to access and a total of 1093 barriers were identified. The compliant intersections are identified as follows:

#	Location	Notes
1	Escallonia Dr and Beckwith Wy - Corners C,D Compliant	Two - way intersection corners A, D compliant
2	Kenneth Ave and Menke Wy - Corners A, D	Two - way intersection corners A, D compliant
3	Kenneth Ave and Quailwood Wy - Corners A, D	Two - way intersection corners C,D compliant
4	Checkerbloom Wy and Poppyfield Wy - Corner C,D	Two - way intersection corners C,D compliant
5	Forbs Wy and Poppyfield Wy - Corner C,D	Four - way intersection corners A,B,C,D compliant
6	Yarrow Wy and Poppyfield Wy - Corner A,B,C,D	Four - way intersection corners A,B,C,D compliant
7	Poppyfield Wy and Nettle Ct - Corner A,B,C,D	Four - way intersection corners A, B, C, D compliant
8	San Cosme Dr and Alma Mesa Wy - Corners A, B, C, D	Two - way intersection corners A, D compliant

9	Alma Mesa Wy and Dana Butte Wy - Corners A, B	Two - way intersection corners B,C compliant
10	Cammeray Dr and Poulson St - Corner B, C	Two - way intersection corners B,C compliant
11	Poulson St and Cammeray Dr - Corner B,C	Two - way intersection corners B,C compliant
12	Hoopes Dr and Camel Rock Wy - Corner A,B compliant	Two - way intersection corners A,B compliant
13	Hoopes Dr and Canelo Hills Dr - Corner C,D compliant	Two - way intersection corners C,D compliant
14	Larwin Dr and bayberry Ct - Corner B,C compliant	Four - way intersection corners A,B,C,D compliant
15	Larwin Dr and Green Ash Ct - Corner A,B,C,D	Four - way intersection corners A,B,C,D compliant
16	Larwin Dr and Clear Creek Ct - Corners A,B,C,D compliant	Two - way intersection corners A,B compliant
17	Larwin Dr and Olive Tree Wy - Corner A,B	Two - way intersection corners B, C compliant
18	Trovita Wy and Tangors Wy - Corners B, C	Two - way intersection corners A, D compliant
19	Trovita Wy and Tangors Wy - Corners A, D	Two - way intersection corner D compliant
20	Fair Oaks Blvd - West	
21	Fair Oaks Blvd and County Boarder - Corner D Compliant	Two - way intersection corner D compliant
22	Fair Oaks Blvd and County Boarder - Corner D Compliant	Two - way intersection corner D compliant

Barrier severity ratings were calculated for the 5 ratings assigned as follows:

<i>Severity 1 (Necessary to Remove)</i>	<i>510 or 47% of total barriers</i>
<i>Severity 2 (Recommended to Remove)</i>	<i>301 or 28% of total barriers</i>
<i>Severity 3 (Hindrance to Access)</i>	<i>221 or 20% of total barriers</i>
<i>Severity 4 (Low Severity Barrier)</i>	<i>59 or 5% of total barriers</i>
<i>Severity 5 (Technically Infeasible to Remove)</i>	<i>1 or 0% of total barriers</i>

Barrier Removal Priority Assignment

The draft barrier removal priorities were assigned to the pedestrian facilities using the criteria described below:

Priority 1 - Primary arterial roadways where the majority of bus routes are located

Fair Oaks Blvd
Greenback Blvd
Oak Ave
Sunrise Blvd

Priority 2 – Major collectors where remaining bus routes are located or where commercial centers, schools, parks, churches, state or local agency facilities exist

Arcadia Drive
Clear Creek Court
Larwin Drive
Linden Lime Court
Shady Grove Court

Old Oak Court
Plum Tree Court
Sweet Gum Court

Priority 3 - Pedestrian routes leading from points of arrival at bus routes to schools, parks or other public accommodations

Canelo Hills Drive
Old Ranch Drive
Woodmore Oaks Drive

Priority 4 - Remaining residential public rights-of-way

Cost Estimates

The total cost for barrier removal within this draft ADA Transition Plan update was calculated as follows:

Cost Estimate Total: \$19,730,225.00

Barrier removal takes place through annual phases that are determined according to the barrier priority assigned and existing budgetary constraints. Draft barrier removal priorities have the following costs associated with each priority assigned:

Cost Estimate - Priority 1: \$1,205,125.00

Cost Estimate - Priority 2: \$2,332,950.00

Cost Estimate - Priority 3: \$635,200.00

Cost Estimate - Priority 4: \$14,063,150.00

Further input is required to complete the ADA Transition Plan. Each Neighborhood Area (NA) must be reviewed by designated Citrus Heights City staff to determine whether overall priorities shall be set per NA or overall throughout the city. Other constraints were taken into consideration while compiling the cost estimates.

1. Currently all barriers are assigned a priority for removal. Some areas may not be used as pedestrian facilities, may be unimproved and could remain so until a request for accommodations is received by the City.
 - a. Assistance in prioritizing areas that lack sidewalk is required. Some segments are lengthy and may not be planned for improvements in the long or short term.
2. Cost estimates have been manually reviewed and corrected

- a. In instances where more than one barrier exists at a curb ramp, cost estimates for curb ramp barriers are often manually changed to ensure that cost estimates do not exceed \$2,500. In these instances, the cost estimate for the first barrier (i.e. 24A, of 24B, 24C and 25D) is listed with a cost estimate of \$2,500 and the remaining barriers are listed with a cost of \$0. This may occur even when the first barrier listed is not ordinarily estimated as high as \$2,500.
- b. Driveways with multiple slopes were assigned a severity 1 rating, rather than a rating that corresponded to the slope of only one of the measurements taken.
- c. Bus stop benches with multiple barriers were only assigned one cost estimate for one accessible bench.

The following barrier data sheets must be reviewed in draft form to provide input for the final report.

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6361
Location:	Menke Wy - East				
X Coordinate:	-121.24847				
Y Coordinate:	38.70026				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	93	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$11,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6362
Location:	Menke Wy and Janquil Wy - Corner B				
X Coordinate:	-121.24849				
Y Coordinate:	38.70006				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	10.1% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date: 3/31/2011 Report Date: 3/31/2011 Barrier #: 6363

Location: Menke Wy and Janquil Wy - Corner C

X Coordinate: -121.2485

Y Coordinate: 38.69992

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 10.0% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners B,C

Field Date: 3/31/2011 Report Date: 3/31/2011 Barrier #: 6364A

Location: Janquil Wy - North

X Coordinate: -121.2484

Y Coordinate: 38.70004

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 968 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.1% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$121,000.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6364B
Location:	Janquil Wy - North				
X Coordinate:	-121.2452				
Y Coordinate:	38.70004				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	8	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6365A
Location:	Janquil Wy - East				
X Coordinate:	-121.24498				
Y Coordinate:	38.7				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	528	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$66,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6365B
Location:	Janquil Wy - East				
X Coordinate:	-121.24497				
Y Coordinate:	38.69957				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - New Construction				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6365C
Location:	Janquil Wy - East				
X Coordinate:	-121.24491				
Y Coordinate:	38.6988				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6366A
Location:	Janquil Wy - West				
X Coordinate:	-121.24515				
Y Coordinate:	38.69869				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	168	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$21,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6366B
Location:	Janquil Wy - West				
X Coordinate:	-121.24507				
Y Coordinate:	38.69889				
Barrier Area:	Sidewalks				
Barrier Type:	Protruding Hazard				
Code Ref:	CBC 1133B.8.6.1 and ADA/ABA 307.2				



As Built Meas:	1	Quantity:	JOB
Description:	Protruding object in route of travel between 27" and 80" high		
As Built Desc:	28" at tree branch		
Solution:	Remove object or provide detectable warning		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,400.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6367
Location:	Janquil Wy and Los Serranos Wy - Corner A				
X Coordinate:	-121.24512				
Y Coordinate:	38.69924				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.0% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,D		

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6368
Location:	Janquil Wy and Los Serranos Wy - Corner D				
X Coordinate:	-121.24509				
Y Coordinate:	38.69915				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	10.0% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,D		

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6369
Location:	Janquil Wy - West				
X Coordinate:	-121.24508				
Y Coordinate:	38.69933				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	202	Quantity:	LF
Description:	Cross slope exceeds 2.0% (2.1% to 3.0%)		
As Built Desc:	3.0% cross slope		
Solution:	Low severity barrier - no remediation recommended		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6370A
Location:	Janquil Wy - South				
X Coordinate:	-121.24522				
Y Coordinate:	38.69989				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	513	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$64,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date: 3/31/2011 Report Date: 3/31/2011 Barrier #: 6370B

Location: Janquil Wy - South

X Coordinate: -121.24692

Y Coordinate: 38.6999

Barrier Area: Sidewalks

Barrier Type: Clear Width - New Construction

Code Ref: CBC 1133B.7.1



As Built Meas: 1 Quantity: LF

Description: Pedestrian route is not min. 48" wide

As Built Desc: 24" clear width due to foliage

Solution: Trim foliage to provide min. 48" clear width

Bar. Severity: 1 Necessary Cost Estimate: \$125.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 3/31/2011 Report Date: 3/31/2011 Barrier #: 6371

Location: Janquil Wy and Goldwood Wy - Corner C

X Coordinate: -121.24701

Y Coordinate: 38.69988

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 9.0% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners C,D

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6372
Location:	Janquil Wy and Goldwood Wy - Corner D				
X Coordinate:	-121.24716				
Y Coordinate:	38.69988				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.1% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C,D		

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6373
Location:	Janquil Wy - South				
X Coordinate:	-121.2473				
Y Coordinate:	38.69989				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	361	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$45,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6374
Location:	Menke Wy - East				
X Coordinate:	-121.2485				
Y Coordinate:	38.69981				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	235	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$29,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6375
Location:	Menke Wy and Menke Wy Ct - Corner B				
X Coordinate:	-121.24835				
Y Coordinate:	38.69917				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.7% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date: 3/31/2011 Report Date: 3/31/2011 Barrier #: 6376

Location: Menke Wy and Menke Wy Ct - Corner C

X Coordinate: -121.24828

Y Coordinate: 38.6991

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 9.1% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners B,C

Field Date: 3/31/2011 Report Date: 3/31/2011 Barrier #: 6377

Location: Menke Wy Ct - North

X Coordinate: -121.24828

Y Coordinate: 38.6992

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (2.1% to 3.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 120 Quantity: LF

Description: Cross slope exceeds 2.0% (2.1% to 3.0%)

As Built Desc: 3.0% cross slope

Solution: Low severity barrier - no remediation recommended

Bar. Severity: 4 Low Severity Cost Estimate: \$0.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 3/31/2011 Report Date: 3/31/2011 Barrier #: 6378

Location: Menke Wy Ct -South

X Coordinate: -121.24797

Y Coordinate: 38.69921

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 120 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.1% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$15,000.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 3/31/2011 Report Date: 3/31/2011 Barrier #: 6379

Location: Menke Wy - East

X Coordinate: -121.24827

Y Coordinate: 38.69902

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 321 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.1% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$40,125.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 3/31/2011 Report Date: 3/31/2011 Barrier #: 6380

Location: Menke Wy - East

X Coordinate: -121.24812

Y Coordinate: 38.69885

Barrier Area: Sidewalks

Barrier Type: Clear Width - New Construction

Code Ref: CBC 1133B.7.1



As Built Meas: 1 Quantity: LF

Description: Pedestrian route is not min. 48" wide

As Built Desc: 24" clear width due to foliage

Solution: Trim foliage to provide min. 48" clear width

Bar. Severity: 1 Necessary Cost Estimate: \$125.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 3/31/2011 Report Date: 3/31/2011 Barrier #: 6381

Location: Menke Wy and Goldwood Wy - Corner B

X Coordinate: -121.24752

Y Coordinate: 38.69841

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 8.6% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners B,C

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6382
Location:	Menke Wy and Goldwood Wy - Corner C				
X Coordinate:	-121.24734				
Y Coordinate:	38.69833				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	10.7% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6383
Location:	Goldwood Wy - West				
X Coordinate:	-121.24739				
Y Coordinate:	38.69848				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	543	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$67,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6384A
Location:	Goldwood Wy - East				
X Coordinate:	-121.24705				
Y Coordinate:	38.69983				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	120	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$15,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6384B
Location:	Goldwood Wy - East				
X Coordinate:	-121.24701				
Y Coordinate:	38.69969				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date: 3/31/2011 Report Date: 3/31/2011 Barrier #: 6385

Location: Goldwood Wy and Los Serranos Wy - Corner B

X Coordinate: -121.24705

Y Coordinate: 38.69926

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 9.5% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners B,C

Field Date: 3/31/2011 Report Date: 3/31/2011 Barrier #: 6386

Location: Goldwood Wy and Los Serranos Wy - Corner C

X Coordinate: -121.247

Y Coordinate: 38.69915

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 9.7% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners B,C

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6387A
Location:	Los Serranos Wy - North				
X Coordinate:	-121.24691				
Y Coordinate:	38.69928				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	507	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$63,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6387B
Location:	Los Serranos Wy -North				
X Coordinate:	-121.24561				
Y Coordinate:	38.69931				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 3/31/2011 Report Date: 3/31/2011 Barrier #: 6388

Location: Los Serranos Wy -South

X Coordinate: -121.24522

Y Coordinate: 38.69917

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 262 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.1% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hindrance Cost Estimate: \$32,750.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 3/31/2011 Report Date: 3/31/2011 Barrier #: 6389

Location: Los Serranos Wy and Quailwood Wy - Corner C

X Coordinate: -121.24609

Y Coordinate: 38.69908

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 10.7% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners C,D

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6390
Location:	Los Serranos Wy and Quailwood Wy - Corner D				
X Coordinate:	-121.24619				
Y Coordinate:	38.69911				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	10.7% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners C,D

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6391
Location:	Quailwood Wy - East				
X Coordinate:	-121.24611				
Y Coordinate:	38.69906				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	413	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$51,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6392
Location:	Quailwood Wy - North				
X Coordinate:	-121.24558				
Y Coordinate:	38.69809				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	324	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$40,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6393
Location:	Quailwood Wy - South				
X Coordinate:	-121.24461				
Y Coordinate:	38.69775				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	343	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$42,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 3/31/2011 Report Date: 3/31/2011 Barrier #: 6394

Location: Quailwood Wy - West

X Coordinate: -121.24576

Y Coordinate: 38.69805

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 438 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.8% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hindrance Cost Estimate: \$54,750.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 3/31/2011 Report Date: 3/31/2011 Barrier #: 6395

Location: Quailwood Wy - West

X Coordinate: -121.24615

Y Coordinate: 38.69849

Barrier Area: Sidewalks

Barrier Type: Clear Width - Existing ($\leq 31"$ or less)

Code Ref: CBC 1133B.7.1



As Built Meas: 12 Quantity: LF

Description: Pedestrian route is not min. 48" wide ($\leq 31"$ or less)

As Built Desc: 24" clear width

Solution: Demolish existing and construct new route

Bar. Severity: 1 Necessary Cost Estimate: \$1,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 3/31/2011 Report Date: 3/31/2011 Barrier #: 6396

Location: Los Serranos Wy - South

X Coordinate: -121.24628

Y Coordinate: 38.69912

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 206 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.3% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hindrance Cost Estimate: \$25,750.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 3/31/2011 Report Date: 3/31/2011 Barrier #: 6397

Location: Goldwood Wy - East

X Coordinate: -121.24701

Y Coordinate: 38.69907

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 291 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.7% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hindrance Cost Estimate: \$36,375.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6398
Location:	Menke Wy - East				
X Coordinate:	-121.24728				
Y Coordinate:	38.69833				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	573	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$71,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6399
Location:	Menke Wy - North				
X Coordinate:	-121.24584				
Y Coordinate:	38.69723				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	246	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$30,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 3/31/2011 Report Date: 3/31/2011 Barrier #: 6400

Location: Menke Wy - South

X Coordinate: -121.24466

Y Coordinate: 38.69682

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 246 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.9% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$30,750.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 3/31/2011 Report Date: 3/31/2011 Barrier #: 6401

Location: Menke Wy and Menke Wy Ct - Corner C

X Coordinate: -121.24543

Y Coordinate: 38.6969

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 8.2% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners C,D

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6402
Location:	Menke Wy and Menke Wy Ct - Corner D				
X Coordinate:	-121.24557				
Y Coordinate:	38.69694				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	11.4% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C,D		

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6403A
Location:	Menke Wy Ct - East				
X Coordinate:	-121.2455				
Y Coordinate:	38.69685				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	157	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$19,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6403B
Location:	Menke Wy Ct - East				
X Coordinate:	-121.24549				
Y Coordinate:	38.69683				
Barrier Area:	Sidewalks				
Barrier Type:	Protruding Hazard				
Code Ref:	CBC 1133B.8.6.1 and ADA/ABA 307.2				



As Built Meas:	1	Quantity:	JOB
Description:	Protruding object in route of travel between 27" and 80" high		
As Built Desc:	17" at tree branch		
Solution:	Remove object or provide detectable warning		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,400.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6404A
Location:	Menke Wy Ct - West				
X Coordinate:	-121.24573				
Y Coordinate:	38.69656				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	163	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$20,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 3/31/2011 Report Date: 3/31/2011 Barrier #: 6404B

Location: Menke Wy Ct - West

X Coordinate: -121.24572

Y Coordinate: 38.69671

Barrier Area: Sidewalks

Barrier Type: Surface Condition - Damaged

Code Ref: CBC 1133B.7.1 and ADA/ABA 302.1



As Built Meas: 8 Quantity: LF

Description: Surface is not firm and stable (cracked, broken or loose soil, etc.)

As Built Desc: Cracked concrete

Solution: Repair surface to make firm and stable

Bar. Severity: 1 Necessary Cost Estimate: \$1,000.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 3/31/2011 Report Date: 3/31/2011 Barrier #: 6405

Location: Menke Wy - West

X Coordinate: -121.24564

Y Coordinate: 38.69699

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 563 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.6% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$70,375.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6406
Location:	Menke Wy and Dalmeny Wy - Corner A				
X Coordinate:	-121.24724				
Y Coordinate:	38.69807				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.8% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,D		

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6407
Location:	Menke Wy and Dalmeny Wy - Corner D				
X Coordinate:	-121.2471				
Y Coordinate:	38.69797				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	10.1% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,D		

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6408
Location:	Dalmeny Wy - South				
X Coordinate:	-121.24717				
Y Coordinate:	38.69791				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	218	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$27,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6409
Location:	Dalmeny Wy and Brookridge Ct - Corner C				
X Coordinate:	-121.2477				
Y Coordinate:	38.6975				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (>5.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (>5.0%)		
As Built Desc:	5.0% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C,D. Corner D compliant		

Field Date: 3/31/2011 Report Date: 3/31/2011 Barrier #: 6410

Location: Brookridge Ct - East

X Coordinate: -121.24761

Y Coordinate: 38.69744

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 600 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.5% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$75,000.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 3/31/2011 Report Date: 3/31/2011 Barrier #: 6411A

Location: Brookridge Ct - West

X Coordinate: -121.24682

Y Coordinate: 38.6961

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 566 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.8% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$70,750.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6411B
Location:	Brookridge Ct - West				
X Coordinate:	-121.2468				
Y Coordinate:	38.6961				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6412
Location:	Dalmeny Wy - South				
X Coordinate:	-121.24787				
Y Coordinate:	38.69745				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				




As Built Meas:	413	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$51,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6413
Location:	Dalmeny Wy and Old Ranch Rd - Corner B				
X Coordinate:	-121.24911				
Y Coordinate:	38.69693				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	11.7% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6414
Location:	Dalmeny Wy and Old Ranch Rd - Corner C				
X Coordinate:	-121.24907				
Y Coordinate:	38.6968				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	7.4% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6415
Location:	Dalmeny Wy - North				
X Coordinate:	-121.24903				
Y Coordinate:	38.69695				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	698	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$87,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6416
Location:	Menke Wy - West				
X Coordinate:	-121.24731				
Y Coordinate:	38.69816				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	203	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$25,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			


Notes:	
--------	--

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6417
Location:	Menke Wy and Corrick Ct - Corner A				
X Coordinate:	-121.24795				
Y Coordinate:	38.69858				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	8.3% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,D		

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6418
Location:	Menke Wy and Corrick Ct - Corner D				
X Coordinate:	-121.24783				
Y Coordinate:	38.69852				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	8.6% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,D		

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6419A
Location:	Corrick Ct - South				
X Coordinate:	-121.24789				
Y Coordinate:	38.69846				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	409	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$51,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6419B
Location:	Corrick Ct - South				
X Coordinate:	-121.24854				
Y Coordinate:	38.69808				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6420A
Location:	Corrick Ct - North				
X Coordinate:	-121.24898				
Y Coordinate:	38.69789				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	452	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$56,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6420B
Location:	Corrick Ct - North				
X Coordinate:	-121.24864				
Y Coordinate:	38.69814				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6421
Location:	Menke Wy - West				
X Coordinate:	-121.24802				
Y Coordinate:	38.69867				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	180	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$22,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6422
Location:	Menke Wy and Amsell Ct - Corner A				
X Coordinate:	-121.24848				
Y Coordinate:	38.69911				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	8.6% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,D
--------	------------------------------------

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6423
Location:	Menke Wy and Amsell Ct - Corner D				
X Coordinate:	-121.24843				
Y Coordinate:	38.699				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	10.0% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,D		

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6424A
Location:	Amsell Ct - South				
X Coordinate:	-121.24853				
Y Coordinate:	38.69898				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	453	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$56,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6424B
Location:	Amsell Ct - South				
X Coordinate:	-121.24973				
Y Coordinate:	38.69848				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	4	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6425A
Location:	Amsell Ct - North				
X Coordinate:	-121.2499				
Y Coordinate:	38.69862				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	500	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$62,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6425B
Location:	Amsell Ct - North				
X Coordinate:	-121.24988				
Y Coordinate:	38.69858				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	4	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/31/2011	Report Date:	3/31/2011	Barrier #:	6426
Location:	Menke Wy - West				
X Coordinate:	-121.2485				
Y Coordinate:	38.69916				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	451	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$56,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6427
Location:	Old Ranch Rd - East				
X Coordinate:	-121.25139				
Y Coordinate:	38.70017				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	217	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$27,125.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6428
Location:	Old Ranch Rd and Jordell Ct - Corner B				
X Coordinate:	-121.25144				
Y Coordinate:	38.69964				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	10.8% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6429
Location:	Old Ranch Rd and Jordell Ct - Corner C				
X Coordinate:	-121.25143				
Y Coordinate:	38.69954				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	11.3% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6430
Location:	Jordell Ct - North				
X Coordinate:	-121.25139				
Y Coordinate:	38.69963				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	614	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$76,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6431
Location:	Jordell Ct - South				
X Coordinate:	-121.2494				
Y Coordinate:	38.69941				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	346	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$43,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6432
Location:	Jordell Ct and Jordell Ct - Corner C				
X Coordinate:	-121.25041				
Y Coordinate:	38.69955				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.0% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners C,D
--------	------------------------------------

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6433
Location:	Jordell Ct and Jordell Ct - Corner D				
X Coordinate:	-121.25057				
Y Coordinate:	38.69958				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	8.7% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C,D		

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6434
Location:	Jordell Ct - East				
X Coordinate:	-121.25039				
Y Coordinate:	38.69949				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	194	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$24,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6435
Location:	Jordell Ct - West				
X Coordinate:	-121.25058				
Y Coordinate:	38.69916				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	194	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$24,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6436
Location:	Jordell Ct - South				
X Coordinate:	-121.25067				
Y Coordinate:	38.69956				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	228	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$28,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6437
Location:	Old Ranch Rd - East				
X Coordinate:	-121.25143				
Y Coordinate:	38.69944				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	1194	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$149,250.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6438
Location:	Old Ranch Rd - East				
X Coordinate:	-121.24902				
Y Coordinate:	38.69673				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	216	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$27,000.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6439
Location:	Old Ranch Rd and Mansfield Dr - Corner B				
X Coordinate:	-121.24891				
Y Coordinate:	38.69615				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	10.4% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6440
Location:	Old Ranch Rd and Mansfield Dr - Corner C				
X Coordinate:	-121.24892				
Y Coordinate:	38.69599				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	11.9% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6441
Location:	Mansfield Dr - North				
X Coordinate:	-121.24886				
Y Coordinate:	38.69611				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	210	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$26,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6442
Location:	Mansfield Dr and Mansfield Dr Ct - Corner A				
X Coordinate:	-121.24818				
Y Coordinate:	38.69599				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	10.7% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,B
--------	------------------------------------

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6443
Location:	Mansfield Dr and Mansfield Dr Ct - Corner B				
X Coordinate:	-121.24798				
Y Coordinate:	38.69594				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.7% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6444A
Location:	Mansfield Dr Ct - West				
X Coordinate:	-121.24816				
Y Coordinate:	38.69603				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	236	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$29,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6444B
Location:	Mansfield Dr Ct - West				
X Coordinate:	-121.24792				
Y Coordinate:	38.69644				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6444C
Location:	Mansfield Dr Ct - West				
X Coordinate:	-121.24786				
Y Coordinate:	38.69646				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	8	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6445
Location:	Mansfield Dr Ct - East				
X Coordinate:	-121.24776				
Y Coordinate:	38.69642				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	231	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$28,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6446A
Location:	Mansfield Dr - North				
X Coordinate:	-121.24802				
Y Coordinate:	38.6959				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	578	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$72,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 4/1/2011 Report Date: 4/1/2011 Barrier #: 6446B

Location: Mansfield Dr - North

X Coordinate: -121.2474

Y Coordinate: 38.69561

Barrier Area: Sidewalks

Barrier Type: Surface Condition - Damaged

Code Ref: CBC 1133B.7.1 and ADA/ABA 302.1



As Built Meas: 12 Quantity: LF

Description: Surface is not firm and stable (cracked, broken or loose soil, etc.)

As Built Desc: Cracked concrete

Solution: Repair surface to make firm and stable

Bar. Severity: 1 Necessary Cost Estimate: \$1,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/1/2011 Report Date: 4/1/2011 Barrier #: 6447

Location: Mansfield Dr and Cranford Wy - Corner A

X Coordinate: -121.24627

Y Coordinate: 38.69509

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 8.4% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Four - way intersection corners A, B, C, D

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6448
Location:	Mansfield Dr and Cranford Wy - Corner B				
X Coordinate:	-121.24613				
Y Coordinate:	38.69508				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	7.9% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Four - way intersection corners A, B, C, D

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6449
Location:	Mansfield Dr and Cranford Wy - Corner C				
X Coordinate:	-121.24616				
Y Coordinate:	38.69492				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	11.2% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Four - way intersection corners A, B, C, D

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6450
Location:	Mansfield Dr and Cranford Wy - Corner D				
X Coordinate:	-121.24635				
Y Coordinate:	38.69497				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	8.3% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A, B, C, D		

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6451
Location:	Cranford Wy - West				
X Coordinate:	-121.24625				
Y Coordinate:	38.69517				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	415	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$51,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date: 4/1/2011 Report Date: 4/1/2011 Barrier #: 6452

Location: Cranford Wy - East

X Coordinate: -121.24544

Y Coordinate: 38.69572

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 436 Quantity: LF

Description: Cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 5.1% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 1 Necessary Cost Estimate: \$54,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/1/2011 Report Date: 4/1/2011 Barrier #: 6453

Location: Mansfield Dr - North

X Coordinate: -121.24606

Y Coordinate: 38.69504

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 457 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.2% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$57,125.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6454
Location:	Mansfield Dr - South				
X Coordinate:	-121.24461				
Y Coordinate:	38.69487				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	235	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$29,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6455
Location:	Mansfield Dr and Jenner Ct - Corner C				
X Coordinate:	-121.24534				
Y Coordinate:	38.69492				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.2% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners C,D
--------	------------------------------------

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6456
Location:	Mansfield Dr and Jenner Ct - Corner D				
X Coordinate:	-121.24551				
Y Coordinate:	38.6949				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.2% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C,D		

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6457A
Location:	Jenner Ct - East				
X Coordinate:	-121.24536				
Y Coordinate:	38.69478				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	502	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$62,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6457B
Location:	Jenner Ct - East				
X Coordinate:	-121.24539				
Y Coordinate:	38.6935				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	4	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6457C
Location:	Jenner Ct - East				
X Coordinate:	-121.24548				
Y Coordinate:	38.69346				
Barrier Area:	Sidewalks				
Barrier Type:	Elbow in Sidewalk - Cross Slope (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	6	Quantity:	LF
Description:	Cross slope at elbow exceeds 2.0% (5.0% or more)		
As Built Desc:	9.8% cross slope		
Solution:	Demolish existing and construct new sidewalk without curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6458
Location:	Jenner Ct - South				
X Coordinate:	-121.246				
Y Coordinate:	38.69361				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	178	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$22,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6459
Location:	Jenner Ct - North				
X Coordinate:	-121.246				
Y Coordinate:	38.69358				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	180	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$22,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6460
Location:	Jenner Ct - North				
X Coordinate:	-121.24557				
Y Coordinate:	38.69357				
Barrier Area:	Sidewalks				
Barrier Type:	Elbow in Sidewalk - Cross Slope (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	6	Quantity:	LF
Description:	Cross slope at elbow exceeds 2.0% (5.0% or more)		
As Built Desc:	11.5% cross slope		
Solution:	Demolish existing and construct new sidewalk without curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6461
Location:	Jenner Ct - North				
X Coordinate:	-121.24551				
Y Coordinate:	38.6937				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	453	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$56,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6462
Location:	Mansfield Dr - South				
X Coordinate:	-121.24562				
Y Coordinate:	38.69491				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	639	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$79,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6463
Location:	Mansfield Dr - South				
X Coordinate:	-121.24644				
Y Coordinate:	38.69499				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	826	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$103,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6464
Location:	Old Ranch Rd - East				
X Coordinate:	-121.24897				
Y Coordinate:	38.69593				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	205	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$25,625.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6465
Location:	Old Ranch Rd and Kingsmill Wy - Corner A				
X Coordinate:	-121.24928				
Y Coordinate:	38.69547				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	10.5% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A, B, C, D		

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6466
Location:	Old Ranch Rd and Kingsmill Wy - Corner B				
X Coordinate:	-121.24911				
Y Coordinate:	38.69543				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	7.5% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A, B, C, D		

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6467
Location:	Old Ranch Rd and Kingsmill Wy - Corner C				
X Coordinate:	-121.24911				
Y Coordinate:	38.69529				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	11.5% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A, B, C, D		

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6468
Location:	Old Ranch Rd and Kingsmill Wy - Corner D				
X Coordinate:	-121.24932				
Y Coordinate:	38.69533				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	13.2% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A, B, C, D		

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6469
Location:	Kingsmill Wy - North				
X Coordinate:	-121.24901				
Y Coordinate:	38.69539				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	857	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$107,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date: 4/1/2011 Report Date: 4/1/2011 Barrier #: 6470

Location: Kingsmill Wy - South

X Coordinate: -121.24695

Y Coordinate: 38.69402

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 890 Quantity: LF

Description: Cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 5.7% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 1 Necessary Cost Estimate: \$111,250.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/1/2011 Report Date: 4/1/2011 Barrier #: 6471

Location: Old Ranch Rd - East

X Coordinate: -121.24914

Y Coordinate: 38.69521

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 607 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.4% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$75,875.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6472
Location:	Old Ranch Rd and Cranford Wy - Corner A				
X Coordinate:	-121.24977				
Y Coordinate:	38.69362				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)		
As Built Desc:	3.8% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Four - way intersection corners A, B, C, D

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6473
Location:	Old Ranch Rd and Cranford Wy - Corner B				
X Coordinate:	-121.24957				
Y Coordinate:	38.69362				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (>5.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (>5.0%)		
As Built Desc:	7.3% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Four - way intersection corners A, B, C, D

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6474
Location:	Old Ranch Rd and Cranford Wy - Corner C				
X Coordinate:	-121.24959				
Y Coordinate:	38.69353				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)		
As Built Desc:	3.6% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Four - way intersection corners A, B, C, D

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6475
Location:	Old Ranch Rd and Cranford Wy - Corner D				
X Coordinate:	-121.24977				
Y Coordinate:	38.69349				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (>5.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (>5.0%)		
As Built Desc:	5.9% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Four - way intersection corners A, B, C, D

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6476
Location:	Cranford Wy - North				
X Coordinate:	-121.24937				
Y Coordinate:	38.69362				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	360	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$45,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6477
Location:	Cranford Wy and Halesworth Ct - Corner A				
X Coordinate:	-121.24811				
Y Coordinate:	38.69362				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	10.6% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,B
--------	------------------------------------

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6478
Location:	Cranford Wy and Halesworth Ct - Corner B				
X Coordinate:	-121.24794				
Y Coordinate:	38.69363				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	8.8% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6479
Location:	Halesworth Ct - West				
X Coordinate:	-121.24813				
Y Coordinate:	38.69378				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	352	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$44,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6480
Location:	Halesworth Ct - West				
X Coordinate:	-121.24808				
Y Coordinate:	38.69382				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6481
Location:	Halesworth Ct - East				
X Coordinate:	-121.24836				
Y Coordinate:	38.69436				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	382	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$47,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6482
Location:	Cranford Wy - North				
X Coordinate:	-121.24786				
Y Coordinate:	38.69362				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	339	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$42,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6483
Location:	Cranford Wy and Kingsmill Wy - Corner A				
X Coordinate:	-121.24674				
Y Coordinate:	38.69403				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	11.8% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,D
--------	------------------------------------

Field Date: 4/1/2011 Report Date: 4/1/2011 Barrier #: 6484

Location: Cranford Wy and Kingsmill Wy - Corner D

X Coordinate: -121.24683

Y Coordinate: 38.69399

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 11.5% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A,D

Field Date: 4/1/2011 Report Date: 4/1/2011 Barrier #: 6485

Location: Cranford Wy - West

X Coordinate: -121.24664

Y Coordinate: 38.69408

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 357 Quantity: LF

Description: Cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 5.9% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 1 Necessary Cost Estimate: \$44,625.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6486A
Location:	Cranford Wy - East				
X Coordinate:	-121.24618				
Y Coordinate:	38.69487				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	402	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$50,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6486B
Location:	Cranford Wy - East				
X Coordinate:	-121.24671				
Y Coordinate:	38.69389				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	20	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6487
Location:	Cranford Wy - South				
X Coordinate:	-121.247				
Y Coordinate:	38.69367				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	895	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$111,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6488
Location:	Old Ranch Rd - East				
X Coordinate:	-121.24964				
Y Coordinate:	38.69342				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	109	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$13,625.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6489A
Location:	Old Ranch Rd - West				
X Coordinate:	-121.24981				
Y Coordinate:	38.69324				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	109	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$13,625.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6489B
Location:	Old Ranch Rd - West				
X Coordinate:	-121.24981				
Y Coordinate:	38.69324				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	24	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$3,000.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6490
Location:	Old Ranch Rd - West				
X Coordinate:	-121.2498				
Y Coordinate:	38.69367				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	194	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$24,250.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6491A
Location:	Old Ranch Rd and Beckwith Wy - Corner A				
X Coordinate:	-121.24967				
Y Coordinate:	38.69432				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (>5.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (>5.0%)		
As Built Desc:	6.3% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,D. Corner D compliant
--------	--

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6491B
Location:	Old Ranch Rd and Beckwith Wy - Corner A				
X Coordinate:	-121.24967				
Y Coordinate:	38.69432				
Barrier Area:	Curb Ramps				
Barrier Type:	Running Slope - Existing (9.0% to 9.4%)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.1				



As Built Meas:	1	Quantity:	EACH
Description:	Ramp run cross slope exceeds 2.0% (9.0% to 9.4%)		
As Built Desc:	9.3% running slope		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,D. Corner D compliant

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6492A
Location:	Old Ranch Rd - West				
X Coordinate:	-121.24963				
Y Coordinate:	38.69437				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	375	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$46,875.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6492B
Location:	Old Ranch Rd - West				
X Coordinate:	-121.24956				
Y Coordinate:	38.69461				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	12	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6493A
Location:	Old Ranch Rd - West				
X Coordinate:	-121.24928				
Y Coordinate:	38.69553				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	1349	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$168,625.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6493B
Location:	Old Ranch Rd - West				
X Coordinate:	-121.24909				
Y Coordinate:	38.69623				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6493C
Location:	Old Ranch Rd - West				
X Coordinate:	-121.2491				
Y Coordinate:	38.69637				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6494
Location:	Old Ranch Rd and Haliburton Ct - Corner A				
X Coordinate:	-121.24978				
Y Coordinate:	38.69732				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	8.4% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,D
--------	------------------------------------

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6495
Location:	Old Ranch Rd and Haliburton Ct - Corner D				
X Coordinate:	-121.24969				
Y Coordinate:	38.69725				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	8.9% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,D
--------	------------------------------------

Field Date: 4/1/2011 Report Date: 4/1/2011 Barrier #: 6496

Location: Haliburton Ct - South

X Coordinate: -121.24974

Y Coordinate: 38.69719

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 182 Quantity: LF

Description: Cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 5.7% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 1 Necessary Cost Estimate: \$22,750.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/1/2011 Report Date: 4/1/2011 Barrier #: 6497

Location: Haliburton Ct - North

X Coordinate: -121.25021

Y Coordinate: 38.69701

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 203 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.3% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$25,375.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/1/2011 Report Date: 4/1/2011 Barrier #: 6498

Location: Old Ranch Rd - West

X Coordinate: -121.24982

Y Coordinate: 38.69739

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3

As Built Meas: 216 Quantity: LF

Description: Cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 5.5% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 1 Necessary Cost Estimate: \$27,000.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:



Field Date: 4/1/2011 Report Date: 4/1/2011 Barrier #: 6499

Location: Old Ranch Rd and Streng - Corner A

X Coordinate: -121.25045

Y Coordinate: 38.69781

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2

As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 10.9% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A,D



Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6500
Location:	Old Ranch Rd and Streng - Corner D				
X Coordinate:	-121.25031				
Y Coordinate:	38.69773				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	12.8% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,D		

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6501
Location:	Old Ranch Rd - West				
X Coordinate:	-121.25056				
Y Coordinate:	38.69795				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	693	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$86,625.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6502
Location:	Old Ranch Rd and Blayden Ct - Corner A				
X Coordinate:	-121.25166				
Y Coordinate:	38.69966				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	12.6% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,D

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6503
Location:	Old Ranch Rd and Blayden Ct - Corner D				
X Coordinate:	-121.25161				
Y Coordinate:	38.69953				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	11.8% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,D

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6504
Location:	Blayden Ct - South				
X Coordinate:	-121.25182				
Y Coordinate:	38.69955				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	196	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$24,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6505A
Location:	Blayden Ct - East				
X Coordinate:	-121.25246				
Y Coordinate:	38.69948				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	325	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$40,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6505B
Location:	Blayden Ct - East				
X Coordinate:	-121.25241				
Y Coordinate:	38.6988				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	4	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6506
Location:	Blayden Ct - West				
X Coordinate:	-121.25253				
Y Coordinate:	38.6988				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	325	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$40,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6507
Location:	Blayden Ct - North				
X Coordinate:	-121.25256				
Y Coordinate:	38.69965				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	206	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$25,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/1/2011	Report Date:	4/1/2011	Barrier #:	6508
Location:	Old Ranch Rd - West				
X Coordinate:	-121.25162				
Y Coordinate:	38.69971				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	235	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$29,375.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6509
Location:	Melva St - East				
X Coordinate:	-121.2541				
Y Coordinate:	38.70038				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	1125	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$112,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6510
Location:	Melva St and Streng Ave - Corner A				
X Coordinate:	-121.25437				
Y Coordinate:	38.69717				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at transition into roadway		
As Built Desc:	No detectable warning		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Four - way intersection corners A, B, C, D
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6511
Location:	Melva St and Streng Ave - Corner B				
X Coordinate:	-121.25418				
Y Coordinate:	38.69718				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at transition into roadway		
As Built Desc:	No detectable warning		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A, B, C, D		

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6512
Location:	Melva St and Streng Ave - Corner C				
X Coordinate:	-121.25416				
Y Coordinate:	38.69702				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at transition into roadway		
As Built Desc:	No detectable warning		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A, B, C, D		

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6513
Location:	Melva St and Streng Ave - Corner D				
X Coordinate:	-121.25437				
Y Coordinate:	38.69699				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at transition into roadway		
As Built Desc:	No detectable warning		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A, B, C, D		

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6514
Location:	Streng Ave - North				
X Coordinate:	-121.25413				
Y Coordinate:	38.69711				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	160	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$16,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6515
Location:	Streng Ave - North				
X Coordinate:	-121.25364				
Y Coordinate:	38.69715				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB
Description:	No barricade provided where sidewalk ends in hazardous location		
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk		
Solution:	Provide barricade with cane detectable warning at end of sidewalk		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6516
Location:	Streng Ave - North				
X Coordinate:	-121.25356				
Y Coordinate:	38.69716				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	625	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$78,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6517
Location:	Streng Ave and Streng Ave CT - Corner A				
X Coordinate:	-121.25136				
Y Coordinate:	38.69734				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	10.9% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Four - way intersection corners A, B, C, D

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6518
Location:	Streng Ave and Streng Ave CT - Corner B				
X Coordinate:	-121.25114				
Y Coordinate:	38.69741				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	12.2% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Four - way intersection corners A, B, C, D

Field Date: 4/4/2011 Report Date: 4/4/2011 Barrier #: 6519

Location: Streng Ave and Kingsmill Ln - Corner C

X Coordinate: -121.2511

Y Coordinate: 38.69728

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 9.5% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Four - way intersection corners A, B, C, D

Field Date: 4/4/2011 Report Date: 4/4/2011 Barrier #: 6520

Location: Streng Ave and Kingsmill Ln - Corner D

X Coordinate: -121.25128

Y Coordinate: 38.69722

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 13.3% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Four - way intersection corners A, B, C, D


Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6521
Location:	Streng Ave CT - West				
X Coordinate:	-121.25139				
Y Coordinate:	38.69738				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	180	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$22,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6522
Location:	Streng Ave CT - East				
X Coordinate:	-121.25143				
Y Coordinate:	38.69766				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	115	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$14,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6523
Location:	Streng Ave - North				
X Coordinate:	-121.2511				
Y Coordinate:	38.69743				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	245	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$30,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6524
Location:	Streng Ave - South				
X Coordinate:	-121.25043				
Y Coordinate:	38.69767				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	270	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$33,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6525
Location:	Kingsmill Ln - East				
X Coordinate:	-121.25131				
Y Coordinate:	38.69716				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	660	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$82,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6526
Location:	Kingsmill Ln and Blandford Ct - Corner A				
X Coordinate:	-121.25022				
Y Coordinate:	38.69568				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	12.7% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Four - way intersection A,B,C,D. Corners C,D compliant
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6527
Location:	Kingsmill Ln and Blandford Ct - Corner B				
X Coordinate:	-121.25005				
Y Coordinate:	38.6956				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	11.8% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection A,B,C,D. Corners C,D compliant		

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6528A
Location:	Blandford Ct - West				
X Coordinate:	-121.25019				
Y Coordinate:	38.6958				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	240	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$30,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6528B
Location:	Blandford Ct - West				
X Coordinate:	-121.25009				
Y Coordinate:	38.69624				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	12	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6529A
Location:	Blandford Ct - East				
X Coordinate:	-121.25004				
Y Coordinate:	38.6962				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	220	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$27,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date: 4/4/2011 Report Date: 4/4/2011 Barrier #: 6529B

Location: Blandford Ct - East

X Coordinate: -121.24999

Y Coordinate: 38.69615

Barrier Area: Sidewalks

Barrier Type: Surface Condition - Damaged

Code Ref: CBC 1133B.7.1 and ADA/ABA 302.1



As Built Meas: 5 Quantity: LF

Description: Surface is not firm and stable (cracked, broken or loose soil, etc.)

As Built Desc: Cracked concrete

Solution: Repair surface to make firm and stable

Bar. Severity: 1 Necessary Cost Estimate: \$625.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/4/2011 Report Date: 4/4/2011 Barrier #: 6530

Location: Kingsmill Ln - North

X Coordinate: -121.24992

Y Coordinate: 38.69557

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 170 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.2% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$21,250.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6531
Location:	Kingsmill Ln - South				
X Coordinate:	-121.24939				
Y Coordinate:	38.69538				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	210	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$26,250.00
Status:			
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6532
Location:	Gateshead Ct - East				
X Coordinate:	-121.25012				
Y Coordinate:	38.69536				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	220	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$27,500.00
Status:			
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6533
Location:	Gateshead Ct - West				
X Coordinate:	-121.25041				
Y Coordinate:	38.69497				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	200	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$25,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6534
Location:	Kingsmill Ln - South				
X Coordinate:	-121.25042				
Y Coordinate:	38.69554				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	159	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$19,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6535
Location:	Kingsmill Ln - West				
X Coordinate:	-121.25088				
Y Coordinate:	38.69588				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	491	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$61,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6536
Location:	Streng Ave - South				
X Coordinate:	-121.25135				
Y Coordinate:	38.69717				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	180	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$22,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6537
Location:	Streng Ave and Escallonia Dr - Corner C				
X Coordinate:	-121.25191				
Y Coordinate:	38.69701				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.8% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C,D		

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6538
Location:	Streng Ave and Escallonia Dr - Corner D				
X Coordinate:	-121.2522				
Y Coordinate:	38.69699				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	11.1% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C,D		

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6539A
Location:	Escallonia Dr - East				
X Coordinate:	-121.25191				
Y Coordinate:	38.6968				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	1006	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6540
Location:	Escallonia Dr - East				
X Coordinate:	-121.25237				
Y Coordinate:	38.69458				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	4	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6542A
Location:	Beckwith Wy - North				
X Coordinate:	-121.25241				
Y Coordinate:	38.69433				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	204	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$25,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6542B
Location:	Beckwith Wy - North				
X Coordinate:	-121.2521				
Y Coordinate:	38.69435				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	8	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6543
Location:	Beckwith Wy and Hatfield Ct - Corner A				
X Coordinate:	-121.25163				
Y Coordinate:	38.69434				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (4.1% to 4.9%)		
As Built Desc:	4.2% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B. Corner B compliant		

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6544A
Location:	Hatfield Ct - West				
X Coordinate:	-121.25168				
Y Coordinate:	38.69441				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	357	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$44,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6544B
Location:	Hatfield Ct - West				
X Coordinate:	-121.25165				
Y Coordinate:	38.69482				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6545A
Location:	Hatfield Ct - East				
X Coordinate:	-121.25139				
Y Coordinate:	38.69528				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	380	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$47,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6545B
Location:	Hatfield Ct - East				
X Coordinate:	-121.25145				
Y Coordinate:	38.69466				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6546
Location:	Beckwith Wy - North				
X Coordinate:	-121.25137				
Y Coordinate:	38.69435				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	495	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$61,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date: 4/4/2011 Report Date: 4/4/2011 Barrier #: 6547

Location: Beckwith Wy - South

X Coordinate: -121.24974

Y Coordinate: 38.6942

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 748 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.5% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$93,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/4/2011 Report Date: 4/4/2011 Barrier #: 6548

Location: Escallonia Dr - East

X Coordinate: -121.25242

Y Coordinate: 38.69419

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 200 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.1% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$25,000.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6549
Location:	Escallonia Dr and Cranford Wy - Corner B				
X Coordinate:	-121.25241				
Y Coordinate:	38.69362				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)		
As Built Desc:	3.1% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6550A
Location:	Escallonia Dr and Cranford Wy - Corner C				
X Coordinate:	-121.25243				
Y Coordinate:	38.69348				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (>5.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (>5.0%)		
As Built Desc:	6.2% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6550B
Location:	Escallonia Dr and Cranford Wy - Corner C				
X Coordinate:	-121.25243				
Y Coordinate:	38.69348				
Barrier Area:	Curb Ramps				
Barrier Type:	Running Slope - New Construction				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	1	Quantity:	EACH
Description:	Ramp run cross slope exceeds 2.0%		
As Built Desc:	10.4% running slope		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6551A
Location:	Cranford Wy - North				
X Coordinate:	-121.25205				
Y Coordinate:	38.69362				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	720	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$90,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6551B
Location:	Cranford Wy - North				
X Coordinate:	-121.24988				
Y Coordinate:	38.69359				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	9	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6552
Location:	Cranford Wy - South				
X Coordinate:	-121.24986				
Y Coordinate:	38.69351				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	717	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$89,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6553
Location:	Escallonia Dr - East				
X Coordinate:	-121.25242				
Y Coordinate:	38.69345				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	103	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$12,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6554
Location:	Escallonia Dr - West				
X Coordinate:	-121.2526				
Y Coordinate:	38.69318				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	441	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$55,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6555
Location:	Escallonia Dr - West				
X Coordinate:	-121.2526				
Y Coordinate:	38.69446				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	166	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$20,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6556A
Location:	Escallonia Dr - West				
X Coordinate:	-121.25261				
Y Coordinate:	38.69503				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	386	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$48,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6556B
Location:	Escallonia Dr - West				
X Coordinate:	-121.25209				
Y Coordinate:	38.69601				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - Tree Heaves				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	12	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1" lip due to tree heaves		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$3,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6557
Location:	Escallonia Dr - West				
X Coordinate:	-121.252				
Y Coordinate:	38.69601				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	84	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$10,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6558
Location:	Escallonia Dr and Burnside Ct - Corner A				
X Coordinate:	-121.25205				
Y Coordinate:	38.69638				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	10.5% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,D

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6559
Location:	Escallonia Dr and Burnside Ct - Corner D				
X Coordinate:	-121.25202				
Y Coordinate:	38.69625				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	10.7% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,D

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6560
Location:	Burnside Ct - South				
X Coordinate:	-121.25207				
Y Coordinate:	38.69627				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	189	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$23,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6561
Location:	Burnside Ct - South				
X Coordinate:	-121.25259				
Y Coordinate:	38.69633				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	175	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$21,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6562
Location:	Escallonia Dr - West				
X Coordinate:	-121.25202				
Y Coordinate:	38.6964				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	215	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$26,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6563
Location:	Streng Ave - South				
X Coordinate:	-121.25222				
Y Coordinate:	38.69702				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	395	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$49,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6564
Location:	Streng Ave - South				
X Coordinate:	-121.25361				
Y Coordinate:	38.69702				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB
Description:	No barricade provided where sidewalk ends in hazardous location		
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk		
Solution:	Provide barricade with cane detectable warning at end of sidewalk		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6565
Location:	Streng Ave - South				
X Coordinate:	-121.25362				
Y Coordinate:	38.69704				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	165	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$16,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6566
Location:	Melva St - East				
X Coordinate:	-121.25415				
Y Coordinate:	38.69695				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	145	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$14,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6567
Location:	Melva St - East				
X Coordinate:	-121.25409				
Y Coordinate:	38.69657				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB
Description:	No barricade provided where sidewalk ends in hazardous location		
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk		
Solution:	Provide barricade with cane detectable warning at end of sidewalk		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6568
Location:	Melva St - East				
X Coordinate:	-121.25411				
Y Coordinate:	38.6965				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	4	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to guy wire		
Solution:	Replace guy wire or demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6569
Location:	Melva St - East				
X Coordinate:	-121.25414				
Y Coordinate:	38.69644				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	149	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$18,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6570
Location:	Prime Wy - South				
X Coordinate:	-121.25431				
Y Coordinate:	38.69594				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	455	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$56,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6571
Location:	Prime Wy - South				
X Coordinate:	-121.25745				
Y Coordinate:	38.69603				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	110	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$13,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6572
Location:	Prime Wy and Cross Dr - Corner B				
X Coordinate:	-121.25793				
Y Coordinate:	38.69617				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	12.4% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6573
Location:	Prime Wy and Cross Dr - Corner C				
X Coordinate:	-121.25791				
Y Coordinate:	38.69607				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	12.7% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6574
Location:	Prime Wy - North				
X Coordinate:	-121.25769				
Y Coordinate:	38.69616				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6575
Location:	Prime Wy - North				
X Coordinate:	-121.25578				
Y Coordinate:	38.69615				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	4	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6576A
Location:	Prime Wy - North				
X Coordinate:	-121.25566				
Y Coordinate:	38.69614				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	380	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$47,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6576B
Location:	Prime Wy - North				
X Coordinate:	-121.25533				
Y Coordinate:	38.69618				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	4	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6577
Location:	Prime Wy - North				
X Coordinate:	-121.25437				
Y Coordinate:	38.69617				
Barrier Area:	Sidewalks				
Barrier Type:	Elbow in Sidewalk - Cross Slope (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	380	Quantity:	LF
Description:	Cross slope at elbow exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.7% cross slope		
Solution:	Demolish existing and construct new sidewalk without curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$47,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6578
Location:	Melva St - West				
X Coordinate:	-121.25434				
Y Coordinate:	38.69621				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	145	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$18,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6579
Location:	Melva St - West				
X Coordinate:	-121.25436				
Y Coordinate:	38.69657				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB
Description:	No barricade provided where sidewalk ends in hazardous location		
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk		
Solution:	Provide barricade with cane detectable warning at end of sidewalk		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6580
Location:	Melva St - West				
X Coordinate:	-121.25432				
Y Coordinate:	38.69661				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	154	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$15,400.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6581
Location:	Streng Ave - South				
X Coordinate:	-121.25436				
Y Coordinate:	38.69707				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	422	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$42,200.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6582
Location:	Streng Ave - South				
X Coordinate:	-121.25584				
Y Coordinate:	38.69705				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB
Description:	No barricade provided where sidewalk ends in hazardous location		
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk		
Solution:	Provide barricade with cane detectable warning at end of sidewalk		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6583A
Location:	Streng Ave - West				
X Coordinate:	-121.25651				
Y Coordinate:	38.69759				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	59	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%) and running slope exceeds 5.0%		
As Built Desc:	3.9% cross slope, 6.2% running slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$7,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6583B
Location:	Streng Ave - West				
X Coordinate:	-121.25647				
Y Coordinate:	38.69769				
Barrier Area:	Sidewalks				
Barrier Type:	Running Slope (New Construction)				
Code Ref:	CBC 1133B.7.3 and ADA/ABA 403.3				



As Built Meas:	20	Quantity:	LF
Description:	Running slope exceeds 5.0% where roadway slope does not		
As Built Desc:	7.6% running slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6584
Location:	Streng Ave - East				
X Coordinate:	-121.25628				
Y Coordinate:	38.69825				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	329	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$41,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6585
Location:	Streng Ave - East				
X Coordinate:	-121.25625				
Y Coordinate:	38.69715				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6586
Location:	Streng Ave - North				
X Coordinate:	-121.25583				
Y Coordinate:	38.6971				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB
Description:	No barricade provided where sidewalk ends in hazardous location		
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk		
Solution:	Provide barricade with cane detectable warning at end of sidewalk		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6587
Location:	Streng Ave - North				
X Coordinate:	-121.2558				
Y Coordinate:	38.69707				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	422	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$42,200.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6588
Location:	Melva St - West				
X Coordinate:	-121.25429				
Y Coordinate:	38.69719				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	280	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$28,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6589
Location:	Melva St and Mandarin Cir - Corner A				
X Coordinate:	-121.25434				
Y Coordinate:	38.69805				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at transition into roadway		
As Built Desc:	No detectable warning provided		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,D
--------	------------------------------------

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6590
Location:	Melva St and Mandarin Cir - Corner D				
X Coordinate:	-121.25433				
Y Coordinate:	38.69794				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at transition into roadway		
As Built Desc:	No detectable warning provided		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,D		

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6591
Location:	Melva St - West				
X Coordinate:	-121.2543				
Y Coordinate:	38.69809				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	295	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$29,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6592
Location:	Melva St and Mandarin Cir - Corner A				
X Coordinate:	-121.25435				
Y Coordinate:	38.69906				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at transition into roadway		
As Built Desc:	No detectable warning provided		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,D		

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6593
Location:	Melva St and Mandarin Cir - Corner D				
X Coordinate:	-121.25434				
Y Coordinate:	38.69891				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at transition into roadway		
As Built Desc:	No detectable warning provided		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,D		

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6594
Location:	Mandarin Cir - South				
X Coordinate:	-121.25438				
Y Coordinate:	38.69893				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	285	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$28,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6595
Location:	Mandarin Cir - East				
X Coordinate:	-121.25526				
Y Coordinate:	38.69887				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	312	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$31,200.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6596
Location:	Mandarin Cir - North				
X Coordinate:	-121.25518				
Y Coordinate:	38.69805				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	260	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$26,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6597
Location:	Mandarin Cir - South				
X Coordinate:	-121.25437				
Y Coordinate:	38.69795				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	280	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$28,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6598
Location:	Mandarin Cir - North				
X Coordinate:	-121.25543				
Y Coordinate:	38.69806				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	350	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$35,000.00
		Status:	
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6599
Location:	Mandarin Cir - North				
X Coordinate:	-121.25535				
Y Coordinate:	38.69899				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	275	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$27,500.00
		Status:	
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/4/2011	Report Date:	4/4/2011	Barrier #:	6600
Location:	Melva St - West				
X Coordinate:	-121.25434				
Y Coordinate:	38.6991				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	441	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$44,100.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6601
Location:	Cross Dr - East				
X Coordinate:	-121.25796				
Y Coordinate:	38.70036				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	1397	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$139,700.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6602
Location:	Cross Dr - East				
X Coordinate:	-121.258				
Y Coordinate:	38.69652				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB
Description:	No barricade provided where sidewalk ends in hazardous location		
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk		
Solution:	Provide barricade with cane detectable warning at end of sidewalk		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6603
Location:	Cross Dr - East				
X Coordinate:	-121.25802				
Y Coordinate:	38.69648				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	98	Quantity:	LF
Description:	Cross slope exceeds 2.0% (2.1% to 3.0%)		
As Built Desc:	3.0% cross slope		
Solution:	Low severity barrier - no remediation recommended		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6604A
Location:	Cross Dr - East				
X Coordinate:	-121.25797				
Y Coordinate:	38.69587				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	117	Quantity:	LF
Description:	Cross slope exceeds 2.0% (2.1% to 3.0%)		
As Built Desc:	3.0% cross slope		
Solution:	Low severity barrier - no remediation recommended		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6604B
Location:	Cross Dr - East				
X Coordinate:	-121.25797				
Y Coordinate:	38.69559				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6605
Location:	Cross Dr - East				
X Coordinate:	-121.25799				
Y Coordinate:	38.69534				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6606
Location:	Cross Dr - West				
X Coordinate:	-121.25812				
Y Coordinate:	38.69317				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date: 4/6/2011 Report Date: 4/6/2011 Barrier #: 6607

Location: Cross Dr - West

X Coordinate: -121.25812

Y Coordinate: 38.69329

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 44 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.1% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hindrance Cost Estimate: \$5,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/6/2011 Report Date: 4/6/2011 Barrier #: 6608

Location: Cross Dr - West

X Coordinate: -121.25811

Y Coordinate: 38.6937

Barrier Area: Sidewalks

Barrier Type: Clear Width - Existing ($\leq 31"$ or less)

Code Ref: CBC 1133B.7.1



As Built Meas: 2 Quantity: LF

Description: Pedestrian route is not min. 48" wide ($\leq 31"$ or less)

As Built Desc: 24" clear width due to pole

Solution: Demolish existing and construct new route

Bar. Severity: 1 Necessary Cost Estimate: \$250.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6609
Location:	Cross Dr - West				
X Coordinate:	-121.25812				
Y Coordinate:	38.69407				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	2	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to pole		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6610
Location:	Cross Dr and Stacey Hills Dr - Corner A				
X Coordinate:	-121.25817				
Y Coordinate:	38.69425				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	10.4% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,D		

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6611
Location:	Cross Dr and Stacey Hills Dr - Corner D				
X Coordinate:	-121.25815				
Y Coordinate:	38.69412				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	13.1% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,D		

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6612A
Location:	Stacey Hills Dr - South				
X Coordinate:	-121.25824				
Y Coordinate:	38.6941				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	216	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$27,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6612B
Location:	Stacey Hills Dr - South				
X Coordinate:	-121.25863				
Y Coordinate:	38.6941				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6613
Location:	Stacey Hills Dr and Stacey Hills Dr - Corner B				
X Coordinate:	-121.25894				
Y Coordinate:	38.69422				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.0% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date: 4/6/2011 Report Date: 4/6/2011 Barrier #: 6614

Location: Stacey Hills Dr and Stacey Hills Dr - Corner C

X Coordinate: -121.25891

Y Coordinate: 38.69408

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 19.0% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners B,C

Field Date: 4/6/2011 Report Date: 4/6/2011 Barrier #: 6615

Location: Stacey Hills Dr - Eaast

X Coordinate: -121.2589

Y Coordinate: 38.69399

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 211 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.4% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hindrance Cost Estimate: \$26,375.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/6/2011 Report Date: 4/6/2011 Barrier #: 6616

Location: Stacey Hills Dr - South

X Coordinate: -121.26101

Y Coordinate: 38.69352

Barrier Area: Sidewalks

Barrier Type: Surface Condition - Damaged

Code Ref: CBC 1133B.7.1 and ADA/ABA 302.1



As Built Meas: 4 Quantity: LF

Description: Surface is not firm and stable (cracked, broken or loose soil, etc.)

As Built Desc: Cracked concrete

Solution: Repair surface to make firm and stable

Bar. Severity: 1 Necessary Cost Estimate: \$500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/6/2011 Report Date: 4/6/2011 Barrier #: 6617A

Location: Stacey Hills Dr and Checkerbloom Wy - Corner A

X Coordinate: -121.26184

Y Coordinate: 38.69365

Barrier Area: Curb Ramps

Barrier Type: 12" Grooves - Existing (4.1% to 4.9%)

Code Ref: CBC 1127B.5.6



As Built Meas: 1 Quantity: EACH

Description: 12" grooves at top of curb ramp are not level (4.1% to 4.9%)

As Built Desc: 4.8% at 12" grooves

Solution: Demolish existing and construct new curb ramp

Bar. Severity: 2 Recommended Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A,B

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6617B
Location:	Stacey Hills Dr and Checkerbloom Wy - Corner A				
X Coordinate:	-121.26184				
Y Coordinate:	38.69365				
Barrier Area:	Curb Ramps				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	1	Quantity:	EACH
Description:	Ramp run cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	9.3% cross slope		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6617C
Location:	Stacey Hills Dr and Checkerbloom Wy - Corner A				
X Coordinate:	-121.26184				
Y Coordinate:	38.69365				
Barrier Area:	Curb Ramps				
Barrier Type:	Parallel Ramp Landing - Existing (>5.0% or more)				
Code Ref:	CBC 1127B.5.4 and ADA/ABA 406.4				



As Built Meas:	1	Quantity:	EACH
Description:	Curb ramp landing or pan not level (>5.0% or more)		
As Built Desc:	9.1% landing slope		
Solution:	Demolish existing and construct new transition		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6618A
Location:	Stacey Hills Dr and Checkerbloom Wy - Corner B				
X Coordinate:	-121.26168				
Y Coordinate:	38.6936				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (>5.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (>5.0%)		
As Built Desc:	6.4% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6618B
Location:	Stacey Hills Dr and Checkerbloom Wy - Corner B				
X Coordinate:	-121.2619				
Y Coordinate:	38.69618				
Barrier Area:	Curb Ramps				
Barrier Type:	Parallel Ramp Landing - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.4 and ADA/ABA 406.4				



As Built Meas:	1	Quantity:	EACH
Description:	Curb ramp landing or pan not level (3.1% to 4.0%)		
As Built Desc:	3.5% landing slope		
Solution:	Demolish existing and construct new transition		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6619
Location:	Checkerbloom Wy - East				
X Coordinate:	-121.26191				
Y Coordinate:	38.69621				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	400	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$50,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6620
Location:	Checkerbloom Wy - East				
X Coordinate:	-121.26171				
Y Coordinate:	38.69435				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	8	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6621
Location:	Checkerbloom Wy - East				
X Coordinate:	-121.26167				
Y Coordinate:	38.69399				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	4	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6622
Location:	Stacey Hills Dr - North				
X Coordinate:	-121.26098				
Y Coordinate:	38.69361				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6623
Location:	Stacey Hills Dr and Forbs Wy - Corner A				
X Coordinate:	-121.26094				
Y Coordinate:	38.69361				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.6% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6624
Location:	Stacey Hills Dr and Forbs Wy - Corner B				
X Coordinate:	-121.26078				
Y Coordinate:	38.69361				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	7.0% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6625
Location:	Forbs Wy - West				
X Coordinate:	-121.26105				
Y Coordinate:	38.69524				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	347	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	3.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$43,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6626A
Location:	Forbs Wy - East				
X Coordinate:	-121.26097				
Y Coordinate:	38.69614				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				




As Built Meas:	933	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$116,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6626B
Location:	Forbs Wy - East				
X Coordinate:	-121.26079				
Y Coordinate:	38.69484				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6627
Location:	Stacey Hills Dr and Yarrow Wy - Corner A				
X Coordinate:	-121.26002				
Y Coordinate:	38.69364				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.1% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6628
Location:	Stacey Hills Dr and Yarrow Wy - Corner B				
X Coordinate:	-121.25988				
Y Coordinate:	38.69364				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.2% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6629A
Location:	Yarrow Wy - West				
X Coordinate:	-121.26001				
Y Coordinate:	38.6937				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	918	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$114,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6629B
Location:	Yarrow Wy - West				
X Coordinate:	-121.26001				
Y Coordinate:	38.69371				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6629C
Location:	Yarrow Wy - West				
X Coordinate:	-121.26013				
Y Coordinate:	38.6951				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date: 4/6/2011 Report Date: 4/6/2011 Barrier #: 6630

Location: Poppyfield Wy - South

X Coordinate: -121.26032

Y Coordinate: 38.69624

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 178 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 4.0% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hindrance Cost Estimate: \$22,250.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/6/2011 Report Date: 4/6/2011 Barrier #: 6631

Location: Poppyfield Wy - South

X Coordinate: -121.26121

Y Coordinate: 38.69624

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 200 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.5% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hindrance Cost Estimate: \$25,000.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6632
Location:	Poppyfield Wy - South				
X Coordinate:	-121.26207				
Y Coordinate:	38.69621				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	78	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$9,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6633A
Location:	Poppyfield Wy - North				
X Coordinate:	-121.26228				
Y Coordinate:	38.69633				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	583	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$72,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6633B
Location:	Poppyfield Wy - North				
X Coordinate:	-121.26156				
Y Coordinate:	38.69633				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	4	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6634A
Location:	Yarrow Wy - West				
X Coordinate:	-121.26023				
Y Coordinate:	38.69638				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	417	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$52,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6634B
Location:	Yarrow Wy - West				
X Coordinate:	-121.2602				
Y Coordinate:	38.69643				
Barrier Area:	Sidewalks				
Barrier Type:	Protruding Hazard				
Code Ref:	CBC 1133B.8.6.1 and ADA/ABA 307.2				



As Built Meas:	1	Quantity:	JOB
Description:	Protruding object in route of travel between 27" and 80" high		
As Built Desc:	27" at tree branch		
Solution:	Remove object or provide detectable warning		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,400.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6635
Location:	Yarrow Wy - West				
X Coordinate:	-121.26092				
Y Coordinate:	38.69737				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	750	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$93,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6636
Location:	Yarrow Wy - West				
X Coordinate:	-121.26078				
Y Coordinate:	38.69939				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - Transition to Shoulder				
Code Ref:	CBC 1121B.2 and ADA/ABA 206.2.1				



As Built Meas:	1	Quantity:	JOB
Description:	Sidewalk ends and no ramp to pedestrian shoulder is provided		
As Built Desc:	No ramp to shoulder to enable pedestrian travel onto existing shoulder		
Solution:	Provide transition ramp to paved shoulder where no opposite sidewalk exists		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6637
Location:	Yarrow Wy - East				
X Coordinate:	-121.26072				
Y Coordinate:	38.69935				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	148	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$14,800.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6638
Location:	Yarrow Wy - East				
X Coordinate:	-121.26067				
Y Coordinate:	38.69893				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB
Description:	No barricade provided where sidewalk ends in hazardous location		
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk		
Solution:	Provide barricade with cane detectable warning at end of sidewalk		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6639A
Location:	Yarrow Wy - East				
X Coordinate:	-121.26069				
Y Coordinate:	38.69893				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	629	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$78,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6639B
Location:	Yarrow Wy - East				
X Coordinate:	-121.26068				
Y Coordinate:	38.69814				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	8	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6640
Location:	Yarrow Wy - East				
X Coordinate:	-121.26073				
Y Coordinate:	38.6972				
Barrier Area:	Sidewalks				
Barrier Type:	Elbow in Sidewalk - Cross Slope (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	6	Quantity:	LF
Description:	Cross slope at elbow exceeds 2.0% (5.0% or more)		
As Built Desc:	10.3% cross slope		
Solution:	Demolish existing and construct new sidewalk without curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6641
Location:	Yarrow Wy and Juli Ct - Corner B				
X Coordinate:	-121.26016				
Y Coordinate:	38.6969				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners B,C

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6642
Location:	Yarrow Wy and Juli Ct - Corner C				
X Coordinate:	-121.26013				
Y Coordinate:	38.6968				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners B,C

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6643
Location:	Juli Ct - North				
X Coordinate:	-121.26011				
Y Coordinate:	38.69694				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	345	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$43,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6644
Location:	Juli Ct - South				
X Coordinate:	-121.25949				
Y Coordinate:	38.69753				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	345	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$43,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6645A
Location:	Yarrow Wy - East				
X Coordinate:	-121.26014				
Y Coordinate:	38.69677				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	145	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$18,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6645B
Location:	Yarrow Wy - East				
X Coordinate:	-121.26014				
Y Coordinate:	38.69664				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6646
Location:	Nettle Ct - North				
X Coordinate:	-121.26				
Y Coordinate:	38.69631				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	257	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$32,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6647A
Location:	Nettle Ct - South				
X Coordinate:	-121.2593				
Y Coordinate:	38.69598				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	324	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$40,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6647B
Location:	Nettle Ct - South				
X Coordinate:	-121.25958				
Y Coordinate:	38.69615				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6648
Location:	Yarrow Wy - East				
X Coordinate:	-121.2601				
Y Coordinate:	38.69616				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	754	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$94,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6649
Location:	Stacey Hills - North				
X Coordinate:	-121.25906				
Y Coordinate:	38.69356				
Barrier Area:	Sidewalks				
Barrier Type:	Elbow in Sidewalk - Cross Slope (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	6	Quantity:	LF
Description:	Cross slope at elbow exceeds 2.0% (5.0% or more)		
As Built Desc:	7.6% cross slope		
Solution:	Demolish existing and construct new sidewalk without curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6650
Location:	Cross Dr - West				
X Coordinate:	-121.25814				
Y Coordinate:	38.69429				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	4	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6651A
Location:	Cross Dr - West				
X Coordinate:	-121.25813				
Y Coordinate:	38.69436				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	122	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$15,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6651B
Location:	Cross Dr - West				
X Coordinate:	-121.25811				
Y Coordinate:	38.69452				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	2	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to pole		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6651C
Location:	Cross Dr - West				
X Coordinate:	-121.25814				
Y Coordinate:	38.69465				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	2	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to pole		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6652
Location:	Cross Dr - West				
X Coordinate:	-121.25813				
Y Coordinate:	38.69541				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	2	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to pole		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6653
Location:	Cross Dr - West				
X Coordinate:	-121.25812				
Y Coordinate:	38.69554				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB
Description:	No barricade provided where sidewalk ends in hazardous location		
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk		
Solution:	Provide barricade with cane detectable warning at end of sidewalk		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6654
Location:	Cross Dr - West				
X Coordinate:	-121.25811				
Y Coordinate:	38.6956				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	4	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/6/2011	Report Date:	4/6/2011	Barrier #:	6655
Location:	Cross Dr - West				
X Coordinate:	-121.25804				
Y Coordinate:	38.69563				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	2596	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$259,600.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6656
Location:	San Cosme Dr - North				
X Coordinate:	-121.26316				
Y Coordinate:	38.69726				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	49	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$6,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6657
Location:	San Cosme Dr and Single Wy - Corner B				
X Coordinate:	-121.2633				
Y Coordinate:	38.69727				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)		
As Built Desc:	3.6% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A, B. Corner A compliant		

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6658
Location:	Single Wy - East				
X Coordinate:	-121.2633				
Y Coordinate:	38.69741				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	1051	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$131,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6659
Location:	Single Wy - West				
X Coordinate:	-121.26356				
Y Coordinate:	38.70018				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	829	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$103,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6660A
Location:	Single Wy and Dana Butte Wy - Corner A				
X Coordinate:	-121.26352				
Y Coordinate:	38.69796				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)		
As Built Desc:	3.4% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A, D
--------	-------------------------------------

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6660B
Location:	Single Wy and Dana Butte Wy - Corner A				
X Coordinate:	-121.26352				
Y Coordinate:	38.69796				
Barrier Area:	Curb Ramps				
Barrier Type:	Parallel Ramp Landing - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.4 and ADA/ABA 406.4				



As Built Meas:	1	Quantity:	EACH
Description:	Curb ramp landing or pan not level (3.1% to 4.0%)		
As Built Desc:	3.8% landing slope		
Solution:	Demolish existing and construct new transition		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A, D		

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6660C
Location:	Single Wy and Dana Butte Wy - Corner A				
X Coordinate:	-121.26352				
Y Coordinate:	38.69796				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A, D		

Field Date: 4/7/2011 Report Date: 4/8/2011 Barrier #: 6660D

Location: Single Wy and Dana Butte Wy - Corner A

X Coordinate: -121.26352

Y Coordinate: 38.69796

Barrier Area: Curb Ramps

Barrier Type: Gutter Slope - Existing (6.6% to 8.2%)

Code Ref: CBC 1127B.5.3 and ADA/ABA 406.2



As Built Meas: 6 Quantity: SF

Description: Gutter slope exceeds 5.0% (6.6% to 8.2%)

As Built Desc: 7.1% gutter slope

Solution: Demolish existing and construct new gutter

Bar. Severity: 2 Recommended Cost Estimate: \$0.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A, D

Field Date: 4/7/2011 Report Date: 4/8/2011 Barrier #: 6661A

Location: Single Wy and Dana Butte Wy - Corner D

X Coordinate: -121.26349

Y Coordinate: 38.69783

Barrier Area: Curb Ramps

Barrier Type: Parallel Ramp Landing - Existing (2.1% to 3.0%)

Code Ref: CBC 1127B.5.4 and ADA/ABA 406.4



As Built Meas: 1 Quantity: EACH

Description: Curb ramp landing or pan not level (2.1% to 3.0%)

As Built Desc: 2.8% landing slope

Solution: Demolish existing and construct new transition

Bar. Severity: 4 Low Severity Cost Estimate: \$250.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A, D

Field Date: 4/7/2011 Report Date: 4/8/2011 Barrier #: 6661B

Location: Single Wy and Dana Butte Wy - Corner D

X Coordinate: -121.26349

Y Coordinate: 38.69783

Barrier Area: Curb Ramps

Barrier Type: Detectable Warnings - Truncated Domes

Code Ref: CBC 1127B.5.7 and ADA/ABA 705.1.3



As Built Meas: 1 Quantity: EACH

Description: No truncated domes provided at curb ramp

As Built Desc: No detectable warnings at curb ramp

Solution: Provide compliant truncated domes

Bar. Severity: 2 Recommended Cost Estimate: \$1,400.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A, D

Field Date: 4/7/2011 Report Date: 4/8/2011 Barrier #: 6662

Location: Single Wy - West

X Coordinate: -121.26348

Y Coordinate: 38.69775

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 178 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 4.0% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hindrance Cost Estimate: \$22,250.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6663
Location:	San Cosme Dr - North				
X Coordinate:	-121.26351				
Y Coordinate:	38.69728				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	638	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$79,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6664
Location:	Alma Mesa Wy - East				
X Coordinate:	-121.26539				
Y Coordinate:	38.69823				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	210	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$26,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6665
Location:	Alma Mesa Wy and Dana Butte Wy - Corner B				
X Coordinate:	-121.26549				
Y Coordinate:	38.69891				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (4.1% to 4.9%)		
As Built Desc:	4.1% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D. Corners A,C,D compliant		

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6666
Location:	Dana Butte Wy - South				
X Coordinate:	-121.26528				
Y Coordinate:	38.69883				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	648	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$81,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6667
Location:	Dana Butte Wy - North				
X Coordinate:	-121.26356				
Y Coordinate:	38.69796				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	659	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$82,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6668
Location:	Alma Mesa Wy - East				
X Coordinate:	-121.2654				
Y Coordinate:	38.69901				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	240	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$30,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6669A
Location:	Alma Mesa Wy - North				
X Coordinate:	-121.26561				
Y Coordinate:	38.69972				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	845	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$105,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6669B
Location:	Alma Mesa Wy - North				
X Coordinate:	-121.26752				
Y Coordinate:	38.69967				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6669C
Location:	Alma Mesa Wy - North				
X Coordinate:	-121.26842				
Y Coordinate:	38.69968				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	8" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6670
Location:	Alma Mesa Wy - West				
X Coordinate:	-121.26859				
Y Coordinate:	38.69962				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	275	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$34,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6671
Location:	Alma Mesa Wy - East				
X Coordinate:	-121.26837				
Y Coordinate:	38.69895				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	210	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$26,250.00
Status:			
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6672A
Location:	Alma Mesa Wy - South				
X Coordinate:	-121.26832				
Y Coordinate:	38.69947				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	747	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$93,375.00
Status:			
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			


Notes:	
--------	--

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6672B
Location:	Alma Mesa Wy - South				
X Coordinate:	-121.26718				
Y Coordinate:	38.69954				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - Tree Heaves				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	12	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	5/8" lip due to tree heaves		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$3,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6672C
Location:	Alma Mesa Wy - South				
X Coordinate:	-121.2671				
Y Coordinate:	38.69953				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6673
Location:	Alma Mesa Wy - West				
X Coordinate:	-121.26562				
Y Coordinate:	38.69954				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	58	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$7,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6674
Location:	Alma Mesa Wy - West				
X Coordinate:	-121.26562				
Y Coordinate:	38.69933				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	124	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$15,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6675
Location:	Dana Butte Wy - North				
X Coordinate:	-121.26568				
Y Coordinate:	38.69892				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	764	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$95,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6676
Location:	Dana Butte Wy - North				
X Coordinate:	-121.26868				
Y Coordinate:	38.69892				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	177	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$22,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 4/7/2011 Report Date: 4/8/2011 Barrier #: 6677

Location: Dana Butte Wy - South

X Coordinate: -121.26918

Y Coordinate: 38.69878

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 1028 Quantity: LF

Description: Cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 5.1% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 1 Necessary Cost Estimate: \$128,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/7/2011 Report Date: 4/8/2011 Barrier #: 6678

Location: Alma Mesa Wy - West

X Coordinate: -121.26555

Y Coordinate: 38.6988

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 208 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.6% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$26,000.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6679A
Location:	San Cosme Dr - North				
X Coordinate:	-121.26563				
Y Coordinate:	38.69814				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	1027	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$128,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6679B
Location:	San Cosme Dr - North				
X Coordinate:	-121.26836				
Y Coordinate:	38.69812				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6679C
Location:	San Cosme Dr - North				
X Coordinate:	-121.2686				
Y Coordinate:	38.69811				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6679D
Location:	San Cosme Dr - North				
X Coordinate:	-121.26879				
Y Coordinate:	38.69812				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date: 4/7/2011 Report Date: 4/8/2011 Barrier #: 6680

Location: San Cosme Dr - South

X Coordinate: -121.26906

Y Coordinate: 38.69801

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 189 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.3% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$23,625.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/7/2011 Report Date: 4/8/2011 Barrier #: 6681

Location: San Cosme Dr and Camel Rock Wy - Corner C

X Coordinate: -121.26834

Y Coordinate: 38.69802

Barrier Area: Curb Ramps

Barrier Type: 12" Grooves - Existing (4.1% to 4.9%)

Code Ref: CBC 1127B.5.6



As Built Meas: 1 Quantity: EACH

Description: 12" grooves at top of curb ramp are not level (4.1% to 4.9%)

As Built Desc: 4.9% at 12" grooves

Solution: Demolish existing and construct new curb ramp

Bar. Severity: 2 Recommended Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners C, D. Corner D compliant

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6682
Location:	Camel Rock Wy - West				
X Coordinate:	-121.26845				
Y Coordinate:	38.69792				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	549	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$68,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6683
Location:	Camel Rock Wy - East				
X Coordinate:	-121.26827				
Y Coordinate:	38.69651				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	267	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$33,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6684
Location:	Camel Rock Wy and Escalante Wy - Corner B				
X Coordinate:	-121.26832				
Y Coordinate:	38.69738				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners B,C

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6685
Location:	Camel Rock Wy and Escalante Wy - Corner C				
X Coordinate:	-121.26831				
Y Coordinate:	38.69724				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners B,C

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6686
Location:	Escalante Wy - South				
X Coordinate:	-121.26805				
Y Coordinate:	38.69724				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	218	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$27,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6687
Location:	Escalante Wy - West				
X Coordinate:	-121.26747				
Y Coordinate:	38.69721				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	284	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$35,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 4/7/2011 Report Date: 4/8/2011 Barrier #: 6688

Location: Escalante Wy - East

X Coordinate: -121.26732

Y Coordinate: 38.69647

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 316 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.2% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$39,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/7/2011 Report Date: 4/8/2011 Barrier #: 6689

Location: Escalante Wy - North

X Coordinate: -121.26736

Y Coordinate: 38.69731

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 276 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.3% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$34,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6690
Location:	Camel Rock Wy - East				
X Coordinate:	-121.2683				
Y Coordinate:	38.69748				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	207	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$25,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6691
Location:	San Cosme Dr - South				
X Coordinate:	-121.26813				
Y Coordinate:	38.69802				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	517	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$64,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6692
Location:	San Cosme Dr and Ocone Ct - Corner D				
X Coordinate:	-121.26645				
Y Coordinate:	38.69802				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (2.1% to 3.0%)		
As Built Desc:	3.0% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners C, D. Corner C compliant

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6693
Location:	Ocone Ct - West				
X Coordinate:	-121.26642				
Y Coordinate:	38.69796				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	361	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$45,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6694
Location:	Ocone Ct - East				
X Coordinate:	-121.26629				
Y Coordinate:	38.69771				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	366	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$45,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6695
Location:	San Cosme Dr - South				
X Coordinate:	-121.26612				
Y Coordinate:	38.69803				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	200	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$25,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6696A
Location:	Alma Mesa Wy - West				
X Coordinate:	-121.26552				
Y Coordinate:	38.69776				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	371	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$46,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6696B
Location:	Alma Mesa Wy - West				
X Coordinate:	-121.26549				
Y Coordinate:	38.69706				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6697
Location:	Alma Mesa Wy - East				
X Coordinate:	-121.2653				
Y Coordinate:	38.69703				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	8	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6698
Location:	Alma Mesa Wy - East				
X Coordinate:	-121.26531				
Y Coordinate:	38.69716				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	409	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$51,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6699
Location:	San Cosme Dr - South				
X Coordinate:	-121.26534				
Y Coordinate:	38.69801				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	335	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$41,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6700
Location:	San Cosme Dr and San Cosme Ct - Corner D				
X Coordinate:	-121.26441				
Y Coordinate:	38.69737				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)		
As Built Desc:	3.7% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners C, D. Corner C compliant
--------	---

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6701
Location:	San Cosme Ct - West				
X Coordinate:	-121.26447				
Y Coordinate:	38.69732				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	130	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$16,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6702
Location:	San Cosme Ct - East				
X Coordinate:	-121.26449				
Y Coordinate:	38.69704				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	103	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$12,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/7/2011	Report Date:	4/8/2011	Barrier #:	6703
Location:	San Cosme Dr - South				
X Coordinate:	-121.26385				
Y Coordinate:	38.69716				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	450	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$56,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6704
Location:	Canelo Hills Dr - East				
X Coordinate:	-121.26914				
Y Coordinate:	38.70002				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	478	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$59,750.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6705A
Location:	Canelo Hills Dr and Dana Butte Wy - Corner A				
X Coordinate:	-121.26951				
Y Coordinate:	38.69888				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)		
As Built Desc:	3.4% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Three - way intersection corners A, B, C

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6705B
Location:	Canelo Hills Dr and Dana Butte Wy - Corner A				
X Coordinate:	-121.26951				
Y Coordinate:	38.69888				
Barrier Area:	Curb Ramps				
Barrier Type:	Running Slope - Existing (9.0% to 9.4%)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.1				



As Built Meas:	1	Quantity:	EACH
Description:	Ramp run cross slope exceeds 2.0% (9.0% to 9.4%)		
As Built Desc:	9.0% running slope		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Three - way intersection corners A, B, C

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6705C
Location:	Canelo Hills Dr and Dana Butte Wy - Corner A				
X Coordinate:	-121.26951				
Y Coordinate:	38.69888				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Three - way intersection corners A, B, C		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6705D
Location:	Canelo Hills Dr and Dana Butte Wy - Corner A				
X Coordinate:	-121.26951				
Y Coordinate:	38.69888				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (8.3% or more)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	6	Quantity:	SF
Description:	Gutter slope exceeds 5.0% (8.3% or more)		
As Built Desc:	9.5% gutter slope		
Solution:	Demolish existing and construct new gutter		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Three - way intersection corners A, B, C		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6706A
Location:	Canelo Hills Dr and Dana Butte Wy - Corner B				
X Coordinate:	-121.26918				
Y Coordinate:	38.69892				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (4.1% to 4.9%)		
As Built Desc:	4.9% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Three - way intersection corners A, B, C		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6706B
Location:	Canelo Hills Dr and Dana Butte Wy - Corner B				
X Coordinate:	-121.26918				
Y Coordinate:	38.69892				
Barrier Area:	Curb Ramps				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	1	Quantity:	EACH
Description:	Ramp run cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.2% cross slope		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$0.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Three - way intersection corners A, B, C		

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6706C

Location: Canelo Hills Dr and Dana Butte Wy - Corner B

X Coordinate: -121.26918

Y Coordinate: 38.69892

Barrier Area: Curb Ramps

Barrier Type: Detectable Warnings - Truncated Domes

Code Ref: CBC 1127B.5.7 and ADA/ABA 705.1.3



As Built Meas: 1 Quantity: EACH

Description: No truncated domes provided at curb ramp

As Built Desc: No detectable warnings at curb ramp

Solution: Provide compliant truncated domes

Bar. Severity: 2 Recommended Cost Estimate: \$0.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Three - way intersection corners A, B, C

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6706D

Location: Canelo Hills Dr and Dana Butte Wy - Corner B

X Coordinate: -121.26918

Y Coordinate: 38.69892

Barrier Area: Curb Ramps

Barrier Type: Lip - Bottom of Ramp at Flow Line

Code Ref: CBC 1127B.5.3 and ADA/ABA 303.3



As Built Meas: 1 Quantity: EACH

Description: Transition at ramp bottom (flow line) is not flush and free of any lip

As Built Desc: 1/2" lip at flow line

Solution: Remove lip to create flush transition

Bar. Severity: 1 Necessary Cost Estimate: \$0.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Three - way intersection corners A, B, C

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6706E

Location: Canelo Hills Dr and Dana Butte Wy - Corner B

X Coordinate: -121.26918

Y Coordinate: 38.69892

Barrier Area: Curb Ramps

Barrier Type: Gutter Slope - Existing (8.3% or more)

Code Ref: CBC 1127B.5.3 and ADA/ABA 406.2



As Built Meas: 6 Quantity: SF

Description: Gutter slope exceeds 5.0% (8.3% or more)

As Built Desc: 9.4% gutter slope

Solution: Demolish existing and construct new gutter

Bar. Severity: 1 Necessary Cost Estimate: \$0.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Three - way intersection corners A, B, C

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6707A

Location: Canelo Hills Dr and Dana Butte Wy - Corner C

X Coordinate: -121.26918

Y Coordinate: 38.69878

Barrier Area: Curb Ramps

Barrier Type: 12" Grooves - Existing (>5.0%)

Code Ref: CBC 1127B.5.6



As Built Meas: 1 Quantity: EACH

Description: 12" grooves at top of curb ramp are not level (>5.0%)

As Built Desc: 5.7% at 12" grooves

Solution: Demolish existing and construct new curb ramp

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Three - way intersection corners A, B, C

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6707B
Location:	Canelo Hills Dr and Dana Butte Wy - Corner C				
X Coordinate:	-121.26918				
Y Coordinate:	38.69878				
Barrier Area:	Curb Ramps				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	1	Quantity:	EACH
Description:	Ramp run cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.9% cross slope		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$0.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Three - way intersection corners A, B, C

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6707C
Location:	Canelo Hills Dr and Dana Butte Wy - Corner C				
X Coordinate:	-121.26918				
Y Coordinate:	38.69878				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Three - way intersection corners A, B, C

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6707D
Location:	Canelo Hills Dr and Dana Butte Wy - Corner C				
X Coordinate:	-121.26918				
Y Coordinate:	38.69878				
Barrier Area:	Curb Ramps				
Barrier Type:	Lip - Bottom of Ramp at Flow Line				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 303.3				



As Built Meas:	1	Quantity:	EACH
Description:	Transition at ramp bottom (flow line) is not flush and free of any lip		
As Built Desc:	1/2" lip at flow line		
Solution:	Remove lip to create flush transition		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Three - way intersection corners A, B, C		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6707E
Location:	Canelo Hills Dr and Dana Butte Wy - Corner C				
X Coordinate:	-121.26918				
Y Coordinate:	38.69878				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (8.3% or more)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	6	Quantity:	SF
Description:	Gutter slope exceeds 5.0% (8.3% or more)		
As Built Desc:	8.5% gutter slope		
Solution:	Demolish existing and construct new gutter		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Three - way intersection corners A, B, C		

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6708

Location: Canelo Hills Dr - East

X Coordinate: -121.26923

Y Coordinate: 38.69852

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 215 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.7% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$26,875.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6709

Location: Canelo Hills Dr and San Cosme Dr - Corner B

X Coordinate: -121.26915

Y Coordinate: 38.69818

Barrier Area: Curb Ramps

Barrier Type: 12" Grooves - Existing (3.1% to 4.0%)

Code Ref: CBC 1127B.5.6



As Built Meas: 1 Quantity: EACH

Description: 12" grooves at top of curb ramp are not level (3.1% to 4.0%)

As Built Desc: 3.2% at 12" grooves

Solution: Demolish existing and construct new curb ramp

Bar. Severity: 3 Hindrance Cost Estimate: \$2,500.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners B, C. Corner C compliant

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6710
Location:	Canelo Hills Dr - East				
X Coordinate:	-121.26913				
Y Coordinate:	38.69769				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	558	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$69,750.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6711A
Location:	Canelo Hills Dr and Copperwood Dr - Corner B				
X Coordinate:	-121.26911				
Y Coordinate:	38.69644				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)		
As Built Desc:	3.7% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6711B
Location:	Canelo Hills Dr and Copperwood Dr - Corner B				
X Coordinate:	-121.26911				
Y Coordinate:	38.69644				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners B,C

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6711C
Location:	Canelo Hills Dr and Copperwood Dr - Corner B				
X Coordinate:	-121.26911				
Y Coordinate:	38.69644				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (8.3% or more)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	6	Quantity:	SF
Description:	Gutter slope exceeds 5.0% (8.3% or more)		
As Built Desc:	14.3% gutter slope		
Solution:	Demolish existing and construct new gutter		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners B,C

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6712A
Location:	Canelo Hills Dr and Copperwood Dr - Corner C				
X Coordinate:	-121.26913				
Y Coordinate:	38.69627				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)		
As Built Desc:	3.1% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners B,C

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6712B
Location:	Canelo Hills Dr and Copperwood Dr - Corner C				
X Coordinate:	-121.26913				
Y Coordinate:	38.69627				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners B,C

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6712C
Location:	Canelo Hills Dr and Copperwood Dr - Corner C				
X Coordinate:	-121.26913				
Y Coordinate:	38.69627				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (6.6% to 8.2%)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	6	Quantity:	SF
Description:	Gutter slope exceeds 5.0% (6.6% to 8.2%)		
As Built Desc:	7.4% gutter slope		
Solution:	Demolish existing and construct new gutter		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners B,C

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6713
Location:	Copperwood Dr - North				
X Coordinate:	-121.26885				
Y Coordinate:	38.69644				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	192	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$24,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6714A
Location:	Copperwood Dr and Camel Rock Wy - Corner A				
X Coordinate:	-121.26848				
Y Coordinate:	38.69644				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (>5.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (>5.0%)		
As Built Desc:	6.6% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Four - way intersection corners A, B, C, D

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6714B
Location:	Copperwood Dr and Camel Rock Wy - Corner A				
X Coordinate:	-121.26848				
Y Coordinate:	38.69644				
Barrier Area:	Curb Ramps				
Barrier Type:	Cross Slope - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	1	Quantity:	EACH
Description:	Ramp run cross slope exceeds 2.0% (2.1% to 3.0%)		
As Built Desc:	2.9% cross slope		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Four - way intersection corners A, B, C, D

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6714C
Location:	Copperwood Dr and Camel Rock Wy - Corner A				
X Coordinate:	-121.26848				
Y Coordinate:	38.69644				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A, B, C, D		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6714D
Location:	Copperwood Dr and Camel Rock Wy - Corner A				
X Coordinate:	-121.26848				
Y Coordinate:	38.69644				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (8.3% or more)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	6	Quantity:	SF
Description:	Gutter slope exceeds 5.0% (8.3% or more)		
As Built Desc:	10.7% gutter slope		
Solution:	Demolish existing and construct new gutter		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A, B, C, D		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6715A
Location:	Copperwood Dr and Camel Rock Wy - Corner B				
X Coordinate:	-121.26826				
Y Coordinate:	38.69642				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)		
As Built Desc:	3.7% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A, B, C, D		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6715B
Location:	Copperwood Dr and Camel Rock Wy - Corner B				
X Coordinate:	-121.26826				
Y Coordinate:	38.69642				
Barrier Area:	Curb Ramps				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	1	Quantity:	EACH
Description:	Ramp run cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A, B, C, D		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6715C
Location:	Copperwood Dr and Camel Rock Wy - Corner B				
X Coordinate:	-121.26826				
Y Coordinate:	38.69642				
Barrier Area:	Curb Ramps				
Barrier Type:	Abrupt Change in Level - >1/2"				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 303.3				



As Built Meas:	36	Quantity:	SF
Description:	Change in level greater than 1/2" in curb ramp		
As Built Desc:	1/2" lip in curb ramp surface		
Solution:	Grind or repair to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$9,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A, B, C, D		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6715D
Location:	Copperwood Dr and Camel Rock Wy - Corner B				
X Coordinate:	-121.26826				
Y Coordinate:	38.69642				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A, B, C, D		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6715E
Location:	Copperwood Dr and Camel Rock Wy - Corner C				
X Coordinate:	-121.26826				
Y Coordinate:	38.69642				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (8.3% or more)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	6	Quantity:	SF
Description:	Gutter slope exceeds 5.0% (8.3% or more)		
As Built Desc:	13.0% gutter slope		
Solution:	Demolish existing and construct new gutter		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A, B, C, D		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6716A
Location:	Copperwood Dr and Camel Rock Wy - Corner C				
X Coordinate:	-121.26823				
Y Coordinate:	38.69632				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)		
As Built Desc:	3.1% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A, B, C, D		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6716B
Location:	Copperwood Dr and Camel Rock Wy - Corner C				
X Coordinate:	-121.26823				
Y Coordinate:	38.69632				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A, B, C, D		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6716C
Location:	Copperwood Dr and Camel Rock Wy - Corner C				
X Coordinate:	-121.26823				
Y Coordinate:	38.69632				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (8.3% or more)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	6	Quantity:	SF
Description:	Gutter slope exceeds 5.0% (8.3% or more)		
As Built Desc:	9.5% gutter slope		
Solution:	Demolish existing and construct new gutter		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A, B, C, D		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6717A
Location:	Copperwood Dr and Camel Rock Wy - Corner D				
X Coordinate:	-121.26846				
Y Coordinate:	38.69632				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (>5.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (>5.0%)		
As Built Desc:	6.9% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A, B, C, D		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6717B
Location:	Copperwood Dr and Camel Rock Wy - Corner D				
X Coordinate:	-121.26846				
Y Coordinate:	38.69632				
Barrier Area:	Curb Ramps				
Barrier Type:	Parallel Ramp Landing - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.4 and ADA/ABA 406.4				



As Built Meas:	1	Quantity:	EACH
Description:	Curb ramp landing or pan not level (3.1% to 4.0%)		
As Built Desc:	3.1% landing slope		
Solution:	Demolish existing and construct new transition		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A, B, C, D		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6717C
Location:	Copperwood Dr and Camel Rock Wy - Corner D				
X Coordinate:	-121.26846				
Y Coordinate:	38.69632				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A, B, C, D		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6717D
Location:	Copperwood Dr and Camel Rock Wy - Corner D				
X Coordinate:	-121.26846				
Y Coordinate:	38.69632				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (8.3% or more)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	6	Quantity:	SF
Description:	Gutter slope exceeds 5.0% (8.3% or more)		
As Built Desc:	9.0% gutter slope		
Solution:	Demolish existing and construct new gutter		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A, B, C, D		

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6718

Location: Copperwood Dr - North

X Coordinate: -121.26809

Y Coordinate: 38.69646

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 213 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.9% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended

Cost Estimate: \$26,625.00

Status:

Implementation Priority: 4

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes:

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6719A

Location: Copperwood Dr and Escalante Wy - Corner A

X Coordinate: -121.26747

Y Coordinate: 38.69645

Barrier Area: Curb Ramps

Barrier Type: 12" Grooves - Existing (>5.0%)

Code Ref: CBC 1127B.5.6



As Built Meas: 1 Quantity: EACH

Description: 12" grooves at top of curb ramp are not level (>5.0%)

As Built Desc: 5.3% at 12" grooves

Solution: Demolish existing and construct new curb ramp

Bar. Severity: 1 Necessary

Cost Estimate: \$2,500.00

Status:

Implementation Priority: 4

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A,B

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6719B
Location:	Copperwood Dr and Escalante Wy - Corner A				
X Coordinate:	-121.26747				
Y Coordinate:	38.69645				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6719C
Location:	Copperwood Dr and Escalante Wy - Corner A				
X Coordinate:	-121.26747				
Y Coordinate:	38.69645				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (6.6% to 8.2%)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	6	Quantity:	SF
Description:	Gutter slope exceeds 5.0% (6.6% to 8.2%)		
As Built Desc:	6.8% gutter slope		
Solution:	Demolish existing and construct new gutter		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6720A
Location:	Copperwood Dr and Escalante Wy - Corner B				
X Coordinate:	-121.26735				
Y Coordinate:	38.69645				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (4.1% to 4.9%)		
As Built Desc:	4.1% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6720B
Location:	Copperwood Dr and Escalante Wy - Corner B				
X Coordinate:	-121.26735				
Y Coordinate:	38.69645				
Barrier Area:	Curb Ramps				
Barrier Type:	Parallel Ramp Landing - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1127B.5.4 and ADA/ABA 406.4				



As Built Meas:	1	Quantity:	EACH
Description:	Curb ramp landing or pan not level(4.1% to 4.9%)		
As Built Desc:	4.1% landing slope		
Solution:	Demolish existing and construct new transition		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6720C
Location:	Copperwood Dr and Escalante Wy - Corner B				
X Coordinate:	-121.26735				
Y Coordinate:	38.69645				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6720D
Location:	Copperwood Dr and Escalante Wy - Corner B				
X Coordinate:	-121.26735				
Y Coordinate:	38.69645				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (8.3% or more)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	6	Quantity:	SF
Description:	Gutter slope exceeds 5.0% (8.3% or more)		
As Built Desc:	8.5% gutter slope		
Solution:	Demolish existing and construct new gutter		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6721

Location: Copperwood Dr - North

X Coordinate: -121.26715

Y Coordinate: 38.69644

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 615 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.4% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended

Cost Estimate: \$76,875.00

Status:

Implementation Priority: 4

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes:

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6722A

Location: Copperwood Dr and McClung Dr - Corner A

X Coordinate: -121.26527

Y Coordinate: 38.69608

Barrier Area: Curb Ramps

Barrier Type: 12" Grooves - Existing (>5.0%)

Code Ref: CBC 1127B.5.6



As Built Meas: 1 Quantity: EACH

Description: 12" grooves at top of curb ramp are not level (>5.0%)

As Built Desc: 5.1% at 12" grooves

Solution: Demolish existing and construct new curb ramp

Bar. Severity: 1 Necessary

Cost Estimate: \$2,500.00

Status:

Implementation Priority: 4

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A,B

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6722B

Location: Copperwood Dr and McClung Dr - Corner A

X Coordinate: -121.26527

Y Coordinate: 38.69608

Barrier Area: Curb Ramps

Barrier Type: Detectable Warnings - Truncated Domes

Code Ref: CBC 1127B.5.7 and ADA/ABA 705.1.3



As Built Meas: 1 Quantity: EACH

Description: No truncated domes provided at curb ramp

As Built Desc: No detectable warnings at curb ramp

Solution: Provide compliant truncated domes

Bar. Severity: 2 Recommended

Cost Estimate: \$0.00

Status:

Implementation Priority: 4

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A,B

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6722C

Location: Copperwood Dr and McClung Dr - Corner A

X Coordinate: -121.26527

Y Coordinate: 38.69608

Barrier Area: Curb Ramps

Barrier Type: Gutter Slope - Existing (6.6% to 8.2%)

Code Ref: CBC 1127B.5.3 and ADA/ABA 406.2



As Built Meas: 6 Quantity: SF

Description: Gutter slope exceeds 5.0% (6.6% to 8.2%)

As Built Desc: 8.0% gutter slope

Solution: Demolish existing and construct new gutter

Bar. Severity: 2 Recommended

Cost Estimate: \$0.00

Status:

Implementation Priority: 4

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A,B

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6723A
Location:	Copperwood Dr and McClung Dr - Corner B				
X Coordinate:	-121.26515				
Y Coordinate:	38.69601				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (>5.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (>5.0%)		
As Built Desc:	6.1% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6723B
Location:	Copperwood Dr and McClung Dr - Corner B				
X Coordinate:	-121.26515				
Y Coordinate:	38.69601				
Barrier Area:	Curb Ramps				
Barrier Type:	Parallel Ramp Landing - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1127B.5.4 and ADA/ABA 406.4				



As Built Meas:	1	Quantity:	EACH
Description:	Curb ramp landing or pan not level (2.1% to 3.0%)		
As Built Desc:	3.0% landing slope		
Solution:	Demolish existing and construct new transition		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6723C
Location:	Copperwood Dr and McClung Dr - Corner B				
X Coordinate:	-121.26515				
Y Coordinate:	38.69601				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6723D
Location:	Copperwood Dr and McClung Dr - Corner B				
X Coordinate:	-121.26515				
Y Coordinate:	38.69601				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (8.3% or more)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	6	Quantity:	SF
Description:	Gutter slope exceeds 5.0% (8.3% or more)		
As Built Desc:	9.6% gutter slope		
Solution:	Demolish existing and construct new gutter		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6724A

Location: McClung Dr - West

X Coordinate: -121.26518

Y Coordinate: 38.69617

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 174 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.8% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hindrance Cost Estimate: \$21,750.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6724B

Location: McClung Dr - West

X Coordinate: -121.26466

Y Coordinate: 38.69644

Barrier Area: Sidewalks

Barrier Type: Protruding Hazard

Code Ref: CBC 1133B.8.6.1 and ADA/ABA 307.2



As Built Meas: 1 Quantity: JOB

Description: Protruding object in route of travel between 27" and 80" high

As Built Desc: 27" at tree branch

Solution: Remove object or provide detectable warning

Bar. Severity: 1 Necessary Cost Estimate: \$1,400.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6725
Location:	McClung Dr - North				
X Coordinate:	-121.26315				
Y Coordinate:	38.69655				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	356	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$44,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6726
Location:	McClung Dr - East				
X Coordinate:	-121.26313				
Y Coordinate:	38.69584				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	262	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$32,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6727
Location:	McClung Dr - West				
X Coordinate:	-121.26321				
Y Coordinate:	38.69638				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	132	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$16,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6728
Location:	McClung Dr - South				
X Coordinate:	-121.26461				
Y Coordinate:	38.69634				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	391	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$48,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6729
Location:	McClung Dr - South				
X Coordinate:	-121.2648				
Y Coordinate:	38.69632				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	67	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$8,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6730
Location:	McClung Dr - East				
X Coordinate:	-121.26504				
Y Coordinate:	38.69612				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	143	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$17,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6731A
Location:	Copperwood Dr - North				
X Coordinate:	-121.26505				
Y Coordinate:	38.69595				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	594	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$74,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6731B
Location:	Copperwood Dr - North				
X Coordinate:	-121.26426				
Y Coordinate:	38.69576				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6731C
Location:	Copperwood Dr - North				
X Coordinate:	-121.26406				
Y Coordinate:	38.69578				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6732A
Location:	Copperwood Dr and McClung Dr - Corner A				
X Coordinate:	-121.26314				
Y Coordinate:	38.69578				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (4.1% to 4.9%)		
As Built Desc:	4.8% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,B
--------	------------------------------------

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6732B
Location:	Copperwood Dr and McClung Dr - Corner A				
X Coordinate:	-121.26314				
Y Coordinate:	38.69578				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6732C
Location:	Copperwood Dr and McClung Dr - Corner A				
X Coordinate:	-121.26314				
Y Coordinate:	38.69578				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (8.3% or more)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	6	Quantity:	SF
Description:	Gutter slope exceeds 5.0% (8.3% or more)		
As Built Desc:	8.3% gutter slope		
Solution:	Demolish existing and construct new gutter		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6733A
Location:	Copperwood Dr and McClung Dr - Corner B				
X Coordinate:	-121.263				
Y Coordinate:	38.6958				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (>5.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (>5.0%)		
As Built Desc:	5.7% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6733B
Location:	Copperwood Dr and McClung Dr - Corner B				
X Coordinate:	-121.263				
Y Coordinate:	38.6958				
Barrier Area:	Curb Ramps				
Barrier Type:	Parallel Ramp Landing - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.4 and ADA/ABA 406.4				



As Built Meas:	1	Quantity:	EACH
Description:	Curb ramp landing or pan not level (3.1% to 4.0%)		
As Built Desc:	3.7% landing slope		
Solution:	Demolish existing and construct new transition		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6733C
Location:	Copperwood Dr and McClung Dr - Corner B				
X Coordinate:	-121.263				
Y Coordinate:	38.6958				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6733D
Location:	Copperwood Dr and McClung Dr - Corner B				
X Coordinate:	-121.263				
Y Coordinate:	38.6958				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (8.3% or more)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	6	Quantity:	SF
Description:	Gutter slope exceeds 5.0% (8.3% or more)		
As Built Desc:	8.3% gutter slope		
Solution:	Demolish existing and construct new gutter		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6734
Location:	Copperwood Dr - North				
X Coordinate:	-121.26287				
Y Coordinate:	38.69582				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	75	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$9,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6735
Location:	Copperwood Dr - South				
X Coordinate:	-121.26271				
Y Coordinate:	38.69569				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	279	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$34,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6736A
Location:	Copperwood Dr and Cammeray Dr - Corner C				
X Coordinate:	-121.26368				
Y Coordinate:	38.69564				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)		
As Built Desc:	3.9% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C,D		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6736B
Location:	Copperwood Dr and Cammeray Dr - Corner C				
X Coordinate:	-121.26368				
Y Coordinate:	38.69564				
Barrier Area:	Curb Ramps				
Barrier Type:	Cross Slope - New Construction				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	1	Quantity:	EACH
Description:	Ramp run cross slope exceeds 2.0%		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C,D		

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6736C

Location: Copperwood Dr and Cammeray Dr - Corner C

X Coordinate: -121.26368

Y Coordinate: 38.69564

Barrier Area: Curb Ramps

Barrier Type: Detectable Warnings - Truncated Domes

Code Ref: CBC 1127B.5.7 and ADA/ABA 705.1.3



As Built Meas: 1 Quantity: EACH

Description: No truncated domes provided at curb ramp

As Built Desc: No detectable warnings at curb ramp

Solution: Provide compliant truncated domes

Bar. Severity: 2 Recommended Cost Estimate: \$0.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners C,D

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6736D

Location: Copperwood Dr and Cammeray Dr - Corner C

X Coordinate: -121.26368

Y Coordinate: 38.69564

Barrier Area: Curb Ramps

Barrier Type: Gutter Slope - Existing (6.6% to 8.2%)

Code Ref: CBC 1127B.5.3 and ADA/ABA 406.2



As Built Meas: 6 Quantity: SF

Description: Gutter slope exceeds 5.0% (6.6% to 8.2%)

As Built Desc: 7.5% gutter slope

Solution: Demolish existing and construct new gutter

Bar. Severity: 2 Recommended Cost Estimate: \$0.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners C,D

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6737A
Location:	Copperwood Dr and Cammeray Dr - Corner D				
X Coordinate:	-121.26378				
Y Coordinate:	38.69563				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (>5.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (>5.0%)		
As Built Desc:	6.8% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C,D		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6737B
Location:	Copperwood Dr and Cammeray Dr - Corner D				
X Coordinate:	-121.26378				
Y Coordinate:	38.69563				
Barrier Area:	Curb Ramps				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	1	Quantity:	EACH
Description:	Ramp run cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.4% cross slope		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C,D		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6737C
Location:	Copperwood Dr and Cammeray Dr - Corner D				
X Coordinate:	-121.26378				
Y Coordinate:	38.69563				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C,D		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6737D
Location:	Copperwood Dr and Cammeray Dr - Corner D				
X Coordinate:	-121.26378				
Y Coordinate:	38.69563				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (6.6% to 8.2%)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	6	Quantity:	SF
Description:	Gutter slope exceeds 5.0% (6.6% to 8.2%)		
As Built Desc:	8.2% gutter slope		
Solution:	Demolish existing and construct new gutter		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C,D		

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6738

Location: Cammeray Dr - East

X Coordinate: -121.26368

Y Coordinate: 38.69553

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 147 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.1% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$18,375.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6739

Location: Poulson St - North

X Coordinate: -121.26368

Y Coordinate: 38.69519

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 101 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.4% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$12,625.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6740
Location:	Poulson St - East				
X Coordinate:	-121.26289				
Y Coordinate:	38.69487				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	373	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$46,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6741
Location:	Poulson St - South				
X Coordinate:	-121.26314				
Y Coordinate:	38.69374				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	398	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$49,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6742

Location: Poulson St - South

X Coordinate: -121.26517

Y Coordinate: 38.69349

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 190 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.3% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hindrance Cost Estimate: \$23,750.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6743A

Location: Hoopes Dr and Baugh Ct - Corner A

X Coordinate: -121.26581

Y Coordinate: 38.69499

Barrier Area: Curb Ramps

Barrier Type: 12" Grooves - Existing (3.1% to 4.0%)

Code Ref: CBC 1127B.5.6



As Built Meas: 1 Quantity: EACH

Description: 12" grooves at top of curb ramp are not level (3.1% to 4.0%)

As Built Desc: 3.1% at 12" grooves

Solution: Demolish existing and construct new curb ramp

Bar. Severity: 3 Hindrance Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Four - way intersection corners A,B,C,D. Corner D compliant

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6743B
Location:	Hoopes Dr and Baugh Ct - Corner A				
X Coordinate:	-121.26581				
Y Coordinate:	38.69499				
Barrier Area:	Curb Ramps				
Barrier Type:	Parallel Ramp Landing - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1127B.5.4 and ADA/ABA 406.4				



As Built Meas:	1	Quantity:	EACH
Description:	Curb ramp landing or pan not level (2.1% to 3.0%)		
As Built Desc:	3.0% landing slope		
Solution:	Demolish existing and construct new transition		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Four - way intersection corners A,B,C,D. Corner D compliant

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6744A
Location:	Hoopes Dr and Baugh Ct - Corner B				
X Coordinate:	-121.26571				
Y Coordinate:	38.69499				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)		
As Built Desc:	3.6% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Four - way intersection corners A,B,C,D. Corner D compliant

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6744B

Location: Hoopes Dr and Baugh Ct - Corner B

X Coordinate: -121.26571

Y Coordinate: 38.69499

Barrier Area: Curb Ramps

Barrier Type: 12" Grooves - Existing (3.1% to 4.0%)

Code Ref: CBC 1127B.5.6



As Built Meas: 1 Quantity: EACH

Description: 12" grooves at top of curb ramp are not level (3.1% to 4.0%)

As Built Desc: 3.7% at 12" grooves

Solution: Demolish existing and construct new curb ramp

Bar. Severity: 3 Hindrance Cost Estimate: \$0.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Four - way intersection corners A,B,C,D. Corner D compliant

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6745A

Location: Poulson St and Hoopes Dr - Corner C

X Coordinate: -121.26569

Y Coordinate: 38.69487

Barrier Area: Curb Ramps

Barrier Type: 12" Grooves - Existing (3.1% to 4.0%)

Code Ref: CBC 1127B.5.6



As Built Meas: 1 Quantity: EACH

Description: 12" grooves at top of curb ramp are not level (3.1% to 4.0%)

As Built Desc: 3.1% at 12" grooves

Solution: Demolish existing and construct new curb ramp

Bar. Severity: 3 Hindrance Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Four - way intersection corners A,B,C,D. Corner D compliant

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6745B

Location: Poulson St and Hoopes Dr - Corner C

X Coordinate: -121.26569

Y Coordinate: 38.69487

Barrier Area: Curb Ramps

Barrier Type: Parallel Ramp Landing - Existing (3.1% to 4.0%)

Code Ref: CBC 1127B.5.4 and ADA/ABA 406.4



As Built Meas: 1 Quantity: EACH

Description: Curb ramp landing or pan not level (3.1% to 4.0%)

As Built Desc: 3.1% landing slope

Solution: Demolish existing and construct new transition

Bar. Severity: 3 Hindrance Cost Estimate: \$0.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Four - way intersection corners A,B,C,D. Corner D compliant

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6746

Location: Poulson St - East

X Coordinate: -121.2657

Y Coordinate: 38.69483

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 189 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.5% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$23,625.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6747
Location:	Poulson St - East				
X Coordinate:	-121.26565				
Y Coordinate:	38.69409				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	214	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$26,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6748
Location:	Poulson St - North				
X Coordinate:	-121.26561				
Y Coordinate:	38.69355				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	565	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$70,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6749
Location:	Poulson St - West				
X Coordinate:	-121.26301				
Y Coordinate:	38.69392				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	351	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$43,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6750
Location:	Poulson St - South				
X Coordinate:	-121.26316				
Y Coordinate:	38.69495				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	181	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$22,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6751
Location:	Cammeray Dr - East				
X Coordinate:	-121.26378				
Y Coordinate:	38.69504				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	1511	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$188,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6752A
Location:	Cammeray Dr and Cammeray Dr Ct - Corner B				
X Coordinate:	-121.26408				
Y Coordinate:	38.69471				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (4.1% to 4.9%)		
As Built Desc:	4.8% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6752B
Location:	Cammeray Dr and Cammeray Dr Ct - Corner B				
X Coordinate:	-121.26408				
Y Coordinate:	38.69471				
Barrier Area:	Curb Ramps				
Barrier Type:	Parallel Ramp Landing - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.4 and ADA/ABA 406.4				



As Built Meas:	1	Quantity:	EACH
Description:	Curb ramp landing or pan not level (3.1% to 4.0%)		
As Built Desc:	3.6% landing slope		
Solution:	Demolish existing and construct new transition		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners B,C

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6753
Location:	Cammeray Dr and Cammeray Dr Ct - Corner C				
X Coordinate:	-121.26418				
Y Coordinate:	38.69464				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)		
As Built Desc:	3.1% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners B,C

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6754

Location: Cammeray Dr - North

X Coordinate: -121.26551

Y Coordinate: 38.69429

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 253 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.3% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hindrance Cost Estimate: \$31,625.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6755

Location: Cammeray Dr - West

X Coordinate: -121.26461

Y Coordinate: 38.69448

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 480 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.5% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hindrance Cost Estimate: \$60,000.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6756
Location:	Cammeray Dr - South				
X Coordinate:	-121.26386				
Y Coordinate:	38.69563				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	194	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$24,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6757A
Location:	Copperwood Dr and Hoopes Dr - Corner C				
X Coordinate:	-121.26456				
Y Coordinate:	38.69559				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)		
As Built Desc:	3.5% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners C,D
--------	------------------------------------

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6757B
Location:	Copperwood Dr and Hoopes Dr - Corner C				
X Coordinate:	-121.26456				
Y Coordinate:	38.69559				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C,D		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6757C
Location:	Copperwood Dr and Hoopes Dr - Corner C				
X Coordinate:	-121.26456				
Y Coordinate:	38.69559				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (8.3% or more)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	6	Quantity:	SF
Description:	Gutter slope exceeds 5.0% (8.3% or more)		
As Built Desc:	11.5% gutter slope		
Solution:	Demolish existing and construct new gutter		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C,D		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6758A
Location:	Copperwood Dr and Hoopes Dr - Corner D				
X Coordinate:	-121.26472				
Y Coordinate:	38.69563				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (4.1% to 4.9%)		
As Built Desc:	4.2% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C,D		

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6758B
Location:	Copperwood Dr and Hoopes Dr - Corner D				
X Coordinate:	-121.26472				
Y Coordinate:	38.69563				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C,D		

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6758C

Location: Copperwood Dr and Hoopes Dr - Corner D

X Coordinate: -121.26472

Y Coordinate: 38.69563

Barrier Area: Curb Ramps

Barrier Type: Gutter Slope - Existing (6.6% to 8.2%)

Code Ref: CBC 1127B.5.3 and ADA/ABA 406.2



As Built Meas: 6 Quantity: SF

Description: Gutter slope exceeds 5.0% (6.6% to 8.2%)

As Built Desc: 7.9% gutter slope

Solution: Demolish existing and construct new gutter

Bar. Severity: 2 Recommended

Cost Estimate: \$0.00

Status:

Implementation Priority: 4

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes: Two - way intersection corners C,D

Field Date: 4/11/2011 Report Date: 4/11/2011 Barrier #: 6759

Location: Copperwood Dr - South

X Coordinate: -121.26475

Y Coordinate: 38.69566

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 1057 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.6% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended

Cost Estimate: \$132,125.00

Status:

Implementation Priority: 4

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes:

Field Date:	4/11/2011	Report Date:	4/11/2011	Barrier #:	6760
Location:	Copperwood Dr - South				
X Coordinate:	-121.26863				
Y Coordinate:	38.69631				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	195	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$24,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6761
Location:	Canelo Hills Dr - East				
X Coordinate:	-121.2692				
Y Coordinate:	38.69622				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	161	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$20,125.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6762
Location:	Canelo Hills Dr and Sundgarden Dr - Corner A				
X Coordinate:	-121.2693				
Y Coordinate:	38.69576				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.9% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6763A
Location:	Canelo Hills Dr and Sundgarden Dr - Corner B				
X Coordinate:	-121.26908				
Y Coordinate:	38.69574				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Three - way intersection corners A, B, C
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6763B
Location:	Canelo Hills Dr and Sundgarden Dr - Corner B				
X Coordinate:	-121.26908				
Y Coordinate:	38.69574				
Barrier Area:	Curb Ramps				
Barrier Type:	Clear Width				
Code Ref:	CBC 1127B.5.2				



As Built Meas:	1	Quantity:	LF
Description:	Curb ramp not at least 48" wide		
As Built Desc:	24" due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Three - way intersection corners A, B, C		

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6764
Location:	Canelo Hills Dr and Sundgarden Dr - Corner C				
X Coordinate:	-121.26919				
Y Coordinate:	38.69566				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Three - way intersection corners A, B, C		

Field Date: 4/12/2011 Report Date: 4/12/2011 Barrier #: 6765

Location: Canelo Hills Dr - East

X Coordinate: -121.26903

Y Coordinate: 38.69564

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 374 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.2% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$46,750.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/12/2011 Report Date: 4/12/2011 Barrier #: 6766A

Location: Canelo Hills Dr and Hoopes Dr - Corner B

X Coordinate: -121.26853

Y Coordinate: 38.69471

Barrier Area: Curb Ramps

Barrier Type: 12" Grooves - Existing (>5.0%)

Code Ref: CBC 1127B.5.6



As Built Meas: 1 Quantity: EACH

Description: 12" grooves at top of curb ramp are not level (>5.0%)

As Built Desc: 5.3% at 12" grooves

Solution: Demolish existing and construct new curb ramp

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6766B
Location:	Canelo Hills Dr and Hoopes Dr - Corner B				
X Coordinate:	-121.26853				
Y Coordinate:	38.69471				
Barrier Area:	Curb Ramps				
Barrier Type:	Parallel Ramp Landing - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1127B.5.4 and ADA/ABA 406.4				



As Built Meas:	1	Quantity:	EACH
Description:	Curb ramp landing or pan not level(4.1% to 4.9%)		
As Built Desc:	4.6% landing slope		
Solution:	Demolish existing and construct new transition		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6766C
Location:	Canelo Hills Dr and Hoopes Dr - Corner B				
X Coordinate:	-121.26853				
Y Coordinate:	38.69471				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				




As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6767A
Location:	Canelo Hills Dr and Hoopes Dr - Corner C				
X Coordinate:	-121.26851				
Y Coordinate:	38.6946				
Barrier Area:	Curb Ramps				
Barrier Type:	Parallel Ramp Landing - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1127B.5.4 and ADA/ABA 406.4				



As Built Meas:	1	Quantity:	EACH
Description:	Curb ramp landing or pan not level (2.1% to 3.0%)		
As Built Desc:	3.0% landing slope		
Solution:	Demolish existing and construct new transition		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$250.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6767B
Location:	Canelo Hills Dr and Hoopes Dr - Corner C				
X Coordinate:	-121.26851				
Y Coordinate:	38.6946				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6768A
Location:	Hoopes Dr - North				
X Coordinate:	-121.26847				
Y Coordinate:	38.69473				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	183	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$22,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6768B
Location:	Hoopes Dr - North				
X Coordinate:	-121.268				
Y Coordinate:	38.69478				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6769
Location:	Camel Rock Wy - West				
X Coordinate:	-121.26794				
Y Coordinate:	38.69486				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	554	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$69,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6770
Location:	Camel Rock Wy - West				
X Coordinate:	-121.26799				
Y Coordinate:	38.69513				
Barrier Area:	Sidewalks				
Barrier Type:	Protruding Hazard				
Code Ref:	CBC 1133B.8.6.1 and ADA/ABA 307.2				



As Built Meas:	1	Quantity:	JOB
Description:	Protruding object in route of travel between 27" and 80" high		
As Built Desc:	31" at tree branch		
Solution:	Remove object or provide detectable warning		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,400.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 4/12/2011 Report Date: 4/12/2011 Barrier #: 6771

Location: Camel Rock Wy - East

X Coordinate: -121.26831

Y Coordinate: 38.69623

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 283 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.4% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hindrance Cost Estimate: \$35,375.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/12/2011 Report Date: 4/12/2011 Barrier #: 6772

Location: Camel Rock Wy and Cranmore Ct - Corner B

X Coordinate: -121.26798

Y Coordinate: 38.69555

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 8.1% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners B,C

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6773
Location:	Camel Rock Wy and Cranmore Ct - Corner C				
X Coordinate:	-121.26792				
Y Coordinate:	38.69544				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	12.5% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6774
Location:	Cranmore Ct - North				
X Coordinate:	-121.2679				
Y Coordinate:	38.69554				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	339	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$42,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6775A
Location:	Cranmore Ct - South				
X Coordinate:	-121.26683				
Y Coordinate:	38.69566				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	3530	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$441,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6775B
Location:	Cranmore Ct - South				
X Coordinate:	-121.26683				
Y Coordinate:	38.69564				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6776A
Location:	Camel Rock Wy - East				
X Coordinate:	-121.26789				
Y Coordinate:	38.69533				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	164	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$20,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6776B
Location:	Camel Rock Wy - East				
X Coordinate:	-121.26778				
Y Coordinate:	38.69503				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6777
Location:	Hoopes Dr - North				
X Coordinate:	-121.26763				
Y Coordinate:	38.69484				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	512	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$64,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6778
Location:	Baugh Ct - West				
X Coordinate:	-121.26586				
Y Coordinate:	38.69505				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	222	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$27,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 4/12/2011 Report Date: 4/12/2011 Barrier #: 6779

Location: Baugh Ct - East

X Coordinate: -121.26596

Y Coordinate: 38.69551

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 234 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.3% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$29,250.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/12/2011 Report Date: 4/12/2011 Barrier #: 6780

Location: Hoopes Dr - West

X Coordinate: -121.26561

Y Coordinate: 38.69503

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 359 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.5% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$44,875.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6781
Location:	Hoopes Dr - East				
X Coordinate:	-121.2646				
Y Coordinate:	38.69554				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	423	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$52,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6782
Location:	Hoopes Dr - South				
X Coordinate:	-121.26622				
Y Coordinate:	38.69487				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	111	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$13,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 4/12/2011 Report Date: 4/12/2011 Barrier #: 6783

Location: Hoopes Dr - South

X Coordinate: -121.26692

Y Coordinate: 38.69485

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 492 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.5% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended

Cost Estimate: \$61,500.00

Status:

Implementation Priority: 4

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes:

Field Date: 4/12/2011 Report Date: 4/12/2011 Barrier #: 6784A

Location: Canelo Hills Dr - East

X Coordinate: -121.26851

Y Coordinate: 38.6945

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 373 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 4.5% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hindrance

Cost Estimate: \$46,625.00

Status:

Implementation Priority: 3

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes:

Field Date: 4/12/2011 Report Date: 4/12/2011 Barrier #: 6784B

Location: Canelo Hills Dr - East

X Coordinate: -121.26847

Y Coordinate: 38.69353

Barrier Area: Sidewalks

Barrier Type: Elbow in Sidewalk - Cross Slope (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 1 Quantity: LF

Description: Cross slope at elbow exceeds 2.0% (5.0% or more)

As Built Desc: 11.1% cross slope

Solution: Demolish existing and construct new sidewalk without curb ramp

Bar. Severity: 1 Necessary Cost Estimate: \$750.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/12/2011 Report Date: 4/12/2011 Barrier #: 6785A

Location: Canelo Hills Dr - North

X Coordinate: -121.26842

Y Coordinate: 38.69352

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 223 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.8% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$27,875.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6785B
Location:	Canelo Hills Dr - North				
X Coordinate:	-121.26798				
Y Coordinate:	38.6935				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6786A
Location:	Canelo Hills Dr and Hershberger Ct - Corner A				
X Coordinate:	-121.26768				
Y Coordinate:	38.69353				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (4.1% to 4.9%)		
As Built Desc:	4.2% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,B
--------	------------------------------------

Field Date: 4/12/2011 Report Date: 4/12/2011 Barrier #: 6786B

Location: Canelo Hills Dr and Hershberger Ct - Corner A

X Coordinate: -121.26768

Y Coordinate: 38.69353

Barrier Area: Curb Ramps

Barrier Type: Parallel Ramp Landing - Existing (>5.0% or more)

Code Ref: CBC 1127B.5.4 and ADA/ABA 406.4



As Built Meas: 1 Quantity: EACH

Description: Curb ramp landing or pan not level (>5.0% or more)

As Built Desc: 5.0% landing slope

Solution: Demolish existing and construct new transition

Bar. Severity: 1 Necessary Cost Estimate: \$0.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A,B

Field Date: 4/12/2011 Report Date: 4/12/2011 Barrier #: 6786C

Location: Canelo Hills Dr and Hershberger Ct - Corner A

X Coordinate: -121.26768

Y Coordinate: 38.69353

Barrier Area: Curb Ramps

Barrier Type: Detectable Warnings - Truncated Domes

Code Ref: CBC 1127B.5.7 and ADA/ABA 705.1.3



As Built Meas: 1 Quantity: EACH

Description: No truncated domes provided at curb ramp

As Built Desc: No detectable warnings at curb ramp

Solution: Provide compliant truncated domes

Bar. Severity: 2 Recommended Cost Estimate: \$0.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A,B

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6787A
Location:	Canelo Hills Dr and Hershberger Ct - Corner B				
X Coordinate:	-121.26752				
Y Coordinate:	38.69355				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)		
As Built Desc:	3.9% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6787B
Location:	Canelo Hills Dr and Hershberger Ct - Corner B				
X Coordinate:	-121.26752				
Y Coordinate:	38.69355				
Barrier Area:	Curb Ramps				
Barrier Type:	Parallel Ramp Landing - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.4 and ADA/ABA 406.4				



As Built Meas:	1	Quantity:	EACH
Description:	Curb ramp landing or pan not level (3.1% to 4.0%)		
As Built Desc:	3.9% landing slope		
Solution:	Demolish existing and construct new transition		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$0.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date: 4/12/2011 Report Date: 4/12/2011 Barrier #: 6787C

Location: Canelo Hills Dr and Hershberger Ct - Corner B

X Coordinate: -121.26752

Y Coordinate: 38.69355

Barrier Area: Curb Ramps

Barrier Type: Detectable Warnings - Truncated Domes

Code Ref: CBC 1127B.5.7 and ADA/ABA 705.1.3



As Built Meas: 1 Quantity: EACH

Description: No truncated domes provided at curb ramp

As Built Desc: No detectable warnings at curb ramp

Solution: Provide compliant truncated domes

Bar. Severity: 2 Recommended

Cost Estimate: \$0.00

Status:

Implementation Priority: 3

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A,B

Field Date: 4/12/2011 Report Date: 4/12/2011 Barrier #: 6788

Location: Hershberger Ct -West

X Coordinate: -121.26771

Y Coordinate: 38.69359

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 253 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.8% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hindrance

Cost Estimate: \$31,625.00

Status:

Implementation Priority: 4

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes:

Field Date: 4/12/2011 Report Date: 4/12/2011 Barrier #: 6789

Location: Hershberger Ct -East

X Coordinate: -121.26757

Y Coordinate: 38.69416

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 253 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.7% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hindrance Cost Estimate: \$31,625.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/12/2011 Report Date: 4/12/2011 Barrier #: 6790A

Location: Canelo Hills Dr - North

X Coordinate: -121.26743

Y Coordinate: 38.69352

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 203 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.5% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$25,375.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6790B
Location:	Canelo Hills Dr - North				
X Coordinate:	-121.26672				
Y Coordinate:	38.69356				
Barrier Area:	Sidewalks				
Barrier Type:	Elbow in Sidewalk - Cross Slope (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	6	Quantity:	LF
Description:	Cross slope at elbow exceeds 2.0% (5.0% or more)		
As Built Desc:	12.8% cross slope		
Solution:	Demolish existing and construct new sidewalk without curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$750.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6791
Location:	Canelo Hills Dr - West				
X Coordinate:	-121.26671				
Y Coordinate:	38.69362				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	451	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$56,375.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6792
Location:	Canelo Hills Dr - East				
X Coordinate:	-121.26663				
Y Coordinate:	38.69478				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	514	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$64,250.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6793
Location:	Canelo Hills Dr - South				
X Coordinate:	-121.26667				
Y Coordinate:	38.69342				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	598	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$74,750.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 4/12/2011 Report Date: 4/12/2011 Barrier #: 6794

Location: Canelo Hills Dr - West

X Coordinate: -121.26869

Y Coordinate: 38.69353

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 816 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.7% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$102,000.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/12/2011 Report Date: 4/12/2011 Barrier #: 6795

Location: Sungarden Dr and Crux Dr - Corner C

X Coordinate: -121.26946

Y Coordinate: 38.69562

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 8.3% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners C,D

Field Date: 4/12/2011 Report Date: 4/12/2011 Barrier #: 6796

Location: Sungarden Dr and Crux Dr - Corner D

X Coordinate: -121.26972

Y Coordinate: 38.69553

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 10.8% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners C,D

Field Date: 4/12/2011 Report Date: 4/12/2011 Barrier #: 6797

Location: Crux Dr - West

X Coordinate: -121.2696

Y Coordinate: 38.69534

Barrier Area: Sidewalks

Barrier Type: Driveway - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 40 Quantity: LF

Description: Driveway cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 7.6% cross slope

Solution: Provide min. 48" wide level walkway through driveway

Bar. Severity: 4 Low Severity Cost Estimate: \$5,000.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6798
Location:	Crux Dr - West				
X Coordinate:	-121.26945				
Y Coordinate:	38.695				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	101	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$12,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6799
Location:	Crux Dr - West				
X Coordinate:	-121.26933				
Y Coordinate:	38.69473				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	44	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	8.8% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$5,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6800
Location:	Crux Dr - West				
X Coordinate:	-121.26921				
Y Coordinate:	38.69436				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	181	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$22,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6801
Location:	Crux Dr - West				
X Coordinate:	-121.26919				
Y Coordinate:	38.69384				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	43	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	7.2% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$5,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6802
Location:	Crux Dr - West				
X Coordinate:	-121.2692				
Y Coordinate:	38.69373				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	513	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$64,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6803
Location:	Crux Dr - West				
X Coordinate:	-121.26917				
Y Coordinate:	38.6923				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	44	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.3% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$5,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6804
Location:	Crux Dr - West				
X Coordinate:	-121.26919				
Y Coordinate:	38.69225				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	56	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$7,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6805A
Location:	Crux Dr - East				
X Coordinate:	-121.26898				
Y Coordinate:	38.69215				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	337	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$42,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6805B
Location:	Crux Dr - East				
X Coordinate:	-121.26898				
Y Coordinate:	38.69302				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB
Description:	No barricade provided where sidewalk ends in hazardous location		
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk		
Solution:	Provide barricade with cane detectable warning at end of sidewalk		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6806
Location:	Crux Dr - East				
X Coordinate:	-121.26897				
Y Coordinate:	38.6931				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	926	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$92,600.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date: 4/12/2011 Report Date: 4/12/2011 Barrier #: 6807

Location: Sungarden Dr - South

X Coordinate: -121.26979

Y Coordinate: 38.69552

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 283 Quantity: LF

Description: Cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 5.3% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 1 Necessary Cost Estimate: \$35,375.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/12/2011 Report Date: 4/12/2011 Barrier #: 6808

Location: Sungarden Dr - South

X Coordinate: -121.27075

Y Coordinate: 38.69537

Barrier Area: Sidewalks

Barrier Type: Driveway - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 40 Quantity: LF

Description: Driveway cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 7.3% cross slope

Solution: Provide min. 48" wide level walkway through driveway

Bar. Severity: 4 Low Severity Cost Estimate: \$5,000.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6809
Location:	Sungarden Dr - South				
X Coordinate:	-121.27083				
Y Coordinate:	38.69534				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	71	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$8,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6810
Location:	Sungarden Dr - South				
X Coordinate:	-121.27113				
Y Coordinate:	38.69536				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	38	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.5% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$4,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6811
Location:	Sungarden Dr - South				
X Coordinate:	-121.27122				
Y Coordinate:	38.69537				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	90	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$11,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6812
Location:	Sungarden Dr - North				
X Coordinate:	-121.27158				
Y Coordinate:	38.69547				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	162	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$20,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 4/12/2011 Report Date: 4/12/2011 Barrier #: 6813

Location: Sungarden Dr - North

X Coordinate: -121.2715

Y Coordinate: 38.69547

Barrier Area: Sidewalks

Barrier Type: Clear Width - Existing ($\leq 31"$ or less)

Code Ref: CBC 1133B.7.1



As Built Meas: 1 Quantity: LF

Description: Pedestrian route is not min. 48" wide ($\leq 31"$ or less)

As Built Desc: 24" clear width due to foliage

Solution: Trim foliage to provide min. 48" clear width

Bar. Severity: 1 Necessary Cost Estimate: \$125.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/12/2011 Report Date: 4/12/2011 Barrier #: 6814

Location: Sungarden Dr - North

X Coordinate: -121.27087

Y Coordinate: 38.69549

Barrier Area: Sidewalks

Barrier Type: Driveway - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 38 Quantity: LF

Description: Driveway cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 6.2% cross slope

Solution: Provide min. 48" wide level walkway through driveway

Bar. Severity: 4 Low Severity Cost Estimate: \$4,750.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6815
Location:	Sungarden Dr - North				
X Coordinate:	-121.2708				
Y Coordinate:	38.69549				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	103	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$12,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6816
Location:	Sungarden Dr - North				
X Coordinate:	-121.27069				
Y Coordinate:	38.69546				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6817A
Location:	Sungarden Dr and Crail Ct - Corner A				
X Coordinate:	-121.27044				
Y Coordinate:	38.69553				
Barrier Area:	Curb Ramps				
Barrier Type:	Perpendicular Ramp Landing (4.1% to 4.9%)				
Code Ref:	CBC 1127B.5.4 and ADA/ABA 406.4				



As Built Meas:	1	Quantity:	EACH
Description:	Curb ramp top landing not level (4.1% to 4.9%)		
As Built Desc:	4.2% landing slope		
Solution:	Demolish existing and construct new transition		
Bar. Severity:	1 Necessary	Cost Estimate:	\$250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6817B
Location:	Sungarden Dr and Crail Ct - Corner A				
X Coordinate:	-121.27044				
Y Coordinate:	38.69553				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6817C
Location:	Sungarden Dr and Crail Ct - Corner A				
X Coordinate:	-121.27044				
Y Coordinate:	38.69553				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (8.3% or more)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	6	Quantity:	SF
Description:	Gutter slope exceeds 5.0% (8.3% or more)		
As Built Desc:	8.7% gutter slope		
Solution:	Demolish existing and construct new gutter		
Bar. Severity:	1 Necessary	Cost Estimate:	\$750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6818A
Location:	Sungarden Dr and Crail Ct - Corner B				
X Coordinate:	-121.27024				
Y Coordinate:	38.69553				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)		
As Built Desc:	3.3% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6818B
Location:	Sungarden Dr and Crail Ct - Corner B				
X Coordinate:	-121.27024				
Y Coordinate:	38.69553				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,B
--------	------------------------------------

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6818C
Location:	Sungarden Dr and Crail Ct - Corner B				
X Coordinate:	-121.27024				
Y Coordinate:	38.69553				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (6.6% to 8.2%)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	1	Quantity:	SF
Description:	Gutter slope exceeds 5.0% (6.6% to 8.2%)		
As Built Desc:	7.3% gutter slope		
Solution:	Demolish existing and construct new gutter		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,B
--------	------------------------------------

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6819
Location:	Crail Ct - West				
X Coordinate:	-121.27044				
Y Coordinate:	38.69561				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	356	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$44,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6820
Location:	Crail Ct - East				
X Coordinate:	-121.27022				
Y Coordinate:	38.69626				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	346	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	7.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$43,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6821A
Location:	Sungarden Dr - North				
X Coordinate:	-121.27004				
Y Coordinate:	38.69559				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	257	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$32,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6821B
Location:	Sungarden Dr - North				
X Coordinate:	-121.26993				
Y Coordinate:	38.69561				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6822A
Location:	Canelo Hills Dr - West				
X Coordinate:	-121.26932				
Y Coordinate:	38.69585				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	344	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$43,000.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6822B
Location:	Canelo Hills Dr - West				
X Coordinate:	-121.26947				
Y Coordinate:	38.69675				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB
Description:	No barricade provided where sidewalk ends in hazardous location		
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk		
Solution:	Provide barricade with cane detectable warning at end of sidewalk		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6823
Location:	Canelo Hills Dr - West				
X Coordinate:	-121.26945				
Y Coordinate:	38.69676				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	219	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$21,900.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6824
Location:	Canelo Hills Dr - West				
X Coordinate:	-121.26945				
Y Coordinate:	38.69737				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB
Description:	No barricade provided where sidewalk ends in hazardous location		
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk		
Solution:	Provide barricade with cane detectable warning at end of sidewalk		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6825
Location:	Canelo Hills Dr - West				
X Coordinate:	-121.26944				
Y Coordinate:	38.69735				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway Running Slope - Existing (9.5% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	4	Quantity:	LF
Description:	Running slope exceeds 8.3% (9.5% or more)		
As Built Desc:	11.4% running slope		
Solution:	Demolish existing and construct new pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6826
Location:	Canelo Hills Dr - West				
X Coordinate:	-121.26945				
Y Coordinate:	38.69745				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	38	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.3% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	2 Recommended	Cost Estimate:	\$4,750.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date: 4/12/2011 Report Date: 4/12/2011 Barrier #: 6827

Location: Canelo Hills Dr - West

X Coordinate: -121.26945

Y Coordinate: 38.69747

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 137 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.5% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hindrance Cost Estimate: \$17,125.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/12/2011 Report Date: 4/12/2011 Barrier #: 6828

Location: Canelo Hills Dr - West

X Coordinate: -121.26947

Y Coordinate: 38.69788

Barrier Area: Sidewalks

Barrier Type: Driveway - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 46 Quantity: LF

Description: Driveway cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.1% cross slope

Solution: Provide min. 48" wide level walkway through driveway

Bar. Severity: 2 Recommended Cost Estimate: \$5,750.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6829
Location:	Canelo Hills Dr - West				
X Coordinate:	-121.2695				
Y Coordinate:	38.69838				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway Running Slope - Existing (8.34% to 8.5%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	5	Quantity:	LF
Description:	Running slope exceeds 8.3% (8.34% to 8.5%)		
As Built Desc:	8.4% running slope		
Solution:	Low severity barrier - no remediation recommended		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6830
Location:	Canelo Hills Dr - West				
X Coordinate:	-121.26948				
Y Coordinate:	38.69849				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	44	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.7% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	2 Recommended	Cost Estimate:	\$5,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6831
Location:	Canelo Hills Dr - West				
X Coordinate:	-121.26949				
Y Coordinate:	38.69875				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	44	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$5,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6832
Location:	Canelo Hills Dr and Elementary School Entrance - Corner A				
X Coordinate:	-121.26947				
Y Coordinate:	38.69946				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,B
--------	------------------------------------

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6833
Location:	Canelo Hills Dr and Elementary School Entrance - Corner B				
X Coordinate:	-121.26922				
Y Coordinate:	38.69944				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	4/12/2011	Report Date:	4/12/2011	Barrier #:	6834
Location:	Canelo Hills Dr - West				
X Coordinate:	-121.26948				
Y Coordinate:	38.69995				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	118	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$14,750.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6835
Location:	Woodmore Oaks Dr - North				
X Coordinate:	-121.2714				
Y Coordinate:	38.6922				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	107	Quantity:	LF
Description:	Cross slope exceeds 2.0% (2.1% to 3.0%)		
As Built Desc:	2.7% cross slope		
Solution:	Low severity barrier - no remediation recommended		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6836
Location:	Woodmore Oaks Dr - North				
X Coordinate:	-121.27097				
Y Coordinate:	38.69219				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	40	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.5% cross slope 11.1% running slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	1 Necessary	Cost Estimate:	\$5,000.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 4/14/2011 Report Date: 4/14/2011 Barrier #: 6837

Location: Woodmore Oaks Dr - North

X Coordinate: -121.27032

Y Coordinate: 38.69208

Barrier Area: Sidewalks

Barrier Type: Driveway -12" Grooves Incorrect Application

Code Ref: CBC 1127B.5.6



As Built Meas: 1 Quantity: JOB

Description: 12" grooves required only at curb ramps identified at transition into driveway

As Built Desc: 12" grooves incorrectly provided where no curb ramp exists

Solution: No remediation recommended, until new construction is performed in area

Bar. Severity: 4 Low Severity Cost Estimate: \$0.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/14/2011 Report Date: 4/14/2011 Barrier #: 6838

Location: Woodmore Oaks Dr - North

X Coordinate: -121.27019

Y Coordinate: 38.69205

Barrier Area: Sidewalks

Barrier Type: Driveway -12" Grooves Incorrect Application

Code Ref: CBC 1127B.5.6



As Built Meas: 1 Quantity: JOB

Description: 12" grooves required only at curb ramps identified at transition into driveway

As Built Desc: 12" grooves incorrectly provided where no curb ramp exists

Solution: No remediation recommended, until new construction is performed in area

Bar. Severity: 4 Low Severity Cost Estimate: \$0.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6839
Location:	Woodmore Oaks Dr - North				
X Coordinate:	-121.26939				
Y Coordinate:	38.69204				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	252	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$31,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6840
Location:	Woodmore Oaks Dr - North				
X Coordinate:	-121.26917				
Y Coordinate:	38.69203				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6841
Location:	Woodmore Oaks Dr and Crux Dr - Corner A				
X Coordinate:	-121.26892				
Y Coordinate:	38.69203				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	8.5% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D. Corners C,D compliant		

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6842
Location:	Woodmore Oaks Dr and Crux Dr - Corner B				
X Coordinate:	-121.26874				
Y Coordinate:	38.69207				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	6.7% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D. Corners C,D compliant		

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6843
Location:	Woodmore Oaks Dr - North				
X Coordinate:	-121.26808				
Y Coordinate:	38.69206				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	124	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$15,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6844
Location:	Woodmore Oaks Dr and Stone Canyon Cir - B				
X Coordinate:	-121.26449				
Y Coordinate:	38.69249				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (4.1% to 4.9%)		
As Built Desc:	4.5% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,B. Corner A compliant
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6845A
Location:	Stone Canyon Cir - East				
X Coordinate:	-121.26448				
Y Coordinate:	38.69242				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	104	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$13,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6845B
Location:	Stone Canyon Cir - East				
X Coordinate:	-121.2645				
Y Coordinate:	38.69233				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6845C
Location:	Stone Canyon Cir - East				
X Coordinate:	-121.26463				
Y Coordinate:	38.69212				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	6" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6846A
Location:	Woodmore Oaks Dr and Stone Canyon Cir - B				
X Coordinate:	-121.26447				
Y Coordinate:	38.69212				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (4.1% to 4.9%)		
As Built Desc:	4.6% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D. Corner A compliant		

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6846B
Location:	Woodmore Oaks Dr and Stone Canyon Cir - B				
X Coordinate:	-121.26447				
Y Coordinate:	38.69212				
Barrier Area:	Curb Ramps				
Barrier Type:	Parallel Ramp Landing - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1127B.5.4 and ADA/ABA 406.4				



As Built Meas:	1	Quantity:	EACH
Description:	Curb ramp landing or pan not level(4.1% to 4.9%)		
As Built Desc:	4.4% landing slope		
Solution:	Demolish existing and construct new transition		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D. Corner A compliant		

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6847
Location:	Woodmore Oaks Dr and Stone Canyon Cir - C				
X Coordinate:	-121.26445				
Y Coordinate:	38.69195				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D. Corner A compliant		

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6848
Location:	Woodmore Oaks Dr and Stone Canyon Cir - D				
X Coordinate:	-121.26465				
Y Coordinate:	38.69196				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D. Corner A compliant		

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6849
Location:	Stone Canyon Cir - West				
X Coordinate:	-121.26462				
Y Coordinate:	38.69217				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	189	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$23,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6850
Location:	Stone Canyon Cir - South				
X Coordinate:	-121.26534				
Y Coordinate:	38.69272				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	80	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$10,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6851
Location:	Stone Canyon Cir - South				
X Coordinate:	-121.26714				
Y Coordinate:	38.69271				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6852
Location:	Stone Canyon Cir - South				
X Coordinate:	-121.26742				
Y Coordinate:	38.69271				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6853
Location:	Woodmore Oaks Dr - North				
X Coordinate:	-121.26771				
Y Coordinate:	38.69209				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	196	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$24,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6854
Location:	Woodmore Oaks Dr - North				
X Coordinate:	-121.26676				
Y Coordinate:	38.69212				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	108	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$13,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6855
Location:	Woodmore Oaks Dr - North				
X Coordinate:	-121.2656				
Y Coordinate:	38.69212				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	100	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$12,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6856
Location:	Woodmore Oaks Dr - North				
X Coordinate:	-121.26481				
Y Coordinate:	38.69215				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	20	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6857
Location:	Woodmore Oaks Dr - North				
X Coordinate:	-121.26435				
Y Coordinate:	38.69213				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	130	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$16,250.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6858
Location:	Woodmore Oaks Dr - North				
X Coordinate:	-121.26399				
Y Coordinate:	38.69213				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	35	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	8.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$4,375.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6859
Location:	Woodmore Oaks Dr - North				
X Coordinate:	-121.2639				
Y Coordinate:	38.69213				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	314	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$39,250.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6860
Location:	Woodmore Oaks Dr - North				
X Coordinate:	-121.26307				
Y Coordinate:	38.69212				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6861
Location:	Woodmore Oaks Dr - North				
X Coordinate:	-121.26279				
Y Coordinate:	38.69214				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	35	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	7.6% cross slope, 10.5% running slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	1 Necessary	Cost Estimate:	\$4,375.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6862
Location:	Woodmore Oaks Dr - North				
X Coordinate:	-121.26265				
Y Coordinate:	38.69219				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	20	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6863
Location:	Woodmore Oaks Dr - South				
X Coordinate:	-121.26261				
Y Coordinate:	38.69203				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	145	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$18,125.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6864
Location:	Woodmore Oaks Dr - South				
X Coordinate:	-121.26293				
Y Coordinate:	38.69201				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	4	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6865
Location:	Woodmore Oaks Dr - South				
X Coordinate:	-121.26323				
Y Coordinate:	38.692				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	331	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$41,375.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date: 4/14/2011 Report Date: 4/14/2011 Barrier #: 6866

Location: Larwin Dr - East

X Coordinate: -121.26445

Y Coordinate: 38.69182

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 194 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.3% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$24,250.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/14/2011 Report Date: 4/14/2011 Barrier #: 6867

Location: Larwin Dr and Red Pine Ct - Corner A

X Coordinate: -121.26468

Y Coordinate: 38.69137

Barrier Area: Curb Ramps

Barrier Type: 12" Grooves - Existing (4.1% to 4.9%)

Code Ref: CBC 1127B.5.6



As Built Meas: 1 Quantity: EACH

Description: 12" grooves at top of curb ramp are not level (4.1% to 4.9%)

As Built Desc: 4.3% at 12" grooves

Solution: Demolish existing and construct new curb ramp

Bar. Severity: 2 Recommended Cost Estimate: \$2,500.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Four - way intersection corner A,B,C,D. Corner D compliant

Field Date: 4/14/2011 Report Date: 4/14/2011 Barrier #: 6868

Location: Larwin Dr and Camstock Ct - Corner B

X Coordinate: -121.26446

Y Coordinate: 38.69136

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No curb cut at corner (intersection)

As Built Desc: No curb ramp at corner

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Four - way intersection corner A,B,C,D. Corner D compliant

Field Date: 4/14/2011 Report Date: 4/14/2011 Barrier #: 6869

Location: Larwin Dr and Camstock Ct - Corner C

X Coordinate: -121.26443

Y Coordinate: 38.69122

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No curb cut at corner (intersection)

As Built Desc: No curb ramp at corner

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Four - way intersection corner A,B,C,D. Corner D compliant

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6870
Location:	Camstock Ct - North				
X Coordinate:	-121.26416				
Y Coordinate:	38.69135				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	413	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$51,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6871
Location:	Camstock Ct - South				
X Coordinate:	-121.26307				
Y Coordinate:	38.69123				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	310	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$38,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6872
Location:	Larwin Dr - East				
X Coordinate:	-121.26446				
Y Coordinate:	38.69117				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	190	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$23,750.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6873
Location:	Larwin Dr - East				
X Coordinate:	-121.26446				
Y Coordinate:	38.69094				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 4/14/2011 Report Date: 4/14/2011 Barrier #: 6874

Location: Larwin Dr and Peppermint Ct - Corner A

X Coordinate: -121.26464

Y Coordinate: 38.6906

Barrier Area: Curb Ramps

Barrier Type: 12" Grooves - Existing (4.1% to 4.9%)

Code Ref: CBC 1127B.5.6



As Built Meas: 1 Quantity: EACH

Description: 12" grooves at top of curb ramp are not level (4.1% to 4.9%)

As Built Desc: 4.7% at 12" grooves

Solution: Demolish existing and construct new curb ramp

Bar. Severity: 2 Recommended

Cost Estimate: \$2,500.00

Status:

Implementation Priority: 2

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes: Four - way intersection corners A,B,C,D. Corner D compliant

Field Date: 4/14/2011 Report Date: 4/14/2011 Barrier #: 6875

Location: Larwin Dr and Oak Meadow Ct - Corner B

X Coordinate: -121.26441

Y Coordinate: 38.69063

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No curb cut at corner (intersection)

As Built Desc: No curb ramp at corner

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary

Cost Estimate: \$2,500.00

Status:

Implementation Priority: 2

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes: Four - way intersection corners A,B,C,D. Corner D compliant

Field Date: 4/14/2011 Report Date: 4/14/2011 Barrier #: 6876

Location: Larwin Dr and Oak Meadow Ct - Corner C

X Coordinate: -121.26442

Y Coordinate: 38.69049

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No curb cut at corner (intersection)

As Built Desc: No curb ramp at corner

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Four - way intersection corners A,B,C,D. Corner D compliant

Field Date: 4/14/2011 Report Date: 4/14/2011 Barrier #: 6877

Location: Oak Meadow Ct - North

X Coordinate: -121.26422

Y Coordinate: 38.6906

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 472 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.4% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$59,000.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/14/2011 Report Date: 4/14/2011 Barrier #: 6878

Location: Oak Meadow Ct - South

X Coordinate: -121.26287

Y Coordinate: 38.69052

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 468 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.4% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hindrance Cost Estimate: \$58,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/14/2011 Report Date: 4/14/2011 Barrier #: 6879

Location: Oak Meadow Ct - South

X Coordinate: -121.26402

Y Coordinate: 38.69047

Barrier Area: Sidewalks

Barrier Type: Abrupt Change in Level - > 1/2"

Code Ref: CBC 1133B.7.1 and ADA/ABA 303.3



As Built Meas: 4 Quantity: LF

Description: Change in level greater than 1/2"

As Built Desc: 1/2" lip in sidewalk surface

Solution: Grind or repair sidewalk to remove trip hazard

Bar. Severity: 1 Necessary Cost Estimate: \$1,000.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6880A
Location:	Larwin Dr - East				
X Coordinate:	-121.26445				
Y Coordinate:	38.69043				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	205	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$25,625.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6880B
Location:	Larwin Dr - East				
X Coordinate:	-121.26443				
Y Coordinate:	38.69037				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6881
Location:	Larwin Dr - East				
X Coordinate:	-121.26443				
Y Coordinate:	38.68969				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	156	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	7.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$19,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6882
Location:	Larwin Dr and Willow Glen Ct - Corner C				
X Coordinate:	-121.26464				
Y Coordinate:	38.68925				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (4.1% to 4.9%)		
As Built Desc:	4.3% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners C,D
--------	------------------------------------

Field Date: 4/14/2011 Report Date: 4/14/2011 Barrier #: 6883

Location: Larwin Dr and Willow Glen Ct - Corner D

X Coordinate: -121.26468

Y Coordinate: 38.68918

Barrier Area: Curb Ramps

Barrier Type: 12" Grooves - Existing (3.1% to 4.0%)

Code Ref: CBC 1127B.5.6



As Built Meas: 1 Quantity: EACH

Description: 12" grooves at top of curb ramp are not level (3.1% to 4.0%)

As Built Desc: 3.9% at 12" grooves

Solution: Demolish existing and construct new curb ramp

Bar. Severity: 3 Hindrance Cost Estimate: \$2,500.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners C,D

Field Date: 4/14/2011 Report Date: 4/14/2011 Barrier #: 6884A

Location: Larwin Dr - South

X Coordinate: -121.2648

Y Coordinate: 38.68915

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 93 Quantity: LF

Description: Cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 10.7% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 1 Necessary Cost Estimate: \$11,625.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6884B
Location:	Larwin Dr - South				
X Coordinate:	-121.26512				
Y Coordinate:	38.68903				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	102	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$12,750.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6884C
Location:	Larwin Dr - South				
X Coordinate:	-121.26525				
Y Coordinate:	38.68898				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6885
Location:	Larwin Dr and Shady Grove Ct - Corner C				
X Coordinate:	-121.26544				
Y Coordinate:	38.6889				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	50	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$6,250.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C, D. Corner D compliant		

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6886
Location:	Shady Grove Ct - East				
X Coordinate:	-121.26495				
Y Coordinate:	38.68858				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	50	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$6,250.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6887A
Location:	Shady Grove Ct - West				
X Coordinate:	-121.26528				
Y Coordinate:	38.68852				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	210	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$26,250.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6887B
Location:	Shady Grove Ct - West				
X Coordinate:	-121.26529				
Y Coordinate:	38.68849				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foligae		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6888
Location:	Larwin Dr - South				
X Coordinate:	-121.26574				
Y Coordinate:	38.68884				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	86	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$10,750.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6889
Location:	Larwin Dr and Plumtree Ct - Corner C				
X Coordinate:	-121.26656				
Y Coordinate:	38.68859				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners C,D
--------	------------------------------------

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6890
Location:	Larwin Dr and Plumtree Ct - Corner D				
X Coordinate:	-121.26672				
Y Coordinate:	38.68854				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	10.0% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C,D		

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6891
Location:	Plumtree Ct - East				
X Coordinate:	-121.26652				
Y Coordinate:	38.68851				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	364	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$45,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6892
Location:	Plumtree Ct - East				
X Coordinate:	-121.26599				
Y Coordinate:	38.688				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	293	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$36,625.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6893
Location:	Larwin Dr - South				
X Coordinate:	-121.26707				
Y Coordinate:	38.68846				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6894
Location:	Larwin Dr and Old Oak Ct - Corner C				
X Coordinate:	-121.26759				
Y Coordinate:	38.68827				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C,D		

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6895
Location:	Larwin Dr and Old Oak Ct - Corner D				
X Coordinate:	-121.26773				
Y Coordinate:	38.68818				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	7.0% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C,D		

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6896
Location:	Old Oak Ct - East				
X Coordinate:	-121.26757				
Y Coordinate:	38.68818				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	528	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$66,000.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6897
Location:	Old Oak Ct - East				
X Coordinate:	-121.26735				
Y Coordinate:	38.68802				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			


Notes:	
--------	--

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6898A
Location:	Old Oak Ct - West				
X Coordinate:	-121.26694				
Y Coordinate:	38.68712				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	542	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$67,750.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6898B
Location:	Old Oak Ct - West				
X Coordinate:	-121.26697				
Y Coordinate:	38.68738				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6898C
Location:	Old Oak Ct - West				
X Coordinate:	-121.26706				
Y Coordinate:	38.68769				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/14/2011	Report Date:	4/14/2011	Barrier #:	6899
Location:	Larwin Dr - South				
X Coordinate:	-121.26836				
Y Coordinate:	38.68808				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6900
Location:	Larwin Dr and Canoe Birch Ct - Corner B				
X Coordinate:	-121.26887				
Y Coordinate:	38.68805				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (4.1% to 4.9%)		
As Built Desc:	4.1% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Four - way intersection corners A,B,C,D. Corner A compliant

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6901
Location:	Larwin Dr and Sweet Gum Ct - Corner C				
X Coordinate:	-121.26873				
Y Coordinate:	38.68792				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Four - way intersection corners A,B,C,D. Corner A compliant

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6902
Location:	Larwin Dr and Sweet Gum Ct - Corner D				
X Coordinate:	-121.26881				
Y Coordinate:	38.68784				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Four - way intersection corners A,B,C,D. Corner A compliant

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6903
Location:	Sweet Gum Ct - East				
X Coordinate:	-121.26868				
Y Coordinate:	38.68789				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	387	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$48,375.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6904
Location:	Sweet Gum Ct - West				
X Coordinate:	-121.26775				
Y Coordinate:	38.68727				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	382	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$47,750.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6905
Location:	Larwin Dr - South				
X Coordinate:	-121.26895				
Y Coordinate:	38.68778				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	273	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$34,125.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6906
Location:	Larwin Dr - South				
X Coordinate:	-121.26915				
Y Coordinate:	38.68751				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6907A
Location:	Larwin Dr and Clear Creek Ct - Corner C				
X Coordinate:	-121.26933				
Y Coordinate:	38.68709				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing ($> 5.0\%$)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level ($> 5.0\%$)		
As Built Desc:	5.9% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D. Corners A,B,D compliant		

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6907B
Location:	Larwin Dr and Clear Creek Ct - Corner C				
X Coordinate:	-121.26933				
Y Coordinate:	38.68709				
Barrier Area:	Curb Ramps				
Barrier Type:	Parallel Ramp Landing - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.4 and ADA/ABA 406.4				



As Built Meas:	1	Quantity:	EACH
Description:	Curb ramp landing or pan not level (3.1% to 4.0%)		
As Built Desc:	3.4% landing slope		
Solution:	Demolish existing and construct new transition		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$0.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D. Corners A,B,D compliant		

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6908
Location:	Clear Creek Ct - East				
X Coordinate:	-121.26861				
Y Coordinate:	38.68688				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	23	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$2,875.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6909
Location:	Clear Creek Ct - West				
X Coordinate:	-121.26884				
Y Coordinate:	38.6867				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	8	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6910
Location:	Larwin Dr - South				
X Coordinate:	-121.26965				
Y Coordinate:	38.68679				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	90	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$11,250.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6911
Location:	Larwin Dr and Smoke Tree Ct - Corner C				
X Coordinate:	-121.26992				
Y Coordinate:	38.68664				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (4.1% to 4.9%)		
As Built Desc:	4.1% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners C,D

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6912
Location:	Larwin Dr and Smoke Tree Ct - Corner D				
X Coordinate:	-121.2701				
Y Coordinate:	38.68659				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (4.1% to 4.9%)		
As Built Desc:	4.1% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners C,D

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6913
Location:	Smoke Tree Ct - East				
X Coordinate:	-121.2699				
Y Coordinate:	38.68659				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	45	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$5,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6914
Location:	Smoke Tree Ct - East				
X Coordinate:	-121.26985				
Y Coordinate:	38.6865				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	40	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	8.8% cross slope, 9.6% running slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	1 Necessary	Cost Estimate:	\$5,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6915
Location:	Smoke Tree Ct - East				
X Coordinate:	-121.26981				
Y Coordinate:	38.68639				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	139	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$17,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6916
Location:	Smoke Tree Ct - West				
X Coordinate:	-121.26989				
Y Coordinate:	38.68606				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	211	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$26,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6917
Location:	Larwin Dr - South				
X Coordinate:	-121.27051				
Y Coordinate:	38.68661				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	112	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$14,000.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6918
Location:	Larwin Dr and Sugar Maple Wy - Corner A				
X Coordinate:	-121.27104				
Y Coordinate:	38.68674				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Four - way intersection corners A, B, C, D
--------	--

Field Date: 4/15/2011 Report Date: 4/15/2011 Barrier #: 6919

Location: Larwin Dr and Sugar Maple Wy - Corner B

X Coordinate: -121.27089

Y Coordinate: 38.68674

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No curb cut at corner (intersection)

As Built Desc: No curb ramp at corner

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Four - way intersection corners A, B, C, D

Field Date: 4/15/2011 Report Date: 4/15/2011 Barrier #: 6920

Location: Larwin Dr and Sugar Maple Wy - Corner C

X Coordinate: -121.27087

Y Coordinate: 38.68657

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No curb cut at corner (intersection)

As Built Desc: No curb ramp at corner

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Four - way intersection corners A, B, C, D

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6921
Location:	Larwin Dr and Sugar Maple Wy - Corner D				
X Coordinate:	-121.27102				
Y Coordinate:	38.68658				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A, B, C, D		

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6922
Location:	Golden Rain Ct - East				
X Coordinate:	-121.27089				
Y Coordinate:	38.68649				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	212	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$26,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6923
Location:	Golden Rain Ct - West				
X Coordinate:	-121.27094				
Y Coordinate:	38.68606				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	194	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$24,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6924A
Location:	Larwin Dr - South				
X Coordinate:	-121.27108				
Y Coordinate:	38.68659				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	79	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$9,875.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6924B
Location:	Larwin Dr - South				
X Coordinate:	-121.27123				
Y Coordinate:	38.6866				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - Tree Heaves				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	8	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1" lip due to tree heaves		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,000.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6925
Location:	Larwin Dr - North				
X Coordinate:	-121.27144				
Y Coordinate:	38.68669				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	84	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$10,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date: 4/15/2011 Report Date: 4/15/2011 Barrier #: 6926

Location: Sugar Maple Wy - West

X Coordinate: -121.27131

Y Coordinate: 38.6867

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 705 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.5% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$88,125.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/15/2011 Report Date: 4/15/2011 Barrier #: 6927

Location: Sugar Maple Wy and Sugar Maple Wy Ct - Corner A

X Coordinate: -121.27063

Y Coordinate: 38.68888

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 8.0% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A,D

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6928
Location:	Sugar Maple Wy and Sugar Maple Wy Ct - Corner D				
X Coordinate:	-121.27071				
Y Coordinate:	38.68879				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	10.2% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,D		

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6929
Location:	Sugar Maple Wy Ct - South				
X Coordinate:	-121.27077				
Y Coordinate:	38.68881				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - New Construction				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	165	Quantity:	LF
Description:	Cross slope exceeds 2.0% in new construction		
As Built Desc:	2.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$20,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6930
Location:	Sugar Maple Wy Ct - North				
X Coordinate:	-121.27093				
Y Coordinate:	38.68911				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	147	Quantity:	LF
Description:	Cross slope exceeds 2.0% (2.1% to 3.0%)		
As Built Desc:	4.2% cross slope		
Solution:	Low severity barrier - no remediation recommended		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6931
Location:	Larwin Dr - North				
X Coordinate:	-121.27056				
Y Coordinate:	38.68885				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	554	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$69,250.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6932
Location:	Larwin Dr - East				
X Coordinate:	-121.26873				
Y Coordinate:	38.68905				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	300	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$37,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6933
Location:	Larwin Dr and Sugar Maple Wy - Corner A				
X Coordinate:	-121.26832				
Y Coordinate:	38.68835				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	10.2% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,B
--------	------------------------------------

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6934
Location:	Larwin Dr and Sugar Maple Wy - Corner B				
X Coordinate:	-121.26815				
Y Coordinate:	38.68838				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	8.6% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6935
Location:	Sugar Maple Wy - West				
X Coordinate:	-121.2684				
Y Coordinate:	38.68847				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	354	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$44,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6936
Location:	Sugar Maple Wy - South				
X Coordinate:	-121.26906				
Y Coordinate:	38.68904				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	610	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$76,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6937A
Location:	Sugar Maple Wy - East				
X Coordinate:	-121.27079				
Y Coordinate:	38.68836				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	527	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$65,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6937B
Location:	Sugar Maple Wy - East				
X Coordinate:	-121.27083				
Y Coordinate:	38.68682				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	30" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6938A
Location:	Larwin Dr - North				
X Coordinate:	-121.27082				
Y Coordinate:	38.68674				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	369	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$46,125.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6938B
Location:	Larwin Dr - North				
X Coordinate:	-121.27073				
Y Coordinate:	38.68674				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6939
Location:	Green Ash Ct - West				
X Coordinate:	-121.26967				
Y Coordinate:	38.68713				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	187	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$23,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date: 4/15/2011 Report Date: 4/15/2011 Barrier #: 6940

Location: Green Ash Ct - East

X Coordinate: -121.27016

Y Coordinate: 38.68744

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 226 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.3% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$28,250.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/15/2011 Report Date: 4/15/2011 Barrier #: 6941

Location: Larwin Dr - North

X Coordinate: -121.26948

Y Coordinate: 38.68723

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 125 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.2% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hindrance Cost Estimate: \$15,625.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6942
Location:	Canoe Birch Ct - West				
X Coordinate:	-121.26901				
Y Coordinate:	38.68802				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	221	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$27,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6943
Location:	Canoe Birch Ct - West				
X Coordinate:	-121.26913				
Y Coordinate:	38.68809				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6944
Location:	Canoe Birch Ct - West				
X Coordinate:	-121.26981				
Y Coordinate:	38.68817				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	94	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$11,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6945
Location:	Canoe Birch Ct - East				
X Coordinate:	-121.27009				
Y Coordinate:	38.68817				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	405	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$50,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6946
Location:	Canoe Birch Ct - East				
X Coordinate:	-121.26935				
Y Coordinate:	38.68839				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6947
Location:	Larwin Dr - North				
X Coordinate:	-121.26879				
Y Coordinate:	38.68808				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	159	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$19,875.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6948
Location:	Larwin Dr - North				
X Coordinate:	-121.26799				
Y Coordinate:	38.68835				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	200	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$25,000.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6949
Location:	Olive Tree Wy Ct - West				
X Coordinate:	-121.26748				
Y Coordinate:	38.68857				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	1034	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$129,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6950
Location:	Olive Tree Wy - North				
X Coordinate:	-121.2679				
Y Coordinate:	38.69131				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	289	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$36,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6951A
Location:	Olive Tree Wy and Red Maple Wy - Corner B				
X Coordinate:	-121.26683				
Y Coordinate:	38.69127				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (2.1% to 3.0%)		
As Built Desc:	2.9% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D. Corners A,D compliant		

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6951B
Location:	Olive Tree Wy and Red Maple Wy - Corner B				
X Coordinate:	-121.26683				
Y Coordinate:	38.69127				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D. Corners A,D compliant		

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6951C
Location:	Olive Tree Wy and Red Maple Wy - Corner B				
X Coordinate:	-121.26683				
Y Coordinate:	38.69127				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (8.3% or more)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	6	Quantity:	SF
Description:	Gutter slope exceeds 5.0% (8.3% or more)		
As Built Desc:	9.8% gutter slope		
Solution:	Demolish existing and construct new gutter		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D. Corners A,D compliant		

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6952A
Location:	Olive Tree Wy and Red Maple Wy - Corner C				
X Coordinate:	-121.26679				
Y Coordinate:	38.69115				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)		
As Built Desc:	3.5% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Four - way intersection corners A,B,C,D. Corners A,D compliant

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6952B
Location:	Olive Tree Wy and Red Maple Wy - Corner C				
X Coordinate:	-121.26679				
Y Coordinate:	38.69115				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Four - way intersection corners A,B,C,D. Corners A,D compliant

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6952C
Location:	Olive Tree Wy and Red Maple Wy - Corner C				
X Coordinate:	-121.26679				
Y Coordinate:	38.69115				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (8.3% or more)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	6	Quantity:	SF
Description:	Gutter slope exceeds 5.0% (8.3% or more)		
As Built Desc:	10.5% gutter slope		
Solution:	Demolish existing and construct new gutter		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Four - way intersection corners A,B,C,D. Corners A,D compliant

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6953A
Location:	Olive Tree Wy - South				
X Coordinate:	-121.26798				
Y Coordinate:	38.69122				
Barrier Area:	Curb Ramps				
Barrier Type:	Curb Ramp at Elbow - Cross Slope				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	1	Quantity:	EACH
Description:	Elbow in roadway has non-compliant cross slope at curb ramp		
As Built Desc:	7.4% cross slope at ramp		
Solution:	Demolish existing and construct standard sidewalk		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6953B
Location:	Olive Tree Wy - South				
X Coordinate:	-121.26798				
Y Coordinate:	38.69122				
Barrier Area:	Curb Ramps				
Barrier Type:	Curb Ramp at Elbow - Landing (>5.0% or more)				
Code Ref:	CBC 1127B.5.4 and ADA/ABA 406.4				



As Built Meas:	1	Quantity:	EACH
Description:	Curb ramp landing or pan not level (>5.0% or more)		
As Built Desc:	4.0% slope at ramp landing		
Solution:	Demolish existing and construct standard sidewalk		
Bar. Severity:	1 Necessary	Cost Estimate:	\$250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6954
Location:	Olive Tree Wy - East				
X Coordinate:	-121.26793				
Y Coordinate:	38.69108				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	373	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$46,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6955
Location:	Olive Tree Wy and Olive Tree Wy Ct - Corner B				
X Coordinate:	-121.26791				
Y Coordinate:	38.69009				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)		
As Built Desc:	3.1% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C. Corner C compliant		

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6956
Location:	Olive Tree Ct - North				
X Coordinate:	-121.26787				
Y Coordinate:	38.69011				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	107	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$13,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date: 4/15/2011 Report Date: 4/15/2011 Barrier #: 6957

Location: Olive Tree Ct - South

X Coordinate: -121.26756

Y Coordinate: 38.69006

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 80 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.3% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hindrance Cost Estimate: \$10,000.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/15/2011 Report Date: 4/15/2011 Barrier #: 6958

Location: Olive Tree Wy - East

X Coordinate: -121.26787

Y Coordinate: 38.68973

Barrier Area: Sidewalks

Barrier Type: Clear Width - Existing ($\leq 31"$ or less)

Code Ref: CBC 1133B.7.1



As Built Meas: 1 Quantity: LF

Description: Pedestrian route is not min. 48" wide ($\leq 31"$ or less)

As Built Desc: 24" clear width due to foliage

Solution: Trim foliage to provide min. 48" clear width

Bar. Severity: 1 Necessary Cost Estimate: \$125.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6959
Location:	Olive Tree Wy - East				
X Coordinate:	-121.26787				
Y Coordinate:	38.68956				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	402	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$50,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6960
Location:	Larwin Dr - North				
X Coordinate:	-121.26724				
Y Coordinate:	38.68858				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	312	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$39,000.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6961A
Location:	Larwin Dr and Red Maple Wy - Corner A				
X Coordinate:	-121.26619				
Y Coordinate:	38.68887				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)		
As Built Desc:	3.6% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A, B

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6961B
Location:	Larwin Dr and Red Maple Wy - Corner A				
X Coordinate:	-121.26619				
Y Coordinate:	38.68887				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A, B

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6962A
Location:	Larwin Dr and Red Maple Wy - Corner B				
X Coordinate:	-121.26605				
Y Coordinate:	38.68893				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (4.1% to 4.9%)		
As Built Desc:	4.6% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A, B

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6962B
Location:	Larwin Dr and Red Maple Wy - Corner B				
X Coordinate:	-121.26605				
Y Coordinate:	38.68893				
Barrier Area:	Curb Ramps				
Barrier Type:	Cross Slope - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	1	Quantity:	EACH
Description:	Ramp run cross slope exceeds 2.0% (2.1% to 3.0%)		
As Built Desc:	2.8% cross slope		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A, B

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6962C
Location:	Larwin Dr and Red Maple Wy - Corner B				
X Coordinate:	-121.26605				
Y Coordinate:	38.68893				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A, B		

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6962D
Location:	Larwin Dr and Red Maple Wy - Corner B				
X Coordinate:	-121.26605				
Y Coordinate:	38.68893				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (6.6% to 8.2%)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	6	Quantity:	SF
Description:	Gutter slope exceeds 5.0% (6.6% to 8.2%)		
As Built Desc:	7.7% gutter slope		
Solution:	Demolish existing and construct new gutter		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A, B		

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6963
Location:	Red Maple Wy - West				
X Coordinate:	-121.26623				
Y Coordinate:	38.68893				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	61	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$7,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6964A
Location:	Red Maple Wy and Red Maple Ct - Corner A				
X Coordinate:	-121.26655				
Y Coordinate:	38.68954				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (>5.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (>5.0%)		
As Built Desc:	5.5% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Four - way intersection corners A, B, C, D
--------	--

Field Date: 4/15/2011 Report Date: 4/15/2011 Barrier #: 6964B

Location: Red Maple Wy and Red Maple Ct - Corner A

X Coordinate: -121.26655

Y Coordinate: 38.68954

Barrier Area: Curb Ramps

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1127B.5.3 and ADA/ABA 406.2



As Built Meas: 1 Quantity: EACH

Description: Ramp run cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.5% cross slope

Solution: Demolish existing and construct new curb ramp

Bar. Severity: 2 Recommended

Cost Estimate: \$0.00

Status:

Implementation Priority: 4

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes: Four - way intersection corners A, B, C, D

Field Date: 4/15/2011 Report Date: 4/15/2011 Barrier #: 6964C

Location: Red Maple Wy and Red Maple Ct - Corner A

X Coordinate: -121.26655

Y Coordinate: 38.68954

Barrier Area: Curb Ramps

Barrier Type: Detectable Warnings - Truncated Domes

Code Ref: CBC 1127B.5.7 and ADA/ABA 705.1.3



As Built Meas: 1 Quantity: EACH

Description: No truncated domes provided at curb ramp

As Built Desc: No detectable warnings at curb ramp

Solution: Provide compliant truncated domes

Bar. Severity: 2 Recommended

Cost Estimate: \$0.00

Status:

Implementation Priority: 4

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes: Four - way intersection corners A, B, C, D

Field Date: 4/15/2011 Report Date: 4/15/2011 Barrier #: 6964D

Location: Red Maple Wy and Red Maple Ct - Corner A

X Coordinate: -121.26655

Y Coordinate: 38.68954

Barrier Area: Curb Ramps

Barrier Type: Gutter Slope - Existing (8.3% or more)

Code Ref: CBC 1127B.5.3 and ADA/ABA 406.2



As Built Meas: 6 Quantity: SF

Description: Gutter slope exceeds 5.0% (8.3% or more)

As Built Desc: 8.8% gutter slope

Solution: Demolish existing and construct new gutter

Bar. Severity: 1 Necessary Cost Estimate: \$0.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Four - way intersection corners A, B, C, D

Field Date: 4/15/2011 Report Date: 4/15/2011 Barrier #: 6965A

Location: Red Maple Wy and Black Walnut Ct - Corner B

X Coordinate: -121.2663

Y Coordinate: 38.68962

Barrier Area: Curb Ramps

Barrier Type: 12" Grooves - Existing (>5.0%)

Code Ref: CBC 1127B.5.6



As Built Meas: 1 Quantity: EACH

Description: 12" grooves at top of curb ramp are not level (>5.0%)

As Built Desc: 6.1% at 12" grooves

Solution: Demolish existing and construct new curb ramp

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Four - way intersection corners A, B, C, D

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6965B
Location:	Red Maple Wy and Black Walnut Ct - Corner B				
X Coordinate:	-121.2663				
Y Coordinate:	38.68962				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Four - way intersection corners A, B, C, D

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6966A
Location:	Red Maple Wy and Black Walnut Ct - Corner C				
X Coordinate:	-121.26631				
Y Coordinate:	38.68954				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)		
As Built Desc:	3.1% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Four - way intersection corners A, B, C, D

Field Date: 4/15/2011 Report Date: 4/15/2011 Barrier #: 6966B

Location: Red Maple Wy and Black Walnut Ct - Corner C

X Coordinate: -121.26631

Y Coordinate: 38.68954

Barrier Area: Curb Ramps

Barrier Type: Cross Slope - Existing (2.1% to 3.0%)

Code Ref: CBC 1127B.5.3 and ADA/ABA 406.2



As Built Meas: 1 Quantity: EACH

Description: Ramp run cross slope exceeds 2.0% (2.1% to 3.0%)

As Built Desc: 2.9% cross slope

Solution: Demolish existing and construct new curb ramp

Bar. Severity: 4 Low Severity

Cost Estimate: \$0.00

Status:

Implementation Priority: 4

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes: Four - way intersection corners A, B, C, D

Field Date: 4/15/2011 Report Date: 4/15/2011 Barrier #: 6966C

Location: Red Maple Wy and Black Walnut Ct - Corner C

X Coordinate: -121.26631

Y Coordinate: 38.68954

Barrier Area: Curb Ramps

Barrier Type: Detectable Warnings - Truncated Domes

Code Ref: CBC 1127B.5.7 and ADA/ABA 705.1.3



As Built Meas: 1 Quantity: EACH

Description: No truncated domes provided at curb ramp

As Built Desc: No detectable warnings at curb ramp

Solution: Provide compliant truncated domes

Bar. Severity: 2 Recommended

Cost Estimate: \$0.00

Status:

Implementation Priority: 4

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes: Four - way intersection corners A, B, C, D

Field Date: 4/15/2011 Report Date: 4/15/2011 Barrier #: 6967A

Location: Red Maple Wy and Red Maple Ct - Corner D

X Coordinate: -121.26647

Y Coordinate: 38.68946

Barrier Area: Curb Ramps

Barrier Type: Detectable Warnings - Truncated Domes

Code Ref: CBC 1127B.5.7 and ADA/ABA 705.1.3



As Built Meas: 1 Quantity: EACH

Description: No truncated domes provided at curb ramp

As Built Desc: No detectable warnings at curb ramp

Solution: Provide compliant truncated domes

Bar. Severity: 2 Recommended Cost Estimate: \$1,400.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Four - way intersection corners A, B, C, D

Field Date: 4/15/2011 Report Date: 4/15/2011 Barrier #: 6967B

Location: Red Maple Wy and Red Maple Ct - Corner D

X Coordinate: -121.26647

Y Coordinate: 38.68946

Barrier Area: Curb Ramps

Barrier Type: Gutter Slope - Existing (6.6% to 8.2%)

Code Ref: CBC 1127B.5.3 and ADA/ABA 406.2



As Built Meas: 6 Quantity: SF

Description: Gutter slope exceeds 5.0% (6.6% to 8.2%)

As Built Desc: 7.1% gutter slope

Solution: Demolish existing and construct new gutter

Bar. Severity: 2 Recommended Cost Estimate: \$750.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Four - way intersection corners A, B, C, D

Field Date: 4/15/2011 Report Date: 4/15/2011 Barrier #: 6968

Location: Red Maple Ct - North

X Coordinate: -121.26689

Y Coordinate: 38.6895

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 85 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.3% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hindrance Cost Estimate: \$10,625.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/15/2011 Report Date: 4/15/2011 Barrier #: 6969

Location: Red Maple Wy and Woodmore Oaks Dr - Corner B

X Coordinate: -121.26688

Y Coordinate: 38.6921

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No curb cut at corner (intersection)

As Built Desc: No curb ramp at corner

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Three - way intersection corners B, C, D

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6970A
Location:	Red Maple Wy and Woodmore Oaks Dr - Corner C				
X Coordinate:	-121.2669				
Y Coordinate:	38.69192				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (>5.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (>5.0%)		
As Built Desc:	8.9% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Three - way intersection corners B, C, D

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6970B
Location:	Red Maple Wy and Woodmore Oaks Dr - Corner C				
X Coordinate:	-121.2669				
Y Coordinate:	38.69192				
Barrier Area:	Curb Ramps				
Barrier Type:	Running Slope - Existing (9.5% or more)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.1				



As Built Meas:	1	Quantity:	EACH
Description:	Ramp run cross slope exceeds 2.0% (9.5% or more)		
As Built Desc:	9.8% running slope		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Three - way intersection corners B, C, D

Field Date: 4/15/2011 Report Date: 4/15/2011 Barrier #: 6970C

Location: Red Maple Wy and Woodmore Oaks Dr - Corner C

X Coordinate: -121.2669

Y Coordinate: 38.69192

Barrier Area: Curb Ramps

Barrier Type: Parallel Ramp Landing - Existing (3.1% to 4.0%)

Code Ref: CBC 1127B.5.4 and ADA/ABA 406.4



As Built Meas: 1 Quantity: EACH

Description: Curb ramp landing or pan not level (3.1% to 4.0%)

As Built Desc: 3.4% landing slope

Solution: Demolish existing and construct new transition

Bar. Severity: 3 Hindrance Cost Estimate: \$0.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Three - way intersection corners B, C, D

Field Date: 4/15/2011 Report Date: 4/15/2011 Barrier #: 6970D

Location: Red Maple Wy and Woodmore Oaks Dr - Corner C

X Coordinate: -121.2669

Y Coordinate: 38.69192

Barrier Area: Curb Ramps

Barrier Type: Detectable Warnings - Truncated Domes

Code Ref: CBC 1127B.5.7 and ADA/ABA 705.1.3



As Built Meas: 1 Quantity: EACH

Description: No truncated domes provided at curb ramp

As Built Desc: No detectable warnings at curb ramp

Solution: Provide compliant truncated domes

Bar. Severity: 2 Recommended Cost Estimate: \$0.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Three - way intersection corners B, C, D

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6970E
Location:	Red Maple Wy and Woodmore Oaks Dr - Corner C				
X Coordinate:	-121.2669				
Y Coordinate:	38.69192				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (8.3% or more)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	6	Quantity:	SF
Description:	Gutter slope exceeds 5.0% (8.3% or more)		
As Built Desc:	8.4% gutter slope		
Solution:	Demolish existing and construct new gutter		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Three - way intersection corners B, C, D		

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6971A
Location:	Red Maple Wy and Woodmore Oaks Dr - Corner D				
X Coordinate:	-121.26705				
Y Coordinate:	38.69191				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Three - way intersection corners B, C, D		

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6971B
Location:	Red Maple Wy and Woodmore Oaks Dr - Corner D				
X Coordinate:	-121.26705				
Y Coordinate:	38.69191				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (6.6% to 8.2%)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	6	Quantity:	SF
Description:	Gutter slope exceeds 5.0% (6.6% to 8.2%)		
As Built Desc:	7.3% gutter slope		
Solution:	Demolish existing and construct new gutter		
Bar. Severity:	2 Recommended	Cost Estimate:	\$750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Three - way intersection corners B, C, D		

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6972
Location:	Red Maple Wy - East				
X Coordinate:	-121.26688				
Y Coordinate:	38.69188				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	76	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	26" clear width due to foliage		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$9,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6973
Location:	Black Walnut Ct - North				
X Coordinate:	-121.26605				
Y Coordinate:	38.68967				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6974
Location:	Red Maple Wy - East				
X Coordinate:	-121.26623				
Y Coordinate:	38.68933				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	30" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6975
Location:	Larwin Dr - North				
X Coordinate:	-121.26594				
Y Coordinate:	38.68894				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	352	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	7.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$44,000.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6976
Location:	Larwin Dr - West				
X Coordinate:	-121.26484				
Y Coordinate:	38.68926				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	337	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$42,125.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6977
Location:	Larwin Dr - West				
X Coordinate:	-121.2646				
Y Coordinate:	38.69024				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	72	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$9,000.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6978
Location:	Larwin Dr - West				
X Coordinate:	-121.2646				
Y Coordinate:	38.69027				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	28" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6979A
Location:	Peppermint Ct - North				
X Coordinate:	-121.26579				
Y Coordinate:	38.69067				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	190	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$23,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6979B
Location:	Peppermint Ct - North				
X Coordinate:	-121.26575				
Y Coordinate:	38.69067				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	28" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6980
Location:	Larwin Dr - West				
X Coordinate:	-121.2646				
Y Coordinate:	38.69067				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	190	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$23,750.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6981
Location:	Red Pine Ct - South				
X Coordinate:	-121.26541				
Y Coordinate:	38.69121				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	31	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$3,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6982A
Location:	Red Pine Ct - North				
X Coordinate:	-121.26539				
Y Coordinate:	38.69141				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	64	Quantity:	LF
Description:	Cross slope exceeds 2.0% (2.1% to 3.0%)		
As Built Desc:	2.9% cross slope		
Solution:	Low severity barrier - no remediation recommended		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6982B
Location:	Red Pine Ct - North				
X Coordinate:	-121.26535				
Y Coordinate:	38.69139				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6983A
Location:	Larwin Dr - West				
X Coordinate:	-121.26467				
Y Coordinate:	38.69171				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6983B
Location:	Larwin Dr - West				
X Coordinate:	-121.26465				
Y Coordinate:	38.69174				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	63	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$7,875.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6984
Location:	Woodmore Oaks Dr - South				
X Coordinate:	-121.2685				
Y Coordinate:	38.69193				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	4	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6985A
Location:	Trovita Wy - East				
X Coordinate:	-121.26897				
Y Coordinate:	38.69181				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	260	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$32,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6985B
Location:	Trovita Wy - East				
X Coordinate:	-121.26896				
Y Coordinate:	38.69154				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	30" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6985C
Location:	Trovita Wy - East				
X Coordinate:	-121.26891				
Y Coordinate:	38.6898				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	8	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 4/15/2011 Report Date: 4/15/2011 Barrier #: 6986

Location: Trovita Wy - South

X Coordinate: -121.26895

Y Coordinate: 38.68977

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 575 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.8% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$71,875.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/15/2011 Report Date: 4/15/2011 Barrier #: 6987A

Location: Trovita Wy - West

X Coordinate: -121.27091

Y Coordinate: 38.68977

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 534 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.3% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$66,750.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6987B
Location:	Trovita Wy - West				
X Coordinate:	-121.27096				
Y Coordinate:	38.69108				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	8	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6988
Location:	Trovita Wy - East				
X Coordinate:	-121.27076				
Y Coordinate:	38.69096				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	126	Quantity:	LF
Description:	Cross slope exceeds 2.0% (2.1% to 3.0%)		
As Built Desc:	3.0% cross slope		
Solution:	Low severity barrier - no remediation recommended		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6989
Location:	Trovita Wy - East				
X Coordinate:	-121.27089				
Y Coordinate:	38.69043				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	151	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$18,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6990
Location:	Trovita Wy - North				
X Coordinate:	-121.27082				
Y Coordinate:	38.68982				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	507	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$63,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6991
Location:	Trovita Wy - West				
X Coordinate:	-121.26901				
Y Coordinate:	38.68991				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	200	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$25,000.00
Status:			
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6992
Location:	Tangors Wy - South				
X Coordinate:	-121.26909				
Y Coordinate:	38.6905				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	493	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$61,625.00
Status:			
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6993A
Location:	Tangors Wy - North				
X Coordinate:	-121.27082				
Y Coordinate:	38.6906				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	147	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$18,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6993B
Location:	Tangors Wy - North				
X Coordinate:	-121.27067				
Y Coordinate:	38.69057				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6993C
Location:	Tangors Wy - North				
X Coordinate:	-121.27026				
Y Coordinate:	38.69059				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	30	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	12.8% cross slope at tree heaves		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$3,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6994
Location:	Tangors Wy - North				
X Coordinate:	-121.27016				
Y Coordinate:	38.69057				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	68	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$8,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6995A
Location:	Tangors Wy and Tarocco Wy - Corner A				
X Coordinate:	-121.27003				
Y Coordinate:	38.69056				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (>5.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (>5.0%)		
As Built Desc:	6.7% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A, B. Corner B compliant		

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6995B
Location:	Tangors Wy and Tarocco Wy - Corner A				
X Coordinate:	-121.27003				
Y Coordinate:	38.69056				
Barrier Area:	Curb Ramps				
Barrier Type:	Running Slope - Existing (9.0% to 9.4%)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.1				



As Built Meas:	1	Quantity:	EACH
Description:	Ramp run cross slope exceeds 2.0% (9.0% to 9.4%)		
As Built Desc:	9.1% running slope		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A, B. Corner B compliant		

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6996
Location:	Tangors Wy - North				
X Coordinate:	-121.2698				
Y Coordinate:	38.69057				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	190	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$23,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	6997
Location:	Trovita Wy - West				
X Coordinate:	-121.26907				
Y Coordinate:	38.69067				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	440	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$55,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 4/15/2011 Report Date: 4/15/2011 Barrier #: 6998

Location: Woodmore Oaks Dr and Tarocco Wy - Corner C

X Coordinate: -121.27003

Y Coordinate: 38.6919

Barrier Area: Curb Ramps

Barrier Type: 12" Grooves - Existing (3.1% to 4.0%)

Code Ref: CBC 1127B.5.6



As Built Meas: 1 Quantity: EACH

Description: 12" grooves at top of curb ramp are not level (3.1% to 4.0%)

As Built Desc: 3.4% at 12" grooves

Solution: Demolish existing and construct new curb ramp

Bar. Severity: 3 Hindrance Cost Estimate: \$2,500.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners C,D

Field Date: 4/15/2011 Report Date: 4/15/2011 Barrier #: 6999

Location: Woodmore Oaks Dr and Tarocco Wy - Corner D

X Coordinate: -121.27023

Y Coordinate: 38.69192

Barrier Area: Curb Ramps

Barrier Type: 12" Grooves - Existing (>5.0%)

Code Ref: CBC 1127B.5.6



As Built Meas: 1 Quantity: EACH

Description: 12" grooves at top of curb ramp are not level (>5.0%)

As Built Desc: 5.1% at 12" grooves

Solution: Demolish existing and construct new curb ramp

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners C,D

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	7000
Location:	Tarocco Wy - East				
X Coordinate:	-121.27006				
Y Coordinate:	38.69183				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	447	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$55,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	7001
Location:	Tarocco Wy - West				
X Coordinate:	-121.27001				
Y Coordinate:	38.6907				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	296	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$37,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	7002
Location:	Tarocco Wy - West				
X Coordinate:	-121.27016				
Y Coordinate:	38.69142				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	40	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	7.9% cross slope at cracked concrete		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$5,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/15/2011	Report Date:	4/15/2011	Barrier #:	7003
Location:	Tarocco Wy - West				
X Coordinate:	-121.27022				
Y Coordinate:	38.69148				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	145	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$18,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 4/15/2011 Report Date: 4/15/2011 Barrier #: 7004

Location: Woodmore Oaks Dr - South

X Coordinate: -121.27082

Y Coordinate: 38.69205

Barrier Area: Sidewalks

Barrier Type: Driveway - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 40 Quantity: LF

Description: Driveway cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 5.9% cross slope

Solution: Provide min. 48" wide level walkway through driveway

Bar. Severity: 4 Low Severity Cost Estimate: \$5,000.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/18/2011 Report Date: 4/18/2011 Barrier #: 7005

Location: Kenneth Ave - West

X Coordinate: -121.24445

Y Coordinate: 38.69324

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 584 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.9% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$73,000.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7006
Location:	Kenneth Ave - West				
X Coordinate:	-121.24446				
Y Coordinate:	38.69466				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	4	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7007
Location:	Kenneth Ave and Mansfield Dr - Corner A				
X Coordinate:	-121.24451				
Y Coordinate:	38.69502				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	14.2% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A, D		

Field Date: 4/18/2011 Report Date: 4/18/2011 Barrier #: 7008

Location: Kenneth Ave and Mansfield Dr - Corner D

X Coordinate: -121.24452

Y Coordinate: 38.69489

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 11.6% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A, D

Field Date: 4/18/2011 Report Date: 4/18/2011 Barrier #: 7009

Location: Kenneth Ave - West

X Coordinate: -121.2445

Y Coordinate: 38.69508

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 610 Quantity: LF

Description: Cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 5.3% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 1 Necessary Cost Estimate: \$76,250.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7010
Location:	Kenneth Ave - West				
X Coordinate:	-121.24447				
Y Coordinate:	38.69696				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	249	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$31,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7011
Location:	Kenneth Ave - West				
X Coordinate:	-121.24445				
Y Coordinate:	38.69788				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	854	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$106,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7012A
Location:	Oak Ave - South				
X Coordinate:	-121.24481				
Y Coordinate:	38.70033				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	1020	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$127,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7012B
Location:	Oak Ave - South				
X Coordinate:	-121.24615				
Y Coordinate:	38.70035				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7013
Location:	Oak Ave and Menke Wy - Corner C				
X Coordinate:	-121.2485				
Y Coordinate:	38.70036				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	6.4% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C,D		

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7014
Location:	Oak Ave and Menke Wy - Corner D				
X Coordinate:	-121.24868				
Y Coordinate:	38.70036				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	8.6% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C,D		

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7015
Location:	Oak Ave - South				
X Coordinate:	-121.24876				
Y Coordinate:	38.70036				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	763	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$95,375.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7016
Location:	Oak Ave and Old Ranch Rd - Corner C				
X Coordinate:	-121.25145				
Y Coordinate:	38.70034				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	12.4% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners C,D
--------	------------------------------------

Field Date: 4/18/2011 Report Date: 4/18/2011 Barrier #: 7017

Location: Oak Ave and Old Ranch Rd - Corner D

X Coordinate: -121.25164

Y Coordinate: 38.70035

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 11.9% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners C,D

Field Date: 4/18/2011 Report Date: 4/18/2011 Barrier #: 7018

Location: Oak Ave - South

X Coordinate: -121.25171

Y Coordinate: 38.70037

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 518 Quantity: LF

Description: Cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 5.3% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 1 Necessary Cost Estimate: \$64,750.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7019
Location:	Oak Ave - South				
X Coordinate:	-121.25445				
Y Coordinate:	38.70038				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB
Description:	No barricade provided where sidewalk ends in hazardous location		
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk		
Solution:	Provide barricade with cane detectable warning at end of sidewalk		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7020
Location:	Oak Ave - South				
X Coordinate:	-121.25446				
Y Coordinate:	38.70037				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	80	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$8,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7021
Location:	Oak Ave - South				
X Coordinate:	-121.25507				
Y Coordinate:	38.70046				
Barrier Area:	Sidewalks				
Barrier Type:	Shoulder Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	116	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.4% cross slope		
Solution:	Demolish existing and construct new pedestrian route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$14,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7022
Location:	Oak Ave - South				
X Coordinate:	-121.25655				
Y Coordinate:	38.70044				
Barrier Area:	Sidewalks				
Barrier Type:	Shoulder Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	42	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new pedestrian route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$5,250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7023
Location:	Oak Ave - South				
X Coordinate:	-121.25679				
Y Coordinate:	38.70042				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB
Description:	No barricade provided where sidewalk ends in hazardous location		
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk		
Solution:	Provide barricade with cane detectable warning at end of sidewalk		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7024
Location:	Oak Ave and Streng Ave - Corner C				
X Coordinate:	-121.25688				
Y Coordinate:	38.70042				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (>5.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (>5.0%)		
As Built Desc:	5.6% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C, D. Corner D compliant		

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7025
Location:	Oak Ave - South				
X Coordinate:	-121.25711				
Y Coordinate:	38.70043				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB
Description:	No barricade provided where sidewalk ends in hazardous location		
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk		
Solution:	Provide barricade with cane detectable warning at end of sidewalk		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7026
Location:	Oak Ave and Cross Dr - Corner C				
X Coordinate:	-121.25798				
Y Coordinate:	38.70045				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at transition into roadway		
As Built Desc:	No required detectable warning provided		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners C,D
--------	------------------------------------

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7027
Location:	Oak Ave and Cross Dr - Corner D				
X Coordinate:	-121.25812				
Y Coordinate:	38.70045				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at transition into roadway		
As Built Desc:	No required detectable warning provided		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C,D		

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7028
Location:	Oak Ave - South				
X Coordinate:	-121.25816				
Y Coordinate:	38.70046				
Barrier Area:	Sidewalks				
Barrier Type:	Shoulder Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	386	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.5% cross slope		
Solution:	Demolish existing and construct new pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$48,250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7029
Location:	Fair Oaks Blvd - East				
X Coordinate:	-121.26234				
Y Coordinate:	38.70023				
Barrier Area:	Sidewalks				
Barrier Type:	Shoulder Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	333	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new pedestrian route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$41,625.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7030
Location:	Fair Oaks Blvd and Pleasant View Dr - Corner B				
X Coordinate:	-121.26238				
Y Coordinate:	38.69929				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at transition into roadway		
As Built Desc:	No required detectable warning provided		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7031
Location:	Fair Oaks Blvd and Pleasant View Dr - Corner C				
X Coordinate:	-121.2624				
Y Coordinate:	38.69916				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at transition into roadway		
As Built Desc:	No required detectable warning provided		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7032
Location:	Fair Oaks Blvd - East				
X Coordinate:	-121.26238				
Y Coordinate:	38.69896				
Barrier Area:	Sidewalks				
Barrier Type:	Shoulder Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	245	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new pedestrian route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$30,625.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7033
Location:	Fair Oaks Blvd - East				
X Coordinate:	-121.26245				
Y Coordinate:	38.69724				
Barrier Area:	Sidewalks				
Barrier Type:	Shoulder Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	183	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.4% cross slope		
Solution:	Demolish existing and construct new pedestrian route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$22,875.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7034
Location:	Fair Oaks Blvd - East				
X Coordinate:	-121.26238				
Y Coordinate:	38.69663				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - Transition to Shoulder				
Code Ref:	CBC 1121B.2 and ADA/ABA 206.2.1				



As Built Meas:	1	Quantity:	JOB
Description:	Sidewalk ends and no ramp to pedestrian shoulder is provided		
As Built Desc:	No ramp to shoulder to enable pedestrian travel onto existing shoulder		
Solution:	Provide transition ramp to paved shoulder where no opposite sidewalk exists		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7035
Location:	Fair Oaks Blvd - East				
X Coordinate:	-121.26239				
Y Coordinate:	38.69661				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB
Description:	No barricade provided where sidewalk ends in hazardous location		
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk		
Solution:	Provide barricade with cane detectable warning at end of sidewalk		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7036
Location:	Fair Oaks Blvd - East				
X Coordinate:	-121.26238				
Y Coordinate:	38.69661				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	80	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$10,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 4/18/2011 Report Date: 4/18/2011 Barrier #: 7037

Location: Fair Oaks Blvd and Poppyfield Wy - Corner C

X Coordinate: -121.26234

Y Coordinate: 38.69618

Barrier Area: Curb Ramps

Barrier Type: 12" Grooves - Existing (2.1% to 3.0%)

Code Ref: CBC 1127B.5.6



As Built Meas: 1 Quantity: EACH

Description: 12" grooves at top of curb ramp are not level (2.1% to 3.0%)

As Built Desc: 3.0% at 12" grooves

Solution: Demolish existing and construct new curb ramp

Bar. Severity: 4 Low Severity

Cost Estimate: \$2,500.00

Status:

Implementation Priority: 1

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes: Two - way intersection corners B, C. Corner B compliant

Field Date: 4/18/2011 Report Date: 4/18/2011 Barrier #: 7038A

Location: Fair Oaks Blvd - East

X Coordinate: -121.26234

Y Coordinate: 38.69612

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 765 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.9% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended

Cost Estimate: \$95,625.00

Status:

Implementation Priority: 1

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes:

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7038B
Location:	Fair Oaks Blvd - East				
X Coordinate:	-121.26236				
Y Coordinate:	38.69601				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing (32" to 35")				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide (32" to 35")		
As Built Desc:	32" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7038C
Location:	Fair Oaks Blvd - East				
X Coordinate:	-121.26228				
Y Coordinate:	38.69515				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7039
Location:	Fair Oaks Blvd and Dart Wy - Corner B				
X Coordinate:	-121.26221				
Y Coordinate:	38.69365				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (>5.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (>5.0%)		
As Built Desc:	5.4% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C. Corner C compliant		

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7040
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26222				
Y Coordinate:	38.69363				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	4	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7041
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.2624				
Y Coordinate:	38.67888				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	41	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$5,125.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7042
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26243				
Y Coordinate:	38.6791				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	50	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (2.1% to 3.0%)		
As Built Desc:	3.0% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	1 Necessary	Cost Estimate:	\$6,250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7043
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26242				
Y Coordinate:	38.67924				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	98	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$12,250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7044
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26244				
Y Coordinate:	38.67938				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	50	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.2% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$6,250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7045
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26243				
Y Coordinate:	38.67969				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	18	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7046
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26244				
Y Coordinate:	38.67983				
Barrier Area:	Sidewalks				
Barrier Type:	Shoulder Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	460	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.6% cross slope		
Solution:	Demolish existing and construct new pedestrian route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$57,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7047
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26236				
Y Coordinate:	38.67989				
Barrier Area:	Sidewalks				
Barrier Type:	Running Slope (Existing)				
Code Ref:	CBC 1133B.7.3 and ADA/ABA 403.3				



As Built Meas:	8	Quantity:	LF
Description:	Running slope exceeds 5.0%		
As Built Desc:	6.9% running slope		
Solution:	No remediation where sidewalk sloped as roadway		
Bar. Severity:	5 Technically Infeasible	Cost Estimate:	\$0.00
Status:			
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7048
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26246				
Y Coordinate:	38.68116				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	145	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$18,125.00
Status:			
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7049
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26251				
Y Coordinate:	38.68116				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	61	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.0% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$7,625.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7050
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.2625				
Y Coordinate:	38.68195				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	51	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.5% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$6,375.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7051
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26261				
Y Coordinate:	38.68256				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	460	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$57,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7052
Location:	Fair Oaks Blvd and Oak Creek Apts - Corner A				
X Coordinate:	-121.2626				
Y Coordinate:	38.68272				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)		
As Built Desc:	3.1% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,D. Corner D compliant
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7053
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26257				
Y Coordinate:	38.68423				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	375	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$46,875.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7054
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26261				
Y Coordinate:	38.68463				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	50	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.6% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$6,250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7055
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.2626				
Y Coordinate:	38.68567				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	202	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$25,250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7056
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26255				
Y Coordinate:	38.68641				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	132	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$16,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date: 4/18/2011 Report Date: 4/18/2011 Barrier #: 7057

Location: Fair Oaks Blvd and Linden Lime Ct - Corner A

X Coordinate: -121.26251

Y Coordinate: 38.68702

Barrier Area: Curb Ramps

Barrier Type: 12" Grooves - Existing (3.1% to 4.0%)

Code Ref: CBC 1127B.5.6



As Built Meas: 1 Quantity: EACH

Description: 12" grooves at top of curb ramp are not level (3.1% to 4.0%)

As Built Desc: 3.6% at 12" grooves

Solution: Demolish existing and construct new curb ramp

Bar. Severity: 3 Hindrance Cost Estimate: \$2,500.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A, D. Corner D compliant

Field Date: 4/18/2011 Report Date: 4/18/2011 Barrier #: 7058A

Location: Linden Lime Ct - South

X Coordinate: -121.26271

Y Coordinate: 38.68687

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 224 Quantity: LF

Description: Cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 5.3% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 1 Necessary Cost Estimate: \$28,000.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7058B
Location:	Linden Lime Ct - South				
X Coordinate:	-121.26287				
Y Coordinate:	38.6868				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7059
Location:	Linden Lime Ct and Linden Lime Ct - Corner C				
X Coordinate:	-121.26318				
Y Coordinate:	38.6866				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (4.1% to 4.9%)		
As Built Desc:	4.7% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners C,D
--------	------------------------------------

Field Date: 4/18/2011 Report Date: 4/18/2011 Barrier #: 7060

Location: Linden Lime Ct and Linden Lime Ct - Corner D

X Coordinate: -121.26332

Y Coordinate: 38.68653

Barrier Area: Curb Ramps

Barrier Type: Cross Slope - Existing (2.1% to 3.0%)

Code Ref: CBC 1127B.5.3 and ADA/ABA 406.2



As Built Meas: 1 Quantity: EACH

Description: Ramp run cross slope exceeds 2.0% (2.1% to 3.0%)

As Built Desc: 3.0% cross slope

Solution: Demolish existing and construct new curb ramp

Bar. Severity: 4 Low Severity

Cost Estimate: \$2,500.00

Status:

Implementation Priority: 2

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes: Two - way intersection corners C,D

Field Date: 4/18/2011 Report Date: 4/18/2011 Barrier #: 7061

Location: Linden Lime Ct - East

X Coordinate: -121.26311

Y Coordinate: 38.68648

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 140 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.6% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hindrance

Cost Estimate: \$17,500.00

Status:

Implementation Priority: 2

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes:

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7062
Location:	Linden Lime Ct - West				
X Coordinate:	-121.26313				
Y Coordinate:	38.6862				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	145	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$18,125.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7063A
Location:	Linden Lime Ct - South				
X Coordinate:	-121.26318				
Y Coordinate:	38.6862				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	315	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$39,375.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7063B
Location:	Linden Lime Ct - South				
X Coordinate:	-121.26338				
Y Coordinate:	38.68653				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	8	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	11.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7063C
Location:	Linden Lime Ct - South				
X Coordinate:	-121.26442				
Y Coordinate:	38.68617				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	8	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,000.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7064A
Location:	Linden Lime Ct - South				
X Coordinate:	-121.26456				
Y Coordinate:	38.68623				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	71	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	8.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$8,875.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7064B
Location:	Linden Lime Ct - South				
X Coordinate:	-121.2645				
Y Coordinate:	38.6862				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	8	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/18/2011	Report Date:	4/18/2011	Barrier #:	7065
Location:	Linden Lime Ct - North				
X Coordinate:	-121.26404				
Y Coordinate:	38.68631				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	638	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$79,750.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7066A
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26241				
Y Coordinate:	38.68709				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	208	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$26,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7066B
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26246				
Y Coordinate:	38.68764				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	85	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$10,625.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7067
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26248				
Y Coordinate:	38.68787				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	40	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.4% cross slope 10.5% running slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	1 Necessary	Cost Estimate:	\$5,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7068
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26247				
Y Coordinate:	38.68785				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	73	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$9,125.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7069
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26249				
Y Coordinate:	38.68805				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	40	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	11.4% running slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$5,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7070
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26248				
Y Coordinate:	38.68812				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	148	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$18,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7071A
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26246				
Y Coordinate:	38.68856				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	691	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$86,375.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7071B
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26248				
Y Coordinate:	38.68937				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	4	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7072
Location:	Fair Oaks Blvd and Woodmore Oaks - Corner D				
X Coordinate:	-121.26247				
Y Coordinate:	38.69197				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (4.1% to 4.9%)		
As Built Desc:	4.2% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two -way intersection corners A,D. Corner D compliant		

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7073
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26249				
Y Coordinate:	38.69229				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	165	Quantity:	LF
Description:	Cross slope exceeds 2.0% (2.1% to 3.0%)		
As Built Desc:	3.0% cross slope		
Solution:	Low severity barrier - no remediation recommended		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7074
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26249				
Y Coordinate:	38.69295				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	36	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	7.8% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$4,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7075
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26248				
Y Coordinate:	38.6931				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	36	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	9.3% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$4,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7076
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26248				
Y Coordinate:	38.69319				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	150	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$18,750.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7077
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.2625				
Y Coordinate:	38.69373				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	704	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$88,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7078
Location:	Fair Oaks Blvd and Copperfield Dr - Corner D				
X Coordinate:	-121.26265				
Y Coordinate:	38.69569				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)		
As Built Desc:	3.2% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,D. Corner A compliant
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7079A
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26262				
Y Coordinate:	38.69589				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	460	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$57,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7079B
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26263				
Y Coordinate:	38.69688				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - Tree Heaves				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1" lip due to tree heaves		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7080
Location:	Fair Oaks Blvd and San Consume Dr - Corner A				
X Coordinate:	-121.26268				
Y Coordinate:	38.6973				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (4.1% to 4.9%)		
As Built Desc:	4.6% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,D. Corner D compliant

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7081
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26263				
Y Coordinate:	38.69835				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	132	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$16,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7082
Location:	Fair Oaks Blvd - West				
X Coordinate:	-121.26265				
Y Coordinate:	38.69989				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	146	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$18,250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7083A
Location:	Oak Ave - South				
X Coordinate:	-121.26277				
Y Coordinate:	38.70035				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	178	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$22,250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 4/19/2011 Report Date: 4/19/2011 Barrier #: 7083B

Location: Oak Ave - South

X Coordinate: -121.26326

Y Coordinate: 38.70034

Barrier Area: Sidewalks

Barrier Type: Clear Width - Existing ($\leq 31"$ or less)

Code Ref: CBC 1133B.7.1



As Built Meas: 2 Quantity: LF

Description: Pedestrian route is not min. 48" wide ($\leq 31"$ or less)

As Built Desc: 24" clear width due to pole

Solution: Demolish existing and construct new route

Bar. Severity: 1 Necessary Cost Estimate: \$250.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/19/2011 Report Date: 4/19/2011 Barrier #: 7084A

Location: Oak Ave and Single Ave - Corner C

X Coordinate: -121.26342

Y Coordinate: 38.70032

Barrier Area: Curb Ramps

Barrier Type: 12" Grooves - Existing ($> 5.0\%$)

Code Ref: CBC 1127B.5.6



As Built Meas: 1 Quantity: EACH

Description: 12" grooves at top of curb ramp are not level ($> 5.0\%$)

As Built Desc: 11.3% at 12" grooves

Solution: Demolish existing and construct new curb ramp

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners C,D

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7084B
Location:	Oak Ave and Single Ave - Corner C				
X Coordinate:	-121.26342				
Y Coordinate:	38.70032				
Barrier Area:	Curb Ramps				
Barrier Type:	Running Slope - Existing (9.0% to 9.4%)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.1				



As Built Meas:	1	Quantity:	EACH
Description:	Ramp run cross slope exceeds 2.0% (9.0% to 9.4%)		
As Built Desc:	9.0% running slope		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C,D		

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7084C
Location:	Oak Ave and Single Ave - Corner C				
X Coordinate:	-121.26342				
Y Coordinate:	38.70032				
Barrier Area:	Curb Ramps				
Barrier Type:	Parallel Ramp Landing - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.4 and ADA/ABA 406.4				



As Built Meas:	1	Quantity:	EACH
Description:	Curb ramp landing or pan not level (3.1% to 4.0%)		
As Built Desc:	4.0% landing slope		
Solution:	Demolish existing and construct new transition		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C,D		

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7084D
Location:	Oak Ave and Single Ave - Corner C				
X Coordinate:	-121.26342				
Y Coordinate:	38.70032				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C,D		

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7084E
Location:	Oak Ave and Single Ave - Corner C				
X Coordinate:	-121.26342				
Y Coordinate:	38.70032				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (5.1% - 5.8%)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	1	Quantity:	SF
Description:	Gutter slope exceeds 5.0% (5.1% - 5.8%)		
As Built Desc:	5.5% gutter slope		
Solution:	Demolish existing and construct new gutter		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners C,D		

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7085A
Location:	Oak Ave and Single Ave - Corner D				
X Coordinate:	-121.26356				
Y Coordinate:	38.70032				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (>5.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (>5.0%)		
As Built Desc:	6.2% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners C,D

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7085B
Location:	Oak Ave and Single Ave - Corner D				
X Coordinate:	-121.26356				
Y Coordinate:	38.70032				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners C,D

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7086
Location:	Oak Ave - South				
X Coordinate:	-121.26365				
Y Coordinate:	38.70035				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	8	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7087
Location:	Oak Ave - South				
X Coordinate:	-121.26369				
Y Coordinate:	38.70037				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	90	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$11,250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date: 4/19/2011 Report Date: 4/19/2011 Barrier #: 7088

Location: Oak Ave - South

X Coordinate: -121.26394

Y Coordinate: 38.70035

Barrier Area: Sidewalks

Barrier Type: Driveway - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 30 Quantity: LF

Description: Driveway cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 14.3% cross slope, 12.8% running slope

Solution: Provide min. 48" wide level walkway through driveway

Bar. Severity: 1 Necessary Cost Estimate: \$3,750.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/19/2011 Report Date: 4/19/2011 Barrier #: 7089

Location: Oak Ave - South

X Coordinate: -121.2642

Y Coordinate: 38.70036

Barrier Area: Sidewalks

Barrier Type: Driveway - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 30 Quantity: LF

Description: Driveway cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 13.3% cross slope, 9.2% running slope

Solution: Provide min. 48" wide level walkway through driveway

Bar. Severity: 1 Necessary Cost Estimate: \$3,750.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7090
Location:	Oak Ave - South				
X Coordinate:	-121.26426				
Y Coordinate:	38.70035				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	150	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$18,750.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7091
Location:	Oak Ave - South				
X Coordinate:	-121.2648				
Y Coordinate:	38.70034				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	30	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	15.6% cross slope, 9.6% running slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	1 Necessary	Cost Estimate:	\$3,750.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7092
Location:	Oak Ave - South				
X Coordinate:	-121.26499				
Y Coordinate:	38.70033				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	30	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	12.9% cross slope, 10.6% running slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	1 Necessary	Cost Estimate:	\$3,750.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7093A
Location:	Oak Ave - South				
X Coordinate:	-121.26506				
Y Coordinate:	38.70035				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	306	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$38,250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7093B
Location:	Oak Ave - South				
X Coordinate:	-121.26593				
Y Coordinate:	38.70033				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	2	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to pole		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7094
Location:	Oak Ave - South				
X Coordinate:	-121.26613				
Y Coordinate:	38.70034				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	21	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	10.6% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$2,625.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7095
Location:	Oak Ave - South				
X Coordinate:	-121.26641				
Y Coordinate:	38.70032				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	21	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	12.0% cross slope, 10.8% running slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,625.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7096
Location:	Oak Ave - South				
X Coordinate:	-121.26663				
Y Coordinate:	38.70033				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	20	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	12.4% cross slope, 15.7% running slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7097
Location:	Oak Ave - South				
X Coordinate:	-121.26677				
Y Coordinate:	38.70032				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	20	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	12.1% cross slope, 11.3% running slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7098
Location:	Oak Ave - South				
X Coordinate:	-121.26678				
Y Coordinate:	38.70033				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	94	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$11,750.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7099
Location:	Oak Ave - South				
X Coordinate:	-121.26713				
Y Coordinate:	38.70032				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	21	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	11.6% cross slope, 13.8% running slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,625.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7100
Location:	Oak Ave - South				
X Coordinate:	-121.26738				
Y Coordinate:	38.70031				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	24	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	11.0% cross slope, 12.0% running slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	1 Necessary	Cost Estimate:	\$3,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7101
Location:	Oak Ave - South				
X Coordinate:	-121.26746				
Y Coordinate:	38.70031				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7102
Location:	Oak Ave - South				
X Coordinate:	-121.26757				
Y Coordinate:	38.70032				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7103
Location:	Oak Ave - South				
X Coordinate:	-121.26767				
Y Coordinate:	38.70031				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	21	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	10.8% cross slope, 15.4% running slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,625.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7104
Location:	Oak Ave - South				
X Coordinate:	-121.26791				
Y Coordinate:	38.70029				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	24	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	9.8% cross slope, 13.6% running slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	1 Necessary	Cost Estimate:	\$3,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7105
Location:	Oak Ave - South				
X Coordinate:	-121.26816				
Y Coordinate:	38.7003				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	60	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	11.4% cross slope, 13.8% running slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	1 Necessary	Cost Estimate:	\$7,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7106
Location:	Oak Ave - South				
X Coordinate:	-121.26845				
Y Coordinate:	38.7003				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	22	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	9.8% cross slope, 11.8% running slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,750.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7107
Location:	Oak Ave - South				
X Coordinate:	-121.26869				
Y Coordinate:	38.7003				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	22	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	11.9% cross slope, 15.6% running slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,750.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7108
Location:	Oak Ave - South				
X Coordinate:	-121.2688				
Y Coordinate:	38.7003				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	53	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$6,625.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7109
Location:	Oak Ave - South				
X Coordinate:	-121.269				
Y Coordinate:	38.70029				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	24	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	10.4% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$3,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7110
Location:	Oak Ave and Canelo Hills Dr -Corner A				
X Coordinate:	-121.26949				
Y Coordinate:	38.7004				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at transition into roadway		
As Built Desc:	No detectable warning provided		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Three - way intersection corners A,C,D
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7111A
Location:	Oak Ave and Canelo Hills Dr -Corner C				
X Coordinate:	-121.26927				
Y Coordinate:	38.70023				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (>5.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (>5.0%)		
As Built Desc:	5.8% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Three - way intersection corners A,C,D		

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7111B
Location:	Oak Ave and Canelo Hills Dr -Corner C				
X Coordinate:	-121.26927				
Y Coordinate:	38.70023				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Three - way intersection corners A,C,D		

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7111C
Location:	Oak Ave and Canelo Hills Dr -Corner C				
X Coordinate:	-121.26927				
Y Coordinate:	38.70023				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (8.3% or more)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	6	Quantity:	SF
Description:	Gutter slope exceeds 5.0% (8.3% or more)		
As Built Desc:	1.5% gutter slope		
Solution:	Demolish existing and construct new gutter		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Three - way intersection corners A,C,D		

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7112
Location:	Oak Ave and Canelo Hills Dr -Corner D				
X Coordinate:	-121.26947				
Y Coordinate:	38.70025				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Three - way intersection corners A,C,D		

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7113
Location:	Oak Ave - South				
X Coordinate:	-121.26955				
Y Coordinate:	38.70026				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	80	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$10,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7114
Location:	Oak Ave - South				
X Coordinate:	-121.26985				
Y Coordinate:	38.70027				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway -12" Grooves Incorrect Application				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	JOB
Description:	12" grooves required only at curb ramps identified at transition into driveway		
As Built Desc:	12" grooves incorrectly provided where no curb ramp exists		
Solution:	No remediation recommended, until new construction is performed in area		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7115
Location:	Oak Ave - South				
X Coordinate:	-121.26999				
Y Coordinate:	38.70026				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway -12" Grooves Incorrect Application				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	JOB
Description:	12" grooves required only at curb ramps identified at transition into driveway		
As Built Desc:	12" grooves incorrectly provided where no curb ramp exists		
Solution:	No remediation recommended, until new construction is performed in area		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7116A
Location:	Oak Ave - South				
X Coordinate:	-121.27002				
Y Coordinate:	38.70026				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	454	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$56,750.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7116B
Location:	Oak Ave - South				
X Coordinate:	-121.27049				
Y Coordinate:	38.70027				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	2	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to pole		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7116C
Location:	Oak Ave - South				
X Coordinate:	-121.27092				
Y Coordinate:	38.70026				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	2	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to pole		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date: 4/19/2011 Report Date: 4/19/2011 Barrier #: 7117

Location: Sunrise Blvd - East

X Coordinate: -121.27169

Y Coordinate: 38.70011

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 139 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.4% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$17,375.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/19/2011 Report Date: 4/19/2011 Barrier #: 7118

Location: Sunrise Blvd - East

X Coordinate: -121.27167

Y Coordinate: 38.69987

Barrier Area: Sidewalks

Barrier Type: Clear Width - Existing ($\leq 31"$ or less)

Code Ref: CBC 1133B.7.1



As Built Meas: 8 Quantity: LF

Description: Pedestrian route is not min. 48" wide ($\leq 31"$ or less)

As Built Desc: 24" clear width due to pole

Solution: Demolish existing and construct new route

Bar. Severity: 1 Necessary Cost Estimate: \$1,000.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7119
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27167				
Y Coordinate:	38.69971				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	40	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	12.9% cross slope, 13.4% running slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	1 Necessary	Cost Estimate:	\$5,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7120
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27168				
Y Coordinate:	38.69961				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	2	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to pole		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7121A
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27166				
Y Coordinate:	38.69957				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	112	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$14,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7121B
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27166				
Y Coordinate:	38.69937				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	2	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to pole		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7122
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27164				
Y Coordinate:	38.69924				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	40	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	16.7% cross slope, 8.9% running slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	1 Necessary	Cost Estimate:	\$5,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7123
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27165				
Y Coordinate:	38.69919				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	77	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$9,625.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7124
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27164				
Y Coordinate:	38.69892				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	40	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	11.7% cross slope, 11.7% running slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	1 Necessary	Cost Estimate:	\$5,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7125
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27164				
Y Coordinate:	38.69887				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	2	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to pole		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7126
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27164				
Y Coordinate:	38.69885				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	133	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$16,625.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7127
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27157				
Y Coordinate:	38.69669				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	87	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$10,875.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7128
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27156				
Y Coordinate:	38.69641				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	35	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.9% cross slope, 9.5% running slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	1 Necessary	Cost Estimate:	\$4,375.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7129
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27155				
Y Coordinate:	38.69632				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	232	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$29,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7130A
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27155				
Y Coordinate:	38.69573				
Barrier Area:	Bus Stops and Shelters				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1121B.2.1 and ADAAG 10.2.1(1)				



As Built Meas:	4	Quantity:	LF
Description:	Cross slope at bus pad or shelter exceeds 2.0% (5.0% or more)		
As Built Desc:	8.0% cross slope		
Solution:	Demolish existing and construct new bus pad or shelter pad		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7130B
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27155				
Y Coordinate:	38.69573				
Barrier Area:	Bus Stops and Shelters				
Barrier Type:	Bench Seat Depth				
Code Ref:	ADAAG 4.37.1 and ADA/ABA 903.4				



As Built Meas:	1	Quantity:	EACH
Description:	Bench seat depth not 20" - 24" deep		
As Built Desc:	18" bench seat depth		
Solution:	Provide min. 1 accessible bench at bench stop		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$775.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7131
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27156				
Y Coordinate:	38.69571				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	74	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$9,250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7132
Location:	Sunrise Blvd and Sundgarden Dr - Corner B				
X Coordinate:	-121.2715				
Y Coordinate:	38.69547				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7133
Location:	Sunrise Blvd and Sundgarden Dr - Corner C				
X Coordinate:	-121.27152				
Y Coordinate:	38.69529				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	5.0% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7134
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27154				
Y Coordinate:	38.69522				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	181	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$22,625.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7135
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27149				
Y Coordinate:	38.6947				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	40	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	7.5% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$5,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7136
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27151				
Y Coordinate:	38.69461				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	438	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$54,750.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date: 4/19/2011 Report Date: 4/19/2011 Barrier #: 7137

Location: Sunrise Blvd - East

X Coordinate: -121.27149

Y Coordinate: 38.69335

Barrier Area: Sidewalks

Barrier Type: Driveway - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 40 Quantity: LF

Description: Driveway cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.9% cross slope

Solution: Provide min. 48" wide level walkway through driveway

Bar. Severity: 3 Hindrance Cost Estimate: \$5,000.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/19/2011 Report Date: 4/19/2011 Barrier #: 7138

Location: Sunrise Blvd - East

X Coordinate: -121.2715

Y Coordinate: 38.69332

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 233 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.6% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hindrance Cost Estimate: \$29,125.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7139A
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27148				
Y Coordinate:	38.69266				
Barrier Area:	Bus Stops and Shelters				
Barrier Type:	Bench Seat Depth				
Code Ref:	ADAAG 4.37.1 and ADA/ABA 903.4				



As Built Meas:	1	Quantity:	EACH
Description:	Bench seat depth not 20" - 24" deep		
As Built Desc:	12" bench seat depth		
Solution:	Provide min. 1 accessible bench at bench stop		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$775.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7139B
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27148				
Y Coordinate:	38.69266				
Barrier Area:	Bus Stops and Shelters				
Barrier Type:	Bench Seat Height				
Code Ref:	ADAAG 4.37.3* and ADA/ABA 903.4				



As Built Meas:	1	Quantity:	EACH
Description:	Bench seat height not between 17" - 19"		
As Built Desc:	16" bench seat height		
Solution:	Provide new compliant bench or remount at compliant height where possible		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7140
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27147				
Y Coordinate:	38.69176				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	40	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.3% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$5,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7141
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27147				
Y Coordinate:	38.69166				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	4	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7142
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27147				
Y Coordinate:	38.69169				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	76	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$9,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7143
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27148				
Y Coordinate:	38.69139				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	40	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.5% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$5,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7144A
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27148				
Y Coordinate:	38.69129				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	79	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$9,875.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7144B
Location:	Sunrise Blvd - East				
X Coordinate:	-121.2715				
Y Coordinate:	38.69111				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	4	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7145
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27149				
Y Coordinate:	38.69094				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	5	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7146A
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27149				
Y Coordinate:	38.69092				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	333	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$41,625.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7146B
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27148				
Y Coordinate:	38.69007				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	5	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7147
Location:	Sunrise Blvd - East				
X Coordinate:	-121.2715				
Y Coordinate:	38.68972				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	1100	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$137,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7148A
Location:	Sunrise Blvd and Larwin Dr - Corner B				
X Coordinate:	-121.27143				
Y Coordinate:	38.68671				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (>5.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (>5.0%)		
As Built Desc:	6.4% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7148B
Location:	Sunrise Blvd and Larwin Dr - Corner B				
X Coordinate:	-121.27143				
Y Coordinate:	38.68671				
Barrier Area:	Curb Ramps				
Barrier Type:	Running Slope - Existing (9.5% or more)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.1				



As Built Meas:	1	Quantity:	EACH
Description:	Ramp run cross slope exceeds 2.0% (9.5% or more)		
As Built Desc:	15.7% running slope		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7148C
Location:	Sunrise Blvd and Larwin Dr - Corner B				
X Coordinate:	-121.27143				
Y Coordinate:	38.68671				
Barrier Area:	Curb Ramps				
Barrier Type:	Parallel Ramp Landing - Existing (>5.0% or more)				
Code Ref:	CBC 1127B.5.4 and ADA/ABA 406.4				



As Built Meas:	1	Quantity:	EACH
Description:	Curb ramp landing or pan not level (>5.0% or more)		
As Built Desc:	6.7% landing slope		
Solution:	Demolish existing and construct new transition		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7148D
Location:	Sunrise Blvd and Larwin Dr - Corner B				
X Coordinate:	-121.27143				
Y Coordinate:	38.68671				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7149A
Location:	Sunrise Blvd and Larwin Dr - Corner C				
X Coordinate:	-121.27144				
Y Coordinate:	38.68658				
Barrier Area:	Curb Ramps				
Barrier Type:	Parallel Ramp Landing - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1127B.5.4 and ADA/ABA 406.4				



As Built Meas:	1	Quantity:	EACH
Description:	Curb ramp landing or pan not level (2.1% to 3.0%)		
As Built Desc:	3.0% landing slope		
Solution:	Demolish existing and construct new transition		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners B,C

Field Date:	4/19/2011	Report Date:	4/19/2011	Barrier #:	7149B
Location:	Sunrise Blvd and Larwin Dr - Corner C				
X Coordinate:	-121.27144				
Y Coordinate:	38.68658				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners B,C

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7150
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27144				
Y Coordinate:	38.68652				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	108	Quantity:	LF
Description:	Cross slope exceeds 2.0% (2.1% to 3.0%)		
As Built Desc:	3.0% cross slope		
Solution:	Low severity barrier - no remediation recommended		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7151
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27132				
Y Coordinate:	38.68602				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	2	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to pole		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7152
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27131				
Y Coordinate:	38.68594				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	5	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7153
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27129				
Y Coordinate:	38.68583				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	5	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to pole		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$625.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7154
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27129				
Y Coordinate:	38.68578				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	88	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$11,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7155A
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27135				
Y Coordinate:	38.68558				
Barrier Area:	Bus Stops and Shelters				
Barrier Type:	Bench Seat Depth				
Code Ref:	ADAAG 4.37.1 and ADA/ABA 903.4				



As Built Meas:	1	Quantity:	EACH
Description:	Bench seat depth not 20" - 24" deep		
As Built Desc:	12" bench seat depth		
Solution:	Provide min. 1 accessible bench at bench stop		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$775.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7155B
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27135				
Y Coordinate:	38.68558				
Barrier Area:	Bus Stops and Shelters				
Barrier Type:	Bench Back Support				
Code Ref:	ADAAG 4.37.4 and ADA/ABA 903.4				



As Built Meas:	1	Quantity:	EACH
Description:	Bench has no back support of at least 18" high		
As Built Desc:	16" back support height"		
Solution:	Provide min. 1 accessible bench at bench stop or shelter		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7156
Location:	Sunrise Blvd and Sayonara Dr - Corner A				
X Coordinate:	-121.2717				
Y Coordinate:	38.68544				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (>5.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (>5.0%)		
As Built Desc:	10.7% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,D
--------	------------------------------------

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7157
Location:	Sunrise Blvd and Sayonara Dr - corner D (A-B)				
X Coordinate:	-121.27173				
Y Coordinate:	38.68529				
Barrier Area:	Signalized Intersections				
Barrier Type:	APS Vibrotactile Control				
Code Ref:	PROWAG R306.2				



As Built Meas:	1	Quantity:	JOB
Description:	No vibrotactile pedestrian buttons provided		
As Built Desc:	No level landing provided at ped buttons and no vibrotactile buttons provided		
Solution:	Recommended: Provide vibrotactile ped buttons		
Bar. Severity:	1 Necessary	Cost Estimate:	\$4,700.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,D		

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7158A
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27146				
Y Coordinate:	38.68527				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	157	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$19,625.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7158B
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27145				
Y Coordinate:	38.68497				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	5	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7159
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27145				
Y Coordinate:	38.68457				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	32	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.9% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$4,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7160
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27146				
Y Coordinate:	38.68447				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	5	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to pole		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$625.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7161
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27146				
Y Coordinate:	38.68443				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	5	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to pole		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$625.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7162
Location:	Sunrise Blvd - East				
X Coordinate:	-121.2715				
Y Coordinate:	38.68436				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	5	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7163
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27146				
Y Coordinate:	38.68414				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	10	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to pole and guide wire		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7164
Location:	Sunrise Blvd - East				
X Coordinate:	-121.2714				
Y Coordinate:	38.68384				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	5	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked Utility Cover		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$625.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7165
Location:	Sunrise Blvd - East				
X Coordinate:	-121.2714				
Y Coordinate:	38.68387				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	136	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$17,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 4/20/2011 Report Date: 4/20/2011 Barrier #: 7166

Location: Sunrise Blvd - East

X Coordinate: -121.27144

Y Coordinate: 38.68335

Barrier Area: Sidewalks

Barrier Type: Driveway - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 53 Quantity: LF

Description: Driveway cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 5.9% cross slope

Solution: Provide min. 48" wide level walkway through driveway

Bar. Severity: 4 Low Severity Cost Estimate: \$6,625.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/20/2011 Report Date: 4/20/2011 Barrier #: 7167

Location: Sunrise Blvd - East

X Coordinate: -121.27144

Y Coordinate: 38.68327

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 123 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.5% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hindrance Cost Estimate: \$15,375.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/20/2011 Report Date: 4/20/2011 Barrier #: 7168

Location: Sunrise Blvd - East

X Coordinate: -121.2714

Y Coordinate: 38.68287

Barrier Area: Sidewalks

Barrier Type: Driveway - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 55 Quantity: LF

Description: Driveway cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 6.9% cross slope, 9.2% running slope

Solution: Provide min. 48" wide level walkway through driveway

Bar. Severity: 1 Necessary Cost Estimate: \$6,875.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/20/2011 Report Date: 4/20/2011 Barrier #: 7169

Location: Sunrise Blvd - East

X Coordinate: -121.27141

Y Coordinate: 38.68281

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 226 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.3% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$28,250.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/20/2011 Report Date: 4/20/2011 Barrier #: 7170

Location: Sunrise Blvd - East

X Coordinate: -121.27142

Y Coordinate: 38.68207

Barrier Area: Sidewalks

Barrier Type: Driveway - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 54 Quantity: LF

Description: Driveway cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 5.5% cross slope

Solution: Provide min. 48" wide level walkway through driveway

Bar. Severity: 4 Low Severity Cost Estimate: \$6,750.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/20/2011 Report Date: 4/20/2011 Barrier #: 7171

Location: Sunrise Blvd - East

X Coordinate: -121.2714

Y Coordinate: 38.682

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 171 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.1% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$21,375.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7172
Location:	Sunrise Blvd and Arcadia Dr - Corner C (A-B)				
X Coordinate:	-121.27132				
Y Coordinate:	38.68124				
Barrier Area:	Curb Ramps				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	1	Quantity:	EACH
Description:	Ramp run cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.8% cross slope		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Four - way intersection corners A, B, C, D

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7173
Location:	Sunrise Blvd and Arcadia Dr - Corner C (A-A)				
X Coordinate:	-121.27139				
Y Coordinate:	38.68119				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (>5.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (>5.0%)		
As Built Desc:	5.4% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Four - way intersection corners A, B, C, D

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7174A
Location:	Sunrise Blvd and Arcadia Dr - Corner D (A-B)				
X Coordinate:	-121.27174				
Y Coordinate:	38.6812				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)		
As Built Desc:	3.7% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A, B, C, D		

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7174B
Location:	Sunrise Blvd and Arcadia Dr - Corner D (A-A)				
X Coordinate:	-121.27174				
Y Coordinate:	38.6812				
Barrier Area:	Curb Ramps				
Barrier Type:	Running Slope - Existing (9.0% to 9.4%)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.1				



As Built Meas:	1	Quantity:	EACH
Description:	Ramp run cross slope exceeds 2.0% (9.0% to 9.4%)		
As Built Desc:	9.2% running slope		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A, B, C, D		

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7175
Location:	Arcadia Dr - North				
X Coordinate:	-121.27129				
Y Coordinate:	38.68144				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	173	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$21,625.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7176
Location:	Arcadia Dr - North				
X Coordinate:	-121.27064				
Y Coordinate:	38.68134				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	42	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.3% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	2 Recommended	Cost Estimate:	\$5,250.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7177
Location:	Arcadia Dr - North				
X Coordinate:	-121.27064				
Y Coordinate:	38.68132				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	44	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (2.1% to 3.0%)		
As Built Desc:	2.9% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	1 Necessary	Cost Estimate:	\$5,500.00
		Status:	
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7178
Location:	Arcadia Dr - North				
X Coordinate:	-121.26862				
Y Coordinate:	38.68059				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	238	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	2 Recommended	Cost Estimate:	\$29,750.00
		Status:	
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 4/20/2011 Report Date: 4/20/2011 Barrier #: 7179

Location: Arcadia Dr - North

X Coordinate: -121.26785

Y Coordinate: 38.68041

Barrier Area: Sidewalks

Barrier Type: Driveway - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 37 Quantity: LF

Description: Driveway cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.2% cross slope

Solution: Provide min. 48" wide level walkway through driveway

Bar. Severity: 3 Hindrance Cost Estimate: \$4,625.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/20/2011 Report Date: 4/20/2011 Barrier #: 7180

Location: Arcadia Dr - East

X Coordinate: -121.26705

Y Coordinate: 38.68011

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 34 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.9% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$4,250.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7181
Location:	Arcadia Dr - East				
X Coordinate:	-121.26706				
Y Coordinate:	38.68008				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7182
Location:	Arcadia Dr - East				
X Coordinate:	-121.26705				
Y Coordinate:	38.67978				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	40	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.4% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$5,000.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7183A
Location:	Arcadia Dr - East				
X Coordinate:	-121.26703				
Y Coordinate:	38.6797				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	90	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$11,250.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7183B
Location:	Arcadia Dr - East				
X Coordinate:	-121.26704				
Y Coordinate:	38.67948				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	5	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$625.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7184
Location:	Arcadia Dr - East				
X Coordinate:	-121.26703				
Y Coordinate:	38.67936				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	44	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	8.0% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$5,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7185A
Location:	Arcadia Dr - East				
X Coordinate:	-121.26704				
Y Coordinate:	38.67927				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	65	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$8,125.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7185B
Location:	Arcadia Dr - East				
X Coordinate:	-121.26704				
Y Coordinate:	38.67927				
Barrier Area:	Sidewalks				
Barrier Type:	Protruding Hazard				
Code Ref:	CBC 1133B.8.6.1 and ADA/ABA 307.2				



As Built Meas:	1	Quantity:	JOB
Description:	Protruding object in route of travel between 27" and 80" high		
As Built Desc:	28" at tree branch		
Solution:	Remove object or provide detectable warning		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,400.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7186
Location:	Arcadia Dr - East				
X Coordinate:	-121.26702				
Y Coordinate:	38.67903				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	35	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$4,375.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7187
Location:	Arcadia Dr - East				
X Coordinate:	-121.26701				
Y Coordinate:	38.67876				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	37	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$4,625.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7188A
Location:	Arcadia Dr - West				
X Coordinate:	-121.26727				
Y Coordinate:	38.67896				
Barrier Area:	Bus Stops and Shelters				
Barrier Type:	Bench Seat Depth				
Code Ref:	ADAAG 4.37.1 and ADA/ABA 903.4				



As Built Meas:	1	Quantity:	EACH
Description:	Bench seat depth not 20" - 24" deep		
As Built Desc:	12" bench seat depth		
Solution:	Provide min. 1 accessible bench at bench stop		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$775.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7188B
Location:	Arcadia Dr - West				
X Coordinate:	-121.26727				
Y Coordinate:	38.67896				
Barrier Area:	Bus Stops and Shelters				
Barrier Type:	Bench Back Support				
Code Ref:	ADAAG 4.37.4 and ADA/ABA 903.4				



As Built Meas:	1	Quantity:	EACH
Description:	Bench has no back support of at least 18" high		
As Built Desc:	17" back support height		
Solution:	Provide min. 1 accessible bench at bench stop or shelter		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$0.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7189A
Location:	Arcadia Dr - West				
X Coordinate:	-121.26727				
Y Coordinate:	38.67897				
Barrier Area:	Bus Stops and Shelters				
Barrier Type:	Bench Seat Height				
Code Ref:	ADAAG 4.37.3* and ADA/ABA 903.4				



As Built Meas:	1	Quantity:	EACH
Description:	Bench seat height not between 17" - 19"		
As Built Desc:	20" bench seat height		
Solution:	Provide new compliant bench or remount at compliant height where possible		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$775.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7189B
Location:	Arcadia Dr - West				
X Coordinate:	-121.26727				
Y Coordinate:	38.67897				
Barrier Area:	Bus Stops and Shelters				
Barrier Type:	Bench Seat Depth				
Code Ref:	ADAAG 4.37.1 and ADA/ABA 903.4				



As Built Meas:	1	Quantity:	EACH
Description:	Bench seat depth not 20" - 24" deep		
As Built Desc:	9-1/2" bench seat depth		
Solution:	Provide min. 1 accessible bench at bench stop		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$0.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7189C
Location:	Arcadia Dr - West				
X Coordinate:	-121.26727				
Y Coordinate:	38.67897				
Barrier Area:	Bus Stops and Shelters				
Barrier Type:	Bench Back Support				
Code Ref:	ADAAG 4.37.4 and ADA/ABA 903.4				



As Built Meas:	1	Quantity:	EACH
Description:	Bench has no back support of at least 18" high		
As Built Desc:	No back support provided		
Solution:	Provide min. 1 accessible bench at bench stop or shelter		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$0.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date: 4/20/2011 Report Date: 4/20/2011 Barrier #: 7190

Location: Arcadia Dr -West

X Coordinate: -121.26725

Y Coordinate: 38.67982

Barrier Area: Sidewalks

Barrier Type: Driveway - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 40 Quantity: LF

Description: Driveway cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.7% cross slope

Solution: Provide min. 48" wide level walkway through driveway

Bar. Severity: 3 Hindrance Cost Estimate: \$5,000.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/20/2011 Report Date: 4/20/2011 Barrier #: 7191

Location: Arcadia Dr - South

X Coordinate: -121.26799

Y Coordinate: 38.6803

Barrier Area: Sidewalks

Barrier Type: Driveway - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 42 Quantity: LF

Description: Driveway cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.2% cross slope

Solution: Provide min. 48" wide level walkway through driveway

Bar. Severity: 3 Hindrance Cost Estimate: \$5,250.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7192A
Location:	Arcadia Dr - South				
X Coordinate:	-121.26803				
Y Coordinate:	38.68027				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	153	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$19,125.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7192B
Location:	Arcadia Dr - South				
X Coordinate:	-121.26857				
Y Coordinate:	38.68047				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7193
Location:	Arcadia Dr - South				
X Coordinate:	-121.26808				
Y Coordinate:	38.68033				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	38	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.6% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$4,750.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7194
Location:	Arcadia Dr - South				
X Coordinate:	-121.26869				
Y Coordinate:	38.68049				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	327	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$40,875.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7195
Location:	Arcadia Dr - South				
X Coordinate:	-121.26979				
Y Coordinate:	38.68078				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	46	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	2 Recommended	Cost Estimate:	\$5,750.00
		Status:	
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7196
Location:	Arcadia Dr - South				
X Coordinate:	-121.27078				
Y Coordinate:	38.68121				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	43	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	2 Recommended	Cost Estimate:	\$5,375.00
		Status:	
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7197
Location:	Sunrise Blvd - East				
X Coordinate:	-121.2714				
Y Coordinate:	38.68069				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	143	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$17,875.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7198
Location:	Sunrise Blvd - East				
X Coordinate:	-121.2714				
Y Coordinate:	38.68022				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	36	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	7.0% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$4,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7199
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27137				
Y Coordinate:	38.67955				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	319	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$39,875.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7200
Location:	Sunrise Blvd - East				
X Coordinate:	-121.2714				
Y Coordinate:	38.68021				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	36	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.5% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$4,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7201
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27139				
Y Coordinate:	38.6795				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	200	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$25,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7202A
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27135				
Y Coordinate:	38.679				
Barrier Area:	Bus Stops and Shelters				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1121B.2.1 and ADAAG 10.2.1(1)				



As Built Meas:	4	Quantity:	LF
Description:	Cross slope at bus pad or shelter exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new bus pad or shelter pad		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7202B
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27135				
Y Coordinate:	38.679				
Barrier Area:	Bus Stops and Shelters				
Barrier Type:	Bench Seat Height				
Code Ref:	ADAAG 4.37.3* and ADA/ABA 903.4				



As Built Meas:	1	Quantity:	EACH
Description:	Bench seat height not between 17" - 19"		
As Built Desc:	20" bench seat height		
Solution:	Provide new compliant bench or remount at compliant height where possible		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$775.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7202C
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27135				
Y Coordinate:	38.679				
Barrier Area:	Bus Stops and Shelters				
Barrier Type:	Bench Seat Depth				
Code Ref:	ADAAG 4.37.1 and ADA/ABA 903.4				



As Built Meas:	1	Quantity:	EACH
Description:	Bench seat depth not 20" - 24" deep		
As Built Desc:	9-1/2" bench seat depth		
Solution:	Provide min. 1 accessible bench at bench stop		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7202D
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27135				
Y Coordinate:	38.679				
Barrier Area:	Bus Stops and Shelters				
Barrier Type:	Bench Back Support				
Code Ref:	ADAAG 4.37.4 and ADA/ABA 903.4				



As Built Meas:	1	Quantity:	EACH
Description:	Bench has no back support of at least 18" high		
As Built Desc:	No back support provided		
Solution:	Provide min. 1 accessible bench at bench stop or shelter		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7203
Location:	Greenback Ln - North				
X Coordinate:	-121.27123				
Y Coordinate:	38.67861				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	178	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$22,250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7204
Location:	Greenback Ln - North				
X Coordinate:	-121.27051				
Y Coordinate:	38.67863				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	48	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	8.8% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$6,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7205
Location:	Greenback Ln - North				
X Coordinate:	-121.27046				
Y Coordinate:	38.67859				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	322	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$40,250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7206
Location:	Greenback Ln and "Wendy's" Entrance - Corner A				
X Coordinate:	-121.26923				
Y Coordinate:	38.67861				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (2.1% to 3.0%)		
As Built Desc:	3.0% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7207
Location:	Greenback Ln and "Wendy's" Entrance - Corner B				
X Coordinate:	-121.26907				
Y Coordinate:	38.67862				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at transition into roadway		
As Built Desc:	No detectable warning provided		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date: 4/20/2011 Report Date: 4/20/2011 Barrier #: 7208

Location: Greenback Ln - North

X Coordinate: -121.269

Y Coordinate: 38.67861

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 132 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.1% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$16,500.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/20/2011 Report Date: 4/20/2011 Barrier #: 7209A

Location: Greenback Ln - North

X Coordinate: -121.26848

Y Coordinate: 38.6786

Barrier Area: Bus Stops and Shelters

Barrier Type: Bench Seat Depth

Code Ref: ADAAG 4.37.1 and ADA/ABA 903.4



As Built Meas: 1 Quantity: EACH

Description: Bench seat depth not 20" - 24" deep

As Built Desc: 9-1/2" bench seat depth

Solution: Provide min. 1 accessible bench at bench stop

Bar. Severity: 3 Hindrance Cost Estimate: \$775.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/20/2011 Report Date: 4/20/2011 Barrier #: 7209B

Location: Greenback Ln - North

X Coordinate: -121.26848

Y Coordinate: 38.6786

Barrier Area: Bus Stops and Shelters

Barrier Type: Bench Seat Height

Code Ref: ADAAG 4.37.3* and ADA/ABA 903.4



As Built Meas: 1 Quantity: EACH

Description: Bench seat height not between 17" - 19"

As Built Desc: 20" bench seat height

Solution: Provide new compliant bench or remount at compliant height where possible

Bar. Severity: 3 Hindrance Cost Estimate: \$0.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/20/2011 Report Date: 4/20/2011 Barrier #: 7209C

Location: Greenback Ln - North

X Coordinate: -121.26848

Y Coordinate: 38.6786

Barrier Area: Bus Stops and Shelters

Barrier Type: Bench Back Support

Code Ref: ADAAG 4.37.4 and ADA/ABA 903.4



As Built Meas: 1 Quantity: EACH

Description: Bench has no back support of at least 18" high

As Built Desc: No back rest supported

Solution: Provide min. 1 accessible bench at bench stop or shelter

Bar. Severity: 3 Hindrance Cost Estimate: \$0.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7210
Location:	Greenback Ln and "Wise Buys" Entrance - Corner B				
X Coordinate:	-121.26807				
Y Coordinate:	38.67865				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at transition into roadway		
As Built Desc:	No detectable warning provided		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corner A,B. Corner A compliant		

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7211
Location:	Greenback Ln - North				
X Coordinate:	-121.26801				
Y Coordinate:	38.67865				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	206	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$25,750.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7212
Location:	Greenback Ln - North				
X Coordinate:	-121.26613				
Y Coordinate:	38.67866				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7213
Location:	Greenback Ln - North				
X Coordinate:	-121.26636				
Y Coordinate:	38.67863				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	43	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.5% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$5,375.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7214
Location:	Greenback Ln - North				
X Coordinate:	-121.26602				
Y Coordinate:	38.67869				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	152	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$19,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7215
Location:	Greenback Ln - North				
X Coordinate:	-121.26545				
Y Coordinate:	38.67867				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	38	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope, 9.0% running slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	1 Necessary	Cost Estimate:	\$4,750.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 4/20/2011 Report Date: 4/20/2011 Barrier #: 7216

Location: Greenback Ln - North

X Coordinate: -121.26534

Y Coordinate: 38.67869

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 225 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.6% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hindrance Cost Estimate: \$28,125.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 4/20/2011 Report Date: 4/20/2011 Barrier #: 7217

Location: Greenback Ln - North

X Coordinate: -121.26455

Y Coordinate: 38.67871

Barrier Area: Sidewalks

Barrier Type: Driveway - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 48 Quantity: LF

Description: Driveway cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.5% cross slope

Solution: Provide min. 48" wide level walkway through driveway

Bar. Severity: 3 Hindrance Cost Estimate: \$6,000.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7218
Location:	Greenback Ln - North				
X Coordinate:	-121.26363				
Y Coordinate:	38.67869				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	36	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.7% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$4,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7219
Location:	Greenback Ln - North				
X Coordinate:	-121.2635				
Y Coordinate:	38.67874				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	77	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$9,625.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7220
Location:	Greenback Ln - North				
X Coordinate:	-121.26326				
Y Coordinate:	38.67872				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	22	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	8.0% cross slope, 12.1% running slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,750.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7221
Location:	Greenback Ln - North				
X Coordinate:	-121.26317				
Y Coordinate:	38.67872				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	77	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$9,625.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7222
Location:	Greenback Ln - North				
X Coordinate:	-121.26284				
Y Coordinate:	38.67874				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	48	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	7.4% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$6,000.00
		Status:	
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	4/20/2011	Report Date:	4/20/2011	Barrier #:	7223
Location:	Greenback Ln - North				
X Coordinate:	-121.26272				
Y Coordinate:	38.67874				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	77	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$9,625.00
		Status:	
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--



CITRUS HEIGHTS CITY

Neighborhood Area 9 SONA

Field Date:		Report Date:		Barrier #:	
Location:					
X Coordinate:					
Y Coordinate:					
Barrier Area:					
Barrier Type:					
Code Ref:					
As Built Meas:		Quantity:			
Description:					
As Built Desc:					
Solution:					
Bar. Severity:		Cost Estimate:		Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:					

Cost Estimate Total Summary :	\$19,730,225.00
--------------------------------------	------------------------

Cost Estimate - Priority 1:	\$2,443,700.00
------------------------------------	-----------------------

Cost Estimate - Priority 2:	\$1,417,075.00
------------------------------------	-----------------------

Cost Estimate - Priority 3:	\$1,806,300.00
------------------------------------	-----------------------

Cost Estimate - Priority 4:	\$14,063,150.00
------------------------------------	------------------------
